



Intertek Testing Services
ETL SEMKO

8431 Murphy Drive
Middleton, WI 53562

ITS TEST REPORT #J20049092, 3005306
TEST OF A WOOD BURNING STOVE
FOR EMISSIONS AND EFFICIENCY
PER EPA METHOD 28 AND 5G-3
MODEL: 3600
FOR
MORSO JERNSTOBERI
DK-7900
NYKOBING MORS, DENMARK
REPORT DATE: 15 AUGUST, 2001

TEST OF A WOOD BURNING STOVE

FOR

EMISSIONS AND EFFICIENCY

PER

EPA METHODS 28 AND 5G-3

#J20049092, 3005306

MODEL: 3600

FOR

MORSO JERNSTOBERI
NYKOBING MORS, DENMARK

TESTED BY:

INTERTEK TESTING SERVICES NA INC.
8431 MURPHY DRIVE
MIDDLETON, WISCONSIN 53562

TEST DATES: August 8-9, 2001
REPORT DATE: August 15, 2001

All services undertaken are subject to the following general policy: Reports are submitted for exclusive use of the clients to whom they are addressed. Their significance is subject to the adequacy and representative character of the samples and to the comprehensiveness of the tests, examinations, or surveys made. No quotations from reports or use of the Intertek Testing Services NA name, logo, or registered (WH) mark is permitted except as expressly authorized by Intertek Testing Services NA Inc. in writing.

I. INTRODUCTION

A. General..... 4
B. Test Unit Description..... 4
C. Results 4
D. Pretest Information..... 5
E. Report Organization 5

II. SUMMARY OF TEST RESULTS

A. Emissions 6
B. Weighted Average Calculation..... 6
C. Test Facility Conditions 7
D. Fuel Qualities..... 7
E. Dilution Tunnel Flow Rate Measurement
and Sampling Data (5G-3)..... 8
F. Dilution Tunnel Dual Train Precision 8
G. General Summary of Results..... 9

III. PROCESS DESCRIPTION

A. Discussion 10
B. Unit Dimensions 11
C. Air Supply System..... 11
D. Operation during Test 11
E. Start-Up Operation..... 12

IV. SAMPLING SYSTEMS

A. Sampling Locations 12
1. Dilution Tunnel (Figure 1) 13
B. Operational Drawings
1. Stack Gas Sample Train (Figure 2) 14
2. Dilution Tunnel Sample Systems (Figure 3) 15
C. Equipment List 16

V. SAMPLING METHODS

A. Particulate 17
B. Efficiency 17

VI. QUALITY ASSURANCE

- A. Instrument Calibration
 - 1. Dry Gas Meters 17
 - 2. Stack Sample rotometer 18
 - 3. Gas Analyzers 18
- B. Test Method Procedures
 - 1. Leak Check Procedures 19
 - 2. Tunnel Velocity / Flow Measurement 19
 - 3. PM Sampling System Proportionality (5G-3) 19

VII. PHOTOGRAPHS

VIII. APPENDICES

- Data and Calculation Forms A
- Laboratory Operating Procedure B
- Sampling Proportionality Results C
- Dry Gas Meter Calibration Data D
- Other Calibration Data E
- Drawings and Specifications F
- Operators Manual G
- Calculation Procedures and Sample Calculations H
- Efficiency and Heat Output Results I
- Unit Pre-Burn Documentation J

I. **INTRODUCTION**
I.A. **GENERAL**

From August 6 through 9, 2001 Intertek Testing Services NA Inc. (ITS) conducted tests on Morso's model 3600 wood burning stove to determine compliance with U.S. EPA emissions regulations.

Tests were conducted by Bill Keen. Present, as an observer for tests, was Bob Ferguson, a representative of Morso. The tests were conducted at the Intertek Testing Services NA Inc. laboratory located at 8431 Murphy Drive, Middleton, Wisconsin. The laboratory elevation is 860 feet above sea level. Tests were conducted to EPA Method 28 and 5G-3 criteria.

I.B. **TEST UNIT DESCRIPTION**

The Morso 3600 wood burning stove is rectangular in shape. The unit is constructed from cast iron. Two glass and cast iron front doors are hinged on the outside edges while latching in the middle. The doors are latched by closing the left door first and then the right door, with the latch handle located on the right side door. The unit sits on four cast iron legs. The firebox is of single wall construction with firebrick lining. An ash pan is contained inside the unit below a grated bottom. A permanent log retainer is located at the front of the firebox. The lever to control the air setting is located below the ash lip.

I.C. **RESULTS**

The unit as tested produced a weighted average emissions rate of 5.19 grams/hour and did not exceed any of the emissions rate caps specified in the EPA regulations. The unit thus meets EPA certification requirements for 1990.

I.D. PRETEST INFORMATION

The test unit was received at Intertek Testing Services NA Inc. in Middleton, Wisconsin on August 3, 2001 via Tax Air. The unit was inspected upon receipt and found to be in good condition. The unit was set up following the manufacturer's instructions without difficulty. Following assembly, the unit was placed on the test stand and instrumented with thermocouples in the specified locations. Prior to beginning the emissions tests the unit was operated for a minimum of 10 hours at high-to-medium burn rates. The unit was found to be operating satisfactory during this break-in. The 12 plus hours of pre-burning was conducted August 3-4, 2001. The fuel used for the break-in process is all Red Oak cordwood with Douglas Fir scrap as kindling. The moisture content of the cordwood was 16-20% on the wet basis.

Following the pre-burn break-in process, the unit was allowed to cool. The chimney system and laboratory dilution tunnel was cleaned using standard wire brush chimney cleaning equipment.

On August 5, 2001 the unit was ready for testing.

I.E. REPORT ORGANIZATION

This report includes summaries of all data necessary to determine compliance with the regulations. Raw data, calibration records, intermediate calculations, drawings and specifications and other supporting information are contained in appendices to this report.

II. SUMMARY OF TEST RESULTS

II.A. EMISSIONS

Run Number	Test Date	Burn Rate (kg/hr)	Emission Rate (g/hr)	Adjusted Emission Rate (g/hr)	Heating Efficiency** (% Overall)
1	8/6/01	1.239	3.980	5.728	67.71
2	8/7/01	0.949	1.297	2.257	69.36
3	8/8/01	4.103	6.285	8.369	59.14
4	8/9/01	1.827	5.497	7.489	65.26

**Calculated as specified in CSA B-415

II.B. WEIGHTED AVERAGE CALCULATION

Run Number	Burn Rate	(E)		Output (OHE)*(BTU/HR)	Prob	(K)			
		Adjusted Emission Rate g/hr				Weighting Factor	(KxE)	(KxOHE)	
2	0.949	2.257	69.36	11443.23	.3274	0.5672	1.2801	39.34	
1	1.239	5.728	67.71	14940.11	.5672	.5513	3.1581	37.33	
4	1.827	7.489	65.26	22030.33	.8788	.4278	3.2041	27.92	
3	4.103	8.369	59.14	49474.79	.9950	.1212	1.0145	7.17	
Sums:						1.66756	8.6567	111.76	

Weighted Average Emissions Rate: $8.6567 \div 1.66756 = 5.1913$

Weighted Average Overall Heating Efficiency: $111.76 \div 1.66756 = 67.02\%$

*Calculated as specified in CSA B-415

II.C. TEST FACILITY CONDITIONS

Run Number	Room Temperature (F)		Barometric Pressure (in. Hg)		Relative Humidity (%)		Air Velocity (ft/min)	
	Before	After	Before	After	Before	After	Before	After
1	90	90	29.30	29.30	84	63	0	0
2	90	88	29.28	29.26	72	67	0	0
3	88	90	29.04	29.03	79	61	0	0
4	84	89	29.00	28.96	63	70	0	0

II.D. FUEL QUALITIES

Run Number	Pre-Test Load			Test Load					
	Loading Weight (lb.)	Moisture Content Dry Basis (%)	Coal Bed Weight (lb.)	Weight Wet Basis (lb.)	Loading Density (lbs/ft ³)	Moisture Content Dry Basis (%)	Piece Length (in.)	Number of 2x4's 4x4's	
1	15.49	20.66	3.1	14.87	6.949	21.00	19.00	3	2
2	16.96	20.19	3.4	15.54	7.262	20.42	19.00	3	2
3	15.50	22.04	3.2	15.69	7.332	22.44	19.00	3	2
4	18.31	21.16	3.3	15.61	7.294	20.51	19.00	3	2

E. DILUTION TUNNEL FLOW RATE MEASUREMENTS AND SAMPLING DATA (5G-3)

Average Dilution Tunnel Measurements					Sample Data			
Run Number	Burn Time (min)	Velocity (ft/sec)	Volumetric Flow Rate (dscf/min)	Total Temp. (°R)	Sample Volume (dscf)		Particulate Catch (mg)	
					1	2	1	2
1	270	13.70	141.28	566.50	62.39	63.06	29.5	29.4
2	370	13.29	137.15	565.79	85.59	86.38	12.9	14.2
3	85	16.81	147.24	661.10	19.66	19.70	14.1	13.9
4	193	14.02	136.77	592.38	44.33	44.79	30.0	29.7

I.F. DILUTION TUNNEL DUAL TRAIN PRECISION

Run Number	Sample Ratios		Total Emissions (grams)		% Deviation
	Train 1	Train 2	Train 1	Train 2	
1	611.45	604.94	18.04	17.79	1.17
2	592.92	587.47	7.65	8.34	7.20
3	636.66	635.26	8.96	8.83	1.37
4	595.49	589.29	17.86	17.50	1.70

Report Date: August 15, 2001
 Client: Morso Jernstoberi

Report #: J20049092, 3005306
 Model: 2110

Page 9 of 19

I.G. GENERAL SUMMARY OF RESULTS

Run Number	Burn Rate (kg/hr)	Average Temperature (F) Combustion	Change		Initial Draft (in. H ₂ O)	Primary Air Setting	Run Time (min)	Average Draft (in. H ₂ O)
			In Surface Temperature (F) Surface	In Surface Temperature (F)				
1	1.239	649.50	324.59	-82.60	.065	full closed	270	.060
2	0.949	588.26	305.91	-97.80	.070	full closed	370	.069
3	4.103	1126.10	471.98	-14.60	.096	full open	85	.098
4	1.827	759.00	365.74	-18.00	.072	1-7/8"	193	.076

III. PROCESS DESCRIPTION**III.A. DISCUSSION**

RUN #1 (August 6, 2001) The primary air was set at full closed. The test was loaded in 30 seconds. The door was open for 90 seconds and the air control was full open for 5 minutes. Burn time was 270 minutes for a category 2-burn rate of 1.239 kg/hr..

RUN #2 (August 7, 2001) The air control was set at full closed. The test was loaded in 30 seconds. The door was open for 90 seconds. The air control was full open for 3-1/2 minutes and slowly closed till 5 minutes. Burn time was 370 minutes for a category 1-burn rate of 0.949 kg/hr.

RUN #3 (August 8, 2001) The air control was set to full open. The test was loaded in 40 seconds and the door was open for 40 seconds. The air control was not adjusted. Burn time was 85 minutes for a category 4-burn rate of 4.103 kg/hr.

RUN #4 (August 9, 2001). The primary air control was set at 1-7/8" from ash lip. The test was loaded in 38 seconds. The door was open for 90 seconds. The air control was full open for 4-1/2 minutes, then slowly set to 1-7/8" from lip aat 5 minutes. Burn time was 193 minutes for a category 3-burn rate of 1.827 kg/hr.

III.B. UNIT DIMENSIONS

30" high, 29.5" wide and 25" deep.

III.C. AIR SUPPLY SYSTEM

Primary combustion air enters the unit at the rear of the unit and enters the firebox at the front below the grate. Secondary air is channeled up the rear of the firebox and forward in the baffle where it spills out through 4 steps of holes. A single handle controls primary air and secondary air. This handle opens both an oval hole and a parallelogram shaped hole. Combustion products then exit the unit through a six-inch flue collar located centrally at the rear of the stovetop.

III.D. OPERATION DURING TEST

The unit ran well. The first test did not meet the category I burn rate and the second test was run with the same settings but closing down the air control sooner in the start up.

III.E. START-UP OPERATION

Each test was started with a clean firebox and the scale zeroed. A fire was started using newspaper and Douglas Fir scraps for kindling. For the low burns, a pre preload test was used to warm up the stove, then the stove was cleaned out and rezeroed. The rest of the tests were then started with two to three pounds of kindling and a warm-up pre-test load of fuel was put in as space allowed. Pretest loads were fired on high until burning well. Stirring was done as required to insure uniform charcoalization. At least one hour prior to reloading the air control was set to the approximate position used during the test. Stirring was limited to less than 1 minute during the last 15 minutes of the pre-test.

IV. SAMPLING SYSTEMS

IV.A. SAMPLING LOCATIONS

Particulate samples are collected from the dilution tunnel at a point 20 feet from the tunnel entrance. The tunnel has two elbows and two mixing baffles in the system ahead of the sampling section. (See Figure 3.) The sampling section is a continuous 13 foot section of 6 inch diameter pipe straight over its entire length. Tunnel velocity pressure is determined by a standard Pitot tube located 60 inches from the beginning of the sampling section. The dry bulb thermocouple is located six inches downstream from the Pitot tube. Tunnel samplers are located 60 inches downstream of the Pitot tube and 36 inches upstream from the end of this section. (See Figure 1.)

Stack gas samples are collected from the steel chimney section 8 feet \pm 6 inches above the scale platform. (See Figure 2.)

IV.A.(1) DILUTION TUNNEL





FIGURE 1

IV.B. OPERATIONAL DRAWINGS

IV.B.(1) STACK GAS SAMPLE TRAIN



ITS FLUE GAS SAMPLE TRAIN

FIGURE 2

IV.B.(2). DILUTION TUNNEL SAMPLE SYSTEMS




Figure 3

IV.B. EMISSION AND EFFICIENCY EQUIPMENT LIST

<u>ITEM DESCRIPTION</u>	<u>MANUFACTURER</u>	<u>MODEL</u>	<u>SERIAL #</u>
1. CO2 Analyzer (WHI#010)	HORIBA	PIR-2000	607023
2. CO Analyzer (WHI #009)	HORIBA	PIR-2000	6110019
3. O2 Analyzer (WHI #011)	BECKMAN	755	1001926
4. Dry Gas Meter (WHI #012)	Rockwell	T-110	26866
5. Dry Gas Meter (WHI #013)	Rockwell	T-110	26873
6. Rotometer (WHI # 015)	Matheson	602 Tube	
7. Rotometer (3) (WHI # 016)	Matheson	603 Tube	
8. Rotometer (2) (WHI # 019)	Matheson	604 Tube	
9. Hot Wire Anemometer (WHI #021)	Alnor	8525	MD 1057
10. Inclined Manometer (WHI #022)	Dwyer	125-AV	
11. Pitot Tube (WHI # 044)			
12. Manometer 0-10" (WHI #024)	Dwyer	400-10	
13. Mercury Barometer (WHI # 142)	Meriam	310EC10WM	184550-X1
14. Draft Indicator (WHI #027)	Dwyer	2000-00	R60825 M29
15. Scale, 1000# Cap./Record.(WHI #025)	Toledo Masstron	ML222	8013
16. Readout for 1000# Scale (WHI #007)	NCI	5780	C800174
17. Scale, 75# Capacity (WHI #006)	NCI	3824-100	762117
18. Readout for 75# Scale (WHI #008)	NCI	5780	G800082
19. Analytical Balance (WHI #028)	OHAUS	G-110	5336
20. Dial-o-gram Balance 2610 g (WHI # 031)	OHAUS	1650	
21. Audit Weights 1 mg-100 g/Class-S (WHI # 029)	Ainsworth	4254-S	39392
22. Diaphragm Pumps (4) (WHI # 032 - 035)	Dayton	ZO24 (1) 2Z866 (3)	
23. Method 5H Glassware (WHI # 036)	Andersen	4" Filter, 4-250 ml Impingers	
24. Gases; Calibration, Zero, Span	Matheson		
25. Regulators for Gases (6) (WHI # 037 - 043)	Matheson	8-(XXXXX)	
26. High Accuracy Needle Valves (9)	Matheson		
27. Solenoid Valves (12) (WHI # 045)	Dayton		
28. Switches (Misc.) (WHI # 045)	Dayton		
29. ORSAT Gas Analyzer (WHI # 048)	Fisher	D	
30. Oxygen Bomb Calorimeter (WHI # 047)	Parr	1341	4514
31. Moisture Meter (WHI #049)	Delmhorst	RC-1C	14356
32. Humidity Chamber (WHI # 050)	Lab Built		
33. Dilution Tunnel (WHI # 046)	Lab Built		
34. Spirometer (WHI # 51)	Lab Built		
35. Data Acquisition System (WHI # 052)	Lab Built		
36. Drying Oven (WHI # 002)	Blue-M	SW-11TA-1	SW-291
37. Filter Holders, 47-mm (8) (WHI # 053)	Nalgene		
38. Type-K Meter (WHI #054)	Omega	199	21662
39. Digital Voltmeter (WHI # 055)	Newport	2004-3	6090022-3
40. Type K Thermocouple Wire 24 Ga.	Gordon	Special Limits of Error	
41. Type K T/C Plugs	Gordon	K-901/900	
42. Dry Gas Meter (WHI #014)	Rockwell	T-110	27002
43. Audit Weights; 5#, 10# (WHI # 160)	Rice Lake Weighing System		Class-F
44. Sling Psychrometer (WHI # 126)	Taylor		
45. Chart Recorder (WHI # 056)	Cole-Palmer	2030-0000	221063
46. Infrared Pyrometer (WHI #102)	Omega	OS-2000A	A4048T
47. Class C Weights 1-500 g (WHI # 161)	Ohaus		
48. Bomb Calorimeter Thermometer (WHI # 162)	Parr	1603	3K9347
49. Microtector Gauge (WHI # 103)	Dwyer	1430	
50. Bubble flow meter (WHI # 415)	Humonics	650	570192
51. Soxhlet extractor (WHI # 413)	Fisher Scientific		
52. ESS Unit (WHI # 416)	Omni		
53. Unimantle (WHI # 413)			
54. Magnehelic (WHI #027)			

Prepared January 1988 by Rick Curkeet / Rev. May1997 by Rick Armstrong

V. SAMPLING METHODS**V.A. PARTICULATE SAMPLING**

Particulates were sampled in strict accordance with EPA Method 5G-3. This method uses two identical sampling systems with Gelman A/E 61631 binder free, 47-mm diameter filters. The dryers used in the sample systems are filled with "Drierite" before each test run.

V.B. EFFICIENCY

Efficiencies reported were based on Method CSA-B415 (calculation). Stack gas analysis for oxygen, carbon dioxide and carbon monoxide was performed in accordance with EPA Method 5H.

VI. QUALITY ASSURANCE**VI.A. INSTRUMENT CALIBRATION****VI.A.(1). DRY GAS METERS**

At the conclusion of each test program the dry gas meters are checked against our standard dry gas meter. Three runs are made on each dry gas meter used during the test program. The average calibration factors obtained are then compared with the six-month calibration factor and, if within 5%, the six-month factor is used to calculate standard volumes. Results of this calibration are contained in Appendix D.

An integral part of the post test calibration procedure is a leak check of the pressure side by plugging the system exhaust and pressurizing the system to 10" W.C. The system is judged to be leak free if it retains the pressure for at least 10 minutes.

The standard dry gas meter is calibrated every 6 months using a Spirometer designed by the EPA Emissions Measurement Branch. The process involves sampling the train operation for 1 cubic foot of volume. With readings made to .001 ft³, the resolution is .1%, giving an accuracy higher than the $\pm 2\%$ required by the standard.

VI.A.(2).

STACK SAMPLE ROTAMETER

The stack sample rotometer is checked by running three tests at each flow rate used during the test program. The flow rate is checked by running the rotometer in series with one of the dry gas meters for 10 minutes with the rotometer at a constant setting. The dry gas meter volume measured is then corrected to standard temperature and pressure conditions. The flow rate determined is then used to calculate actual sampled volumes.

VI.A.(3).

GAS ANALYZERS

The continuous analyzers are zeroed and spanned before each test with appropriate gases. A mid-scale multi-component calibration gas is then analyzed (values are recorded). At the conclusion of a test, the instruments are checked again with zero, span and calibration gases (values are recorded only). The drift in each meter is then calculated and must not exceed 5% of the scale used for the test.

At the conclusion of each unit test program, a five-point calibration check is made. This calibration check must meet accuracy requirements of the applicable standards. Consistent deviations between analyzer readings and calibration gas concentrations are used to correct data before computer processing. Data is also corrected for interferences as prescribed by the instrument manufacturers instructions. Calibration gases are checked by ORSAT analysis when received to verify suppliers analysis.

VI.B.

TEST METHOD PROCEDURES

VI.B.(1).

LEAK CHECK PROCEDURES

Before and after each test, each sample train is tested for leaks. Leakage rates are measured and must not exceed 0.02 CFM or 4% of the sampling rate. Leak checks are performed checking the entire sampling train, not just the dry gas meters. Pre-test and post-test leak checks are conducted with a vacuum of 10 inches of mercury. Vacuum is monitored during each test and the highest vacuum reached is then used for the post test vacuum value. If leakage limits are not met, the test-run is rejected. During, these tests the vacuum was typically less than 2 inches of mercury. Thus, leakage rates reported are expected to be much higher than actual leakage during the tests.

Report Date: August 15, 2001
Client: Morso Jernstoberi

Report #: J20049092, 3005306
Model: 2110

Page 19 of 19

VI.B.(2). TUNNEL VELOCITY/FLOW MEASUREMENT

The tunnel velocity is calculated from a center point pitot tube signal multiplied by an adjustment factor. This factor is determined by a traverse of the tunnel as prescribed in EPA Method 1. Final tunnel velocities and flow rates are calculated from EPA Method 2, Equation 6.9 and 6.10. (Tunnel cross sectional area is the average from both lines of traverse.)

Pitot tubes are cleaned before each test and leak checks are conducted after each test.

VI.B.(3). PM SAMPLING PROPORTIONALITY (5G-3)

Proportionality was calculated in accordance with EPA Method 5G-3. The data and results are included in Appendix C.

All tests were conducted, analyzed, and reported on by:



Bill Keen, Engineering Technician

Reviewed By:





Edwin Hodgson, Project Manager





Richard Armstrong, Engineering Technician











APPENDIX A

Intertek Testing Services

SFBA EPA ADJUSTED EMISSION RESULTS

Manufacturer:	Morso		RESULTS	
Model:	3600			
Date:	8/6/01	AVERAGE ADJUSTED EMISSION F	5.728	
Run:	1			
Project #:	J20049092	Burn Rate (Dry kg/hr):	1.239	
Test Duration: (minutes)	270			

PRESSURE FACTOR:	0.97928	BAROMETRIC PRESSURE	
		Average:	29.3

TEMPERATURE FACTORS

DGM #1:	0.96627	Start:	29.3
DGM #2:	0.96881	End:	29.3

DRY GAS METER VALUES

VOLUMES SAMPLED

DGM #1:	62.38804	DGM #1	Final:	304.733
DGM #2:	63.05914		Initial:	240.132

TOTAL TUNNEL VOLUME (scf):	38146.929	DGM #2	Final:	650.944
			Initial:	586.482

SAMPLE RATIOS

Sample Train 1:	611.446
Sample Train 2:	604.939

TEMPERATURES (DEG. RANKIN)

DGM #1:	546.429
DGM #2:	545.000

TOTAL EMISSIONS

Sample Train 1 (g):	18.0377
Sample Train 2 (g):	17.7852

CALIBRATION FACTORS

DGM #1:	1.0206
DGM #2:	1.0311

EMISSION RATES

Sample Train 1 (g/hr):	4.0084
Sample Train 2 (g/hr):	3.9523

TUNNEL FLOW RATE:	141.285
-------------------	---------

ADJUSTED EMISSION RATES

Sample Train 1 (g/hr):	5.7615
Sample Train 2 (g/hr):	5.6945

PARTICULATE CATCH (mg)

Sample Train 1:	29.5
Sample Train 2:	29.4

DEVIATION:	1.17%
------------	-------

Intertek Testing Services

SFBA EPA ADJUSTED EMISSION RESULTS

Manufacturer:	Morso	RESULTS	
Model:	3600	AVERAGE ADJUSTED EMISSION RATE:	2.257
Date:	8/8/01		
Run:	2	Burn Rate (Dry kg/hr):	0.949
Project #:	J20049092		
Test Duration: (minutes)	370		

PRESSURE FACTOR: 0.97828 BAROMETRIC PRESSURE

TEMPERATURE FACTORS

DGM #1: 0.96804
DGM #2: 0.96862

Average: 29.27
Start: 29.28
End: 29.26

DRY GAS METER VALUES

VOLUMES SAMPLED

DGM #1: 85.58870
DGM #2: 86.38268

DGM #1 Final: 393.585
Initial: 305.031
DGM #2 Final: 739.363
Initial: 650.951

TOTAL TUNNEL VOLUME (scf): 50747.168

SAMPLE RATIOS

Sample Train 1: 592.919
Sample Train 2: 587.469

TEMPERATURES (DEG. RANKIN)

DGM #1: 545.434
DGM #2: 545.105

TOTAL EMISSIONS

Sample Train 1 (g): 7.6487
Sample Train 2 (g): 8.3421

CALIBRATION FACTORS

DGM #1: 1.0206
DGM #2: 1.0311

EMISSION RATES

Sample Train 1 (g/hr): 1.2403
Sample Train 2 (g/hr): 1.3528

TUNNEL FLOW RATE: 137.155

ADJUSTED EMISSION RATES

Sample Train 1 (g/hr): 2.1762
Sample Train 2 (g/hr): 2.3388

PARTICULATE CATCH (mg)

Sample Train 1: 12.9
Sample Train 2: 14.2

DEVIATION: 7.20%

Intertek Testing Services

SFBA EPA ADJUSTED EMISSION RESULTS

Manufacturer:	MORSO	RESULTS
Model:	3600	
Date:	8/8/01	AVERAGE ADJUSTED EMISSION F 8.369
Run:	3	
Project #:	0	Burn Rate (Dry kg/hr): 4.103
Test Duration: (minutes)	85	

PRESSURE FACTOR:	0.97042	BAROMETRIC PRESSURE	Average:	29.035
TEMPERATURE FACTORS			Start:	29.04
DGM #1:	0.97184		End:	29.03
DGM #2:	0.97489			

VOLUMES SAMPLED		DRY GAS METER VALUES	
DGM #1:	19.65852	DGM #1	Final: 414.044
DGM #2:	19.70168		Initial: 393.620
TOTAL TUNNEL VOLUME (scf):	12515.759	DGM #2	Final: 759.571
			Initial: 739.374

SAMPLE RATIOS		TEMPERATURES (DEG. RANKIN)	
Sample Train 1:	636.658	DGM #1:	543.300
Sample Train 2:	635.264	DGM #2:	541.600

TOTAL EMISSIONS		CALIBRATION FACTORS	
Sample Train 1 (g):	8.9769	DGM #1:	1.0206
Sample Train 2 (g):	8.8302	DGM #2:	1.0311

EMISSION RATES		TUNNEL FLOW RATE:	
Sample Train 1 (g/hr):	6.3366		147.244
Sample Train 2 (g/hr):	6.2331	PARTICULATE CATCH (mg)	
ADJUSTED EMISSION RATES		Sample Train 1:	14.1
Sample Train 1 (g/hr):	8.4258	Sample Train 2:	13.9
Sample Train 2 (g/hr):	8.3114		

DEVIATION: 1.37%

Intertek Testing Services			
SFBA EPA ADJUSTED EMISSION RESULTS			
Manufacturer:	Morso	RESULTS	
Model:	3600		
Date:	8/9/01	AVERAGE ADJUSTED EMISSION F	7.489
Run:	4		
Project #:	J20049092	Burn Rate (Dry kg/hr):	1.827
Test Duration: (minutes)	193		
PRESSURE FACTOR:		0.96858	BAROMETRIC PRESSURE
TEMPERATURE FACTORS		Average: 28.98	
DGM #1:		0.96987	Start: 29
DGM #2:		0.97093	End: 28.96
DRY GAS METER VALUES			
VOLUMES SAMPLED		DGM #1	Final: 460.600
DGM #1:		44.32674	Initial: 414.366
DGM #2:		44.79301	
TOTAL TUNNEL VOLUME (scf):		26396.089	DGM #2
			Final: 805.902
			Initial: 759.708
SAMPLE RATIOS		TEMPERATURES (DEG. RANKIN)	
Sample Train 1:		595.489	DGM #1: 544.405
Sample Train 2:		589.290	DGM #2: 543.810
TOTAL EMISSIONS		CALIBRATION FACTORS	
Sample Train 1 (g):		17.8647	DGM #1: 1.0206
Sample Train 2 (g):		17.5019	DGM #2: 1.0311
EMISSION RATES		TUNNEL FLOW RATE:	
Sample Train 1 (g/hr):		5.5538	136.767
Sample Train 2 (g/hr):		5.4410	PARTICULATE CATCH (mg)
ADJUSTED EMISSION RATES		Sample Train 1:	
Sample Train 1 (g/hr):		7.5523	30
Sample Train 2 (g/hr):		7.4248	Sample Train 2:
			29.7
DEVIATION:		1.70%	

Manufacturer Morso

Model 3600 Wood Stove

Date 8/6/01

Job # J20049092

Tech W.C.

EMISSIONS TESTING UNIT PREPARATION

Unit description (check all that apply)

- | | | |
|---|--|--|
| <input checked="" type="checkbox"/> Stove | <input checked="" type="checkbox"/> Top Vent | <input type="checkbox"/> Manual Draft |
| <input type="checkbox"/> Insert | <input type="checkbox"/> Rear Vent | <input type="checkbox"/> Bimetal Spring |
| <input type="checkbox"/> Catalytic | <input checked="" type="checkbox"/> Grate | <input type="checkbox"/> Remote Thermostat |
| <input checked="" type="checkbox"/> Non-catalytic | <input checked="" type="checkbox"/> Ashpan | <input type="checkbox"/> Blower or Fans |
| <input type="checkbox"/> Other: | | |

Unit received with all parts: Yes No

Manual: Yes No

Drawings: Yes No

Specifications: Yes No

Materials of construction: Cast Iron

Air introduction: controlled at rear

Control mechanism: handle in front

Unit net weight with all components: 433.5 lbs. 196.7 Kg.

Unit fire box volume: 2.14 Ft³ (attach fire box volume calculations and drawings)

Ideal Load Weight: 14.98 lbs. (Volume x 7)

Load Weight Range: ($\pm 10\%$ of ideal weight) 13.48 lbs. to 16.48 lbs.

Ideal piece length specification: 20 inches. (5/6 of longest fire box dimension)

Thermocouples attached: 8/3/01 Attached by: W.C. (attach T/C map)

Unit conditioned prior to test

10 hours at medium
burn rate (non-catalytic)
(attach burn log)

50 hours at medium
burn rate (attach burn log)

Date started: 8/3/01

Date completed: 8/4/01

Catalyst manufacturer: NA

Serial number: NA Dimensions: _____ Cell size: _____ cells/in.²

Unit ready for testing (date): 8/6/01 Initialed: _____

Manufacturer Morso

Model 3600 Wood Stove


Date 8/6/01

Job # J20049092

Tech JK

Thermocouple Location

Thermocouples are placed centrally on the top, back, right and left sides and the bottom and numbered as shown below.



TC#	LOCATION
5	UNIT TOP
6	UNIT BACK
7	UNIT RIGHT
8	UNIT LEFT
9	UNIT BOTTOM

Manufacturer Morso

Model 3600 Wood Stove

Page 4 of 50

Date 8/3/01

Job # J20049092

Tech [Signature]



Measurements By: [Signature]

Checked By: [Signature]

FIRE BOX VOLUME CALCULATION

See computer drawings

PAGE 5 OF 50




1. 10.06 X 2.83 X 24.00 = 683.28
2. 10.69 X 2.83 X 24.00 = 726.06
3. 11.48 X 2.78 X 24.00 = 765.95
4. 11.71 X 5.11 X 24.00 = 1405.20
5. 10.15 X 0.47 X 24.00 = 114.49
6. .5 X 1.56 X 0.27 X 24.00 = 5.05

Total

= 3700.03 cubic inches

3700.03 / 1728 = 2.141 cubic feet

PAGE — OF —



Manufacturer Morso

Model 3600

Date 8/6/10

Job # J20049092

Run 1

Tech ML

PRETEST DILUTION TUNNEL TRAVERSE RUN

Barometric pressure (P_{bar}) 29.20 (inches Hg.) Static pressure (P_s) 145 (inches w.c.)

Inside diameter: Port A 6in. Port B 6in. Tunnel cross sectional area: 0.1963Ft²

Pitot tube type: Standard

Traverse Point	Position (inches)	Velocity Head Δ_p (inches H ₂ O)	Tunnel Temperature (°F)	√ Δ_p
A-Centroid	3.00	.041	124	.2025
B-Centroid	3.00	.041	116	.2025
A-1	0.40	.040	122	.2008
A-2	1.50	.041	124	.2025
A-3	4.50	.041	124	.2025
A-4	5.60	.037	122	.1924
B-1	0.40	.039	117	.1975
B-2	1.50	.041	116	.2025
B-3	4.50	.041	116	.2025
B-4	5.60	.034	118	.1844
AVERAGE			119.9	.1989

Adjustment factor application

$$V_s = K_p C_p F_p (\sqrt{\Delta_p})_{AVG} \sqrt{\frac{T_s}{P_s M_s}}$$

$$V_s = K_p C_p (\sqrt{\Delta_p})_{avg} \sqrt{\frac{T_s}{P_s M_s}}$$

Pitot correction .145

Where,

C_p = Pitot tube coefficient = 0.99 for standard pitot

Δ_p = manometer reading (inches H₂O)

T_s = average absolute dilution tunnel temperature (°F + 460)

$$F_p = \frac{(\sqrt{\Delta_p})_{avg}}{(\sqrt{\Delta_p})_{centroid}}$$

P_s = absolute dilution tunnel gas pressure or inches H₂O
13.6

$P_{bar} + P_g$

P_s = static pressure

M_s = 28.56, wet molecular weight of stack gas (alternatively, it may be measured)

K_p = 85.49 Pitot tube constant, (conversion factor for English units)

Adjustment factor for alternative Pitot tube placement:

$(\sqrt{\Delta_p})_{avg}$ = Average of the square roots of the velocity heads (Δ_p) measured at each traverse point.

$(\sqrt{\Delta_p})_{centroid}$ = Average of the square roots of the velocity heads measured at the tunnel centroid (inches of H₂O)

Manufacturer Morso

Model 3600

Date 8/6/01

Job # J20049092

Run 1

Tech WJC

Pre/Post Checks

Moisture Meter Calibration Check:

Time: <u>6:30</u>	X: <u>L</u>	Y: <u>C</u>	12: <u>C</u>	22: <u>C</u>
-------------------	-------------	-------------	--------------	--------------

Facility Conditions:

Air Velocity.....
Smoke Capture Check.....

Pre-Test	Post-Test
0 fpm	0 fpm
✓	✓

Wood Heater Conditions:

Date Wood Heater Stack Cleaned.....
Date Dilution Tunnel cleaned.....
Induced Draft Check.....
Tunnel Velocity.....
Flow Rate 140-cfm ±10%.....

<u>8/4/01</u>	
<u>8/4/01</u>	
0	0
.040	.040
	141.285

Pitot Leak Check:

Side A.....
Side B.....

✓	✓
✓	✓

Temperature System:

Ambient (65°- 90°F).....
Wood Heater Surface (±125°F).....

<u>90</u>	°F
<u>-82.6</u>	°F

Proportional Checks:

CO Analyzer Drift Check.....
CO₂ Analyzer Check.....
O₂ Analyzer Check.....
Thermocouple check.....

✓
✓
✓
✓

Sampling Train ID Numbers:

Probe.....
Filter Front.....
Filter Back.....
Filter Thermocouple.....
Filter 5G-3 (<90°F).....

Train 1	Train 2
<u>1</u>	<u>2</u>
<u>9</u>	<u>11</u>
<u>10</u>	<u>12</u>
19	22
✓	✓

Thermocouple Identification Number

Flue.....1
Dilution Tunnel Wet Bulb.....4
Unit Right Side.....7
Catalyst/Combustion Chamber.....10

Room.....2
Unit Top.....5
Unit Left Side.....8

Dilution Tunnel Dry Bulb.....3
Unit Back.....6
Unit Bottom.....9

Manufacturer Moroso

Model 3600

Date 8/6/01

Job # J20049092

Run /

Tech [Signature]

Pre-Test Scale Audit

Scale Type	Audit Weight		Measured Weight	
Platform	<u>10</u>	lbs., Class F	<u>10.0</u>	lbs.
Wood	<u>10</u>	lbs., Class F	<u>10.00</u>	lbs.
Analytical	100 Grams	mg, Class S	Grams <u>100.1</u>	mg.

LIMITS OF WEIGHT RANGES

ANALYTICAL SCALE..... 50%-150% of dry filter weight, ± 0.1 mg
PLATFORM SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%
WOOD SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%

Manufacturer Moroso

Model 3600

Date 8/16/01

Job # J20049092

Run 1

Tech SK

SAMPLING EQUIPMENT CHECK OUT

Leakage Checks Tunnel Samplers

	SYSTEM 1		SYSTEM 2	
	Pre-Test	Post-Test	Pre-Test	Post-Test
Unplugged Flow Rate = .25cfm				
Vacuum (inches Hg.)	<u>10"</u>	<u>10"</u>	<u>10"</u>	<u>10"</u>
Final 1minute DGM (ft ³)	<u>240.132</u>	<u>304.741</u>	<u>586.482</u>	<u>650.948</u>
Initial 1minute DGM (ft ³)	<u>240.132</u>	<u>304.741</u>	<u>586.482</u>	<u>650.948</u>
Change (C) (ft ³)	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
Allowable leakage .04 x Sample rate or .02cfm	0.0100	0.0100	0.0100	0.0100
Check OK	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>

Leakage Checks Flue Gas Sampler

	Pre Test	Post Test
Plugged Probe		
Vacuum (inches Hg.)	<u>10"</u>	<u>10"</u>
Rotometer Reading (mm)	<u>0</u>	<u>0</u>
Flow Rate (CFM)	<u>0</u>	<u>0</u>
Allowable (.04 x Sample Rate)		
Check OK	<u>✓</u>	<u>✓</u>

Manufacturer Morso
 Job # J20049092

Model 3600
 Run 1

Page 11 of 50
 Date 8/6/11
 Tech [Signature]

CONTINUOUS ANALYZERS

Pre-Test (Adjust and Record)

	ZERO		SPAN		CAL. (Record Only)	
CO	00.00	00.00	9.96	9.96	00.96	.999
CO ₂	00.00	00.00	24.65	24.65	9.65	9.99
O ₂	00.00	00.00	20.93	20.93	10.27	10.2
	Actual	Should Be	Actual	Should Be	Actual	Should Be

Post Test (Record Only)

	Zero	Span	Cal.	Zero Drift	Span Drift	Cal. Drift	OK?	Not OK*
CO	00.00	10.05	00.96	-0-	.09	-0-	/	
CO ₂	00.00	24.80	9.70	-0-	.15	.05	/	
O ₂	00.01	20.83	10.27	.01	.10	-0-	/	

* Greater than ± 5% of the range used.

Manufacturer Morso

Model 3600

Date 8/6/01

Job # J20049092

Run 1

Tech WJ

TEST DATA LOG

RAW DRY GAS METER READINGS

	System 1	System 2
Final (ft ³)	304.733	650.944
Initial (ft ³)	240.132	586.482

AMBIENT CONDITIONS

	Start	End
Barometer. (inches Hg)	29.30	29.30
Wet Bulb (°F)		
Dry Bulb (°F)	74	79
Humidity (%)	84	63

Manufacturer Morso

Model 3600

Page 13 of 50

Job # J20049092

Run 1

Date 8/3/01

Tech ml

DILUTION TUNNEL PARTICULATE SAMPLER DATA

FILTER TYPE: Gelman 47mm A/E

Samples in Desecrator. Date: 8/6/01 Time: 14:36

	SYSTEM 1		SYSTEM 2	
	Probe and Front Half Housing # <u>1</u>	Filter Numbers <u>9, 10</u>	Probe and Front Half Housing # <u>2</u>	Filter Numbers <u>11, 12</u>
Post Test Weight:	<u>91.4401</u> grams	<u>.2463</u> grams	<u>91.6245</u> grams	<u>.2453</u> grams
Pre Test Weight:	<u>91.4395</u> grams	<u>.2174</u> grams	<u>91.6242</u> grams	<u>.2162</u> Grams
Gain:	<u>.0006</u> grams	<u>.0289</u> grams	<u>.0003</u> grams	<u>.0291</u> Grams
	a1	b1	a2	b2

Total Gain: $a1 + b1 = 29.5 \text{ m grams}$ $a2 + b2 = 29.4 \text{ m grams}$

Pre-test Weight Record		SYSTEM 1			SYSTEM 2			TEMP	HUMID
		Probe & Housing Number	Front Filter Number	Back Filter Number	Probe & Housing Number	Front Filter Number	Back Filter Number		
Date	Time	<u>1</u>	<u>9</u>	<u>10</u>	<u>2</u>	<u>11</u>	<u>12</u>	°F	%
<u>8/3/01</u>	<u>15:15</u>	<u>91.4395</u>	<u>.1145</u>	<u>.1030</u>	<u>91.6247</u>	<u>.1145</u>	<u>.1018</u>	<u>78</u>	<u>49</u>
<u>8/4/01</u>	<u>10:00</u>	<u>91.4395</u>	<u>.2145</u>	<u>.1032</u>	<u>91.6246</u>	<u>.1144</u>	<u>.1020</u>	<u>76</u>	<u>47</u>
<u>8/5/01</u>	<u>9:20</u>	<u>91.4395</u>	<u>.1144</u>	<u>.1031</u>	<u>91.6243</u>	<u>.1144</u>	<u>.1018</u>	<u>76</u>	<u>48</u>
<u>8/6/01</u>	<u>6:10</u>	<u>91.4395</u>	<u>.1144</u>	<u>.1030</u>	<u>91.6242</u>	<u>.1144</u>	<u>.1018</u>	<u>76</u>	<u>49</u>
		Total	<u>.2174</u>		Total	<u>.2162</u>			

Pre-test Weight Record		SYSTEM 1		SYSTEM 2		TEMP	HUMID
		Probe & Housing Number	Combined Filter Weight Number	Probe & Housing Number	Combined Filter Weight Number		
Date	Time	<u>1</u>	<u>9, 10</u>	<u>2</u>	<u>11, 12</u>	°F	%
<u>8/6/01</u>	<u>14:36</u>	<u>91.4411</u>	<u>.2482</u>	<u>91.6279</u>	<u>.2482</u>	<u>85</u>	<u>46</u>
<u>8/7/01</u>	<u>5:45</u>	<u>91.4407</u>	<u>.2470</u>	<u>91.6245</u>	<u>.2453</u>	<u>75</u>	<u>48</u>
<u>8/8/01</u>	<u>6:58</u>	<u>91.4401</u>	<u>.2465</u>	<u>91.6245</u>	<u>.2453</u>	<u>74</u>	<u>45</u>
<u>8/9/01</u>	<u>7:11</u>	<u>91.4401</u>	<u>.2463</u>	<u>91.6245</u>	<u>.2453</u>	<u>73</u>	<u>48</u>

Manufacturer Morso

Model 3600

Date 8/14/01

Job # J20049092

Run 1

Tech gwl

Air control full closed

SWITCH NUMBER																
				1	2	3	4	5	6	7	8	9	10			
READING #	REAL TIME	ELAPSED TIME	WEIGHT REMAINING	FLUE GAS TEMP	ROOM TEMP	TUNNEL DRY BULB	TUNNEL WET BULB	UNIT TOP	UNIT BACK	UNIT RIGHT SIDE	UNIT LEFT SIDE	UNIT BOTTOM	CATALYST DOWNSTREAM	TUNNEL VELOCITY	DRAFT	SMOKE
0	9:00	0	9.00	771	90	225	81	677	196	335	348	458	1227		.098	
1		10	7.50	507	90	137	80	646	205	357	358	480	963	.040	.084	C
2		20	6.30	485	90	128	81	624	215	348	341	465	967	.041	.081	C
3		30	5.00	463	90	122	80	618	214	341	333	448	889		.078	C
4		40	4.00	436	90	115	81	585	214	337	326	434	859	.040	.074	C
5		50	3.80	424	90	113	80	555	214	332	323	429	841	.040	.071	C
6		60	3.30	375	90	108	81	521	215	326	322	429	732	.041	.062	C
7		70														
8		80														
9		90														
10		100														
11		110														
12		120														
13		130														
14		140														
15		150														
16		160														
17		170														
18		180														
19		190														
20		200														
21		210														
22		220														
23		230														
24		240														
25		250														
Comments: 9:44 0.62 lbs added 19.7% 10:01 Five started 1min																

WHI LTO#: J20049092
 MANUFACTURER: Masco
 SWITCH NUMBER: 3600
 MODEL: 3600
 DATE: 8/16/11
 RUN#: 1
 AIR CONTROL FULL CLOSED
 page 17 of 50
 TECHNICIAN: [Signature]

READING#	REAL TIME	ELAPSED TIME	WEIGHT REMAIN	CO	CO2	FLUE GAS TEMP	ROOM TEMP	TUNNEL TEMP	TUNNEL WET BULB	UNIT TOP	UNIT BACK	UNIT RT. SIDE	UNIT LEFT SIDE	UNIT BOTTOM	CAT EXIT	CAT CENTER	GAS SEMPL. ROTO.	DGM #1 READING	ROTO 1 READING	DGM TEMP INLET	DGM TEMP OUTLET	19	20	21	22	
0	16:02	0	4.87	12.3	7.15	12.37	37.8	90	108	321	215	226	222	429	252		135	290.1	120	79	78	75	76	76	80	
1		10	13.00	1.78	5.12	14.1	43.8	90	128	337	206	274	330	450	325		135	291.5	120	79	78	84	84	89	1065	
2		20	11.40	3.33	13.44	6.46	52.1	90	127	355	206	299	306	440	209		135	294.9	120	80	79	89	89	89	1081	
3		30	9.80	3.35	13.98	6.35	53.6	90	128	375	202	292	307	424	111		135	297.2	120	81	80	90	90	90	1084	
4		40	6.20	2.9	14.24	5.47	54.7	90	126	391	203	295	313	407	4170		135	299.6	120	82	81	90	90	90	1086	
5		50	4.70	2.9	14.04	6.16	53.2	90	120	408	205	302	327	388	1064		135	302.0	120	83	82	90	90	90	1088	
6		60	5.40	2.9	14.04	6.16	53.2	90	120	425	204	310	333	375	846		135	304.4	120	84	83	90	90	90	1090	
7		70	4.20	1.51	2.63	11.81	38.9	90	114	442	207	316	333	370	784		135	306.8	120	85	84	90	90	90	1092	
8		80	4.20	1.28	2.65	11.93	35.8	90	110	460	207	313	330	370	680		135	309.1	120	86	85	90	90	90	1094	
9		90	3.80	1.16	8.24	11.07	35.8	90	108	474	207	307	327	373	696		135	311.5	120	87	86	90	90	90	1096	
10		100	3.20	0.88	8.53	11.13	33.3	90	106	474	206	304	327	374	672		135	313.9	120	88	87	90	90	90	1098	
11		110	2.70	0.36	2.85	11.93	33.2	90	105	460	206	301	326	391	601		135	316.3	120	89	88	90	90	90	1100	
12		120	2.40	0.44	2.54	12.96	31.5	90	102	438	205	299	326	391	526		135	318.7	120	90	88	89	89	89	1090	
13		130	2.30	0.74	2.26	12.96	30.2	90	101	420	206	297	324	393	522		135	321.1	120	91	88	89	89	89	1092	
14		140	2.10	0.84	6.72	12.96	30.2	90	101	403	205	295	323	395	530		135	323.5	120	92	88	89	89	89	1094	
15		150	2.00	0.87	6.52	13.21	28.0	90	99	387	206	290	319	395	530		135	325.9	120	93	89	89	89	89	1096	
16		160	1.80	1.01	6.27	13.57	27.0	90	99	366	201	286	312	395	517		135	328.3	120	94	90	90	90	90	1098	
17		170	1.70	1.31	6.02	13.57	27.0	90	99	360	199	282	308	395	517		135	330.7	120	95	90	90	90	90	1100	
18		180	1.60	1.46	5.89	13.71	26.6	90	98	340	197	278	304	394	503		135	333.1	120	96	89	90	90	90	1102	
19		190	1.50	1.70	5.71	14.06	25.9	90	98	340	195	271	303	391	476		135	335.5	120	97	89	90	90	90	1104	
20		200	1.30	1.65	5.29	14.16	25.3	90	98	321	195	267	297	388	468		135	337.9	120	98	89	90	90	90	1106	
21		210	1.20	1.61	5.18	14.24	24.9	90	97	321	195	267	297	388	468		135	340.3	120	99	89	90	90	90	1108	
22		220	1.00	1.58	5.18	14.32	24.6	90	97	324	194	265	287	385	465		135	342.7	120	100	89	90	90	90	1110	
23		230	0.90	1.75	5.13	14.30	24.7	90	97	320	194	261	285	381	456		135	345.1	120	101	88	90	90	90	1112	
24		240	0.80	1.84	4.84	14.99	24.7	90	97	319	194	259	280	378	456		135	347.5	120	102	88	89	89	89	1114	
25		250	0.70	1.85	4.87	14.63	24.1	90	97	315	191	258	278	375	453		135	349.9	120	103	89	89	89	89	1116	
26		260	0.60	1.64	5.11	14.98	24.2	90	97	311	190	257	277	374	446		135	352.3	120	104	89	89	89	89	1118	
27		270	0.50	1.56	5.17	14.97	23.9	90	96	307	189	256	274	374	473		135	354.7	120	105	89	89	89	89	1120	
28		280																								
29		290																								
30		300																								
31		310																								
32		320																								
33		330																								
34		340																								
35		350																								
36		360																								
37		370																								
38		380																								
39		390																								
40		400																								
41		410																								
42		420																								
43		430																								
44		440																								
45		450																								
46		460																								
47		470																								
48		480																								

11.23 g/kg
 12.30 g/m³

COMMENTS: Test loaded, 35sec
 door open 90sec
 air control open 5min

Manufacturer Moroso

Model 3600

Date 8/7/09

Job # J20049092

Run 2

Tech AK

PRETEST DILUTION TUNNEL TRAVERSE RUN

Barometric pressure (P_{bar}) 29.28 (inches Hg.) Static pressure (P_s) .114 (inches w.c.)

Inside diameter: Port A 6in. Port B 6in. Tunnel cross sectional area: $0.1963Ft^2$

Pitot tube type: Standard

Traverse Point	Position (inches)	Velocity Head Δ_p (inches H ₂ O)	Tunnel Temperature (°F)	$\sqrt{\Delta_p}$
A-Centroid	3.00	.040	121	.2000
B-Centroid	3.00	.040	123	.2000
A-1	0.40	.036	123	.1897
A-2	1.50	.040	123	.2000
A-3	4.50	.040	121	.2000
A-4	5.60	.035	123	.1871
B-1	0.40	.038	121	.1989
B-2	1.50	.040	122	.2000
B-3	4.50	.040	123	.2000
B-4	5.60	.035	120	.1871
AVERAGE			121.8	.1959

Adjustment factor application

$$V_s = K_p C_p F_p (\sqrt{\Delta_p})_{AVG} \sqrt{\frac{T_s}{P_s M_s}} \qquad V_s = K_p C_p (\sqrt{\Delta_p})_{avg} \sqrt{\frac{T_s}{P_s M_s}}$$

Pitot correction .9799

Where,

C_p = Pitot tube coefficient = 0.99 for standard pitot

Δ_p = manometer reading (inches H₂O)

T_s = average absolute dilution tunnel temperature (°F + 460)

$$F_p = \frac{(\sqrt{\Delta_p})_{avg}}{(\sqrt{\Delta_p})_{centroid}}$$

P_s = absolute dilution tunnel gas pressure or $\frac{\text{inches H}_2\text{O}}{13.6}$

$P_{bar} + P_s$

P_s = static pressure

M_s = 28.56, wet molecular weight of stack gas (alternatively, it may be measured)

K_p = 85.49 Pitot tube constant, (conversion factor for English units)

Adjustment factor for alternative Pitot tube placement:

$(\sqrt{\Delta_p})_{avg}$ = Average of the square roots of the velocity heads (O_p) measured at each traverse point.

$(\sqrt{\Delta_p})_{centroid}$ = Average of the square roots of the velocity heads measured at the tunnel centroid (inches of H₂O)

Manufacturer Morso

Model 3600

Date _____

Job # J20049092

Run 2

Tech WJ

Pre/Post Checks

Moisture Meter Calibration Check:

Time: <u>6:50</u>	X: <input checked="" type="checkbox"/>	Y: <input checked="" type="checkbox"/>	12: <input type="checkbox"/>	22: <input checked="" type="checkbox"/>
-------------------	--	--	------------------------------	---

Facility Conditions:

Air Velocity.....

Smoke Capture Check.....

Pre-Test	Post-Test
<u>0</u> fpm	<u>0</u> fpm
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Wood Heater Conditions:

Date Wood Heater Stack Cleaned.....

Date Dilution Tunnel cleaned.....

Induced Draft Check.....

Tunnel Velocity.....

Flow Rate 140-cfm ±10%.....

<u>8/4/01</u>	
<u>8/4/01</u>	
<u>0</u>	<u>0</u>
<u>.040</u>	<u>.027</u>
	<u>137, 155</u>

Pitot Leak Check:

Side A.....

Side B.....

<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Temperature System:

Ambient (65°- 90°F).....

Wood Heater Surface (±125°F).....

<u>88.8</u>	°F
<u>-97.8</u>	°F

Proportional Checks:

CO Analyzer Drift Check.....

CO₂ Analyzer Check.....

O₂ Analyzer Check.....

Thermocouple check.....

<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>	

Sampling Train ID Numbers:

Probe.....

Filter Front.....

Filter Back.....

Filter Thermocouple.....

Filter 5G-3 (<90°F).....

Train 1	Train 2
<u>3</u>	<u>9</u>
<u>13</u>	<u>15</u>
<u>14</u>	<u>16</u>
<u>19</u>	<u>22</u>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Thermocouple Identification Number

Flue.....1
 Dilution Tunnel Wet Bulb4
 Unit Right Side7
 Catalyst/Combustion Chamber10

Room.....2
 Unit Top5
 Unit Left Side8

Dilution Tunnel Dry Bulb..... 3
 Unit Back 6
 Unit Bottom..... 9

Manufacturer Morso

Model 3600

Date 8/7/07

Job # J20049092

Run 2

Tech SL

Pre-Test Scale Audit

Scale Type	Audit Weight		Measured Weight	
Platform	<u>10</u>	lbs., Class F	<u>10.0</u>	lbs.
Wood	<u>10</u>	lbs., Class F	<u>10.00</u>	lbs.
Analytical	100 Grams	mg, Class S	Grams <u>.999</u>	mg.

LIMITS OF WEIGHT RANGES

ANALYTICAL SCALE..... 50%-150% of dry filter weight, ± 0.1 mg
 PLATFORM SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%
 WOOD SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%

Manufacturer Morso

Model 3600

Page 21 of 50

Date 8/7/01

Job # J20049092

Run 2

Tech 21

SAMPLING EQUIPMENT CHECK OUT

Leakage Checks Tunnel Samplers

	SYSTEM 1		SYSTEM 2	
	Pre-Test	Post-Test	Pre-Test	Post-Test
Unplugged Flow Rate = .25cfm				
Vacuum (inches Hg.)	10"	10"	10"	10"
Final 1 minute DGM (ft ³)	305.031	393.592	650.951	739.373
Initial 1 minute DGM (ft ³)	305.031	393.591	650.951	739.371
Change (C) (ft ³)	0	.001	0	.002
Allowable leakage .04 x Sample rate or .02cfm	0.0100	0.0100	0.0100	0.0100
Check OK	✓	✓	✓	✓

Leakage Checks Flue Gas Sampler

	Pre Test	Post Test
Plugged Probe		
Vacuum (inches Hg.)	10"	10"
Rotometer Reading (mm)	0	0
Flow Rate (CFM)	0	0
Allowable (.04 x Sample Rate)		
Check OK	✓	✓

Manufacturer Morso

Model 3600

Page 22 of 50

Date 8/7/01

Job # J20049092

Run 2

Tech BK

CONTINUOUS ANALYZERS

Pre-Test (Adjust and Record)

	ZERO		SPAN		CAL. (Record Only)	
	Actual	Should Be	Actual	Should Be	Actual	Should Be
CO	00.00	00.00	9.96	9.96	.95	.999
CO ₂	00.00	00.00	24.65	24.65	9.62	9.99
O ₂	00.01	00.00	20.93	20.93	10.28	10.2
	Actual	Should Be	Actual	Should Be	Actual	Should Be

Post Test (Record Only)

	Zero	Span	Cal.	Zero Drift	Span Drift	Cal. Drift	OK?	Not OK*
CO	0.00	10.04	9.96	0	.08	.01	✓	
CO ₂	0.00	24.88	9.72	0	.23	.08	✓	
O ₂	.04	20.85	10.24	.04	.08	.04	✓	

* Greater than ± 5% of the range used.

Manufacturer MorsoModel 3600Date 8/20/1Job # J20049092Run 2Tech RF**TEST DATA LOG****RAW DRY GAS METER READINGS**

	System 1	System 2
Final (ft ³)	393.585	739.363
Initial (ft ³)	305.031	650.951

AMBIENT CONDITIONS

	Start	End
Barometer. (inches Hg)	29.28	29.26
Wet Bulb (°F)		
Dry Bulb (°F)	75	80
Humidity (%)	72	67

Manufacturer Morso

Model 3600

Page 24 of 50

Date 8/4/01

Job # J20049092

Run 2

Tech AK

DILUTION TUNNEL PARTICULATE SAMPLER DATA

FILTER TYPE: Gelman 47mm A/E

Samples in Desecrator.		Date:		Time:			
SYSTEM 1				SYSTEM 2			
Probe and Front Half Housing # <u>3</u>		Filter Numbers <u>13 14</u>		Probe and Front Half Housing # <u>4</u>		Filter Numbers <u>15 16</u>	
Post Test Weight:	<u>93.1153</u> grams	<u>.2417</u> grams		<u>89.9660</u> grams	<u>2302</u> grams		
Pre Test Weight:	<u>93.1136</u> grams	<u>.2305</u> grams		<u>89.9651</u> grams	<u>.2169</u> Grams		
Gain:	<u>.0017</u> grams	<u>.0112</u> grams		<u>.0009</u> grams	<u>.0133</u> Grams		
	a1	b1		a2	b2		

Total Gain: a1 + b1 = 12.9 m grams

a2 + b2 = 14.2 m grams

Pre-test Weight Record		SYSTEM 1			SYSTEM 2			TEMP	HUM
		Probe & Housing Number	Front Filter Number	Back Filter Number	Probe & Housing Number	Front Filter Number	Back Filter Number		
Date	Time	<u>3</u>	<u>13</u>	<u>14</u>	<u>4</u>	<u>15</u>	<u>16</u>	°F	%
<u>8/4/01</u>	<u>10:05</u>	<u>93.114</u>	<u>.1151</u>	<u>.1154</u>	<u>89.9651</u>	<u>.1031</u>	<u>.1143</u>	<u>76</u>	<u>43</u>
<u>8/5/01</u>	<u>9:25</u>	<u>93.1139</u>	<u>.1151</u>	<u>.1153</u>	<u>89.9651</u>	<u>.1032</u>	<u>.1141</u>	<u>76</u>	<u>48</u>
<u>8/6/01</u>	<u>6:15</u>	<u>93.1139</u>	<u>.1151</u>	<u>.1154</u>	<u>89.9651</u>	<u>.1031</u>	<u>.1139</u>	<u>76</u>	<u>49</u>
<u>8/7/01</u>	<u>5:50</u>	<u>93.1136</u>	<u>.1151</u>	<u>.1154</u>	<u>89.9651</u>	<u>.1030</u>	<u>.1139</u>	<u>76</u>	<u>48</u>
Total		<u>.2305</u>			Total			<u>.2169</u>	

Pre-test Weight Record		SYSTEM 1		SYSTEM 2		TEMP	HUM
		Probe & Housing Number	Combined Filter Weight Number	Probe & Housing Number	Combined Filter Weight Number		
Date	Time	<u>3</u>	<u>13, 14</u>	<u>4</u>	<u>15, 16</u>	°F	%
<u>8/7/01</u>	<u>16:07</u>	<u>93.1162</u>	<u>.2426</u>	<u>89.9678</u>	<u>.2331</u>	<u>87</u>	<u>47</u>
<u>8/8/01</u>	<u>7:05</u>	<u>93.1154</u>	<u>.2419</u>	<u>89.9674</u>	<u>2308</u>	<u>74</u>	<u>45</u>
<u>8/9/01</u>	<u>7:15</u>	<u>93.1153</u>	<u>.2418</u>	<u>89.9663</u>	<u>2305</u>	<u>74</u>	<u>48</u>
<u>8/10/01</u>	<u>7:25</u>	<u>93.1153</u>	<u>.2417</u>	<u>89.9660</u>	<u>2304</u>	<u>72</u>	<u>46</u>
<u>8/12/01</u>	<u>9:25</u>	<u>93.1153</u>	<u>.2417</u>	<u>89.9660</u>	<u>.2302</u>	<u>75</u>	<u>48</u>

Manufacturer Morso

Model 3600

Date 8/7/01

Job # J20049092

Run 2

Tech ml

Air control full closed

SWITCH NUMBER			1	2	3	4	5	6	7	8	9	10				
READING #	REAL TIME	ELAPSED TIME	WEIGHT REMAINING	FLUE GAS TEMP	ROOM TEMP	TUNNEL DRY BULB	TUNNEL WET BULB	UNIT TOP	UNIT BACK	UNIT RIGHT SIDE	UNIT LEFT SIDE	UNIT BOTTOM	CATALYST DOWNSTREAM	TUNNEL VELOCITY	DRAFT	SMOKE
0	8:32	0	9.60	714	89	171	83	696	164	325	364	331	1098	.040	.091	T
1		10	8.90	449	89	123	80	564	177	336	361	373	800	.041	.078	T
2		20	8.00	459	90	123	79	542	180	325	345	382	974		.080	T
3		30	6.90	461	90	122	79	565	183	317	333	385	969		.080	C
4		40	5.50	454	90	120	79	578	185	316	328	387	879	.040	.079	C
5		50	4.70	430	89	117	80	572	187	320	323	391	841	.040	.076	C
6		60	4.00	402	90	113	80	549	190	322	321	395	798	.040	.071	C
7		70	3.60	338	90	107	79	505	192	321	317	402	617	.040	.084	C
8		80														
9		90														
10		100														
11		110														
12		120														
13		130														
14		140														
15		150														
16		160														
17		170														
18		180														
19		190														
20		200														
21		210														
22		220														
23		230														
24		240														
25		250														
Comments:			<p><i>8:36 0.66 lbs @ 12:30 added</i></p> <p><i>9:46 fire started, door open 1 min</i></p>													

MANUFACTURER: *Flensha* MODEL: *7600* FIRE SIZE: *Low* DATE: *8/7/01* RUN#: *2* TECHNICIAN: *BC*

READING	REAL TIME	BLASPED TIME	WEIGHT REMAIN	CO	CO2	FLAME GAS TEMP	ROOM TEMP	TUNNEL TEMP	TUNNEL WET BULB	UNIT TOP	UNIT BACK	UNIT RT. SIDE	UNIT LEFT SIDE	UNIT BOTTOM	CAT INLET	CAT CENTER	GAS SAMP. NOVD.	DCM #1 READING	KOTO 1 READING	DCM TEMP INLET	DCM TEMP OUTLET	FILTER TEMP	DCM #2 READING	KOTO 2 READING	DCM TEMP INLET	DCM TEMP OUTLET	FILTER TEMP	TUNNEL VELOCITY	DRAFT	SMOKE	MAX DGM PRESS
0	9:47	0	15.55	5.51	7.90	11.90	324	90	106	79	488	192	319	315	405	601	135	305.0	120	79	79	78	650.9	120	77	77	78	0.090	0		
1		10	14.10	5.84	7.96	14.01	439	90	125	80	500	187	303	301	455	846	135	307.9	120	81	79	89	653.3	120	79	77	89	0.082	1		
2		20	12.10	6.40	11.03	9.28	580	90	124	80	527	184	287	284	446	973	135	309.8	120	82	80	88	656.7	120	80	78	89	0.084	1		
3		30	11.40	6.55	13.72	6.91	575	90	128	81	562	181	278	286	429	1020	135	312.1	120	83	81	88	658.1	120	82	80	90	0.088	1		
4		40	10.20	6.88	14.20	6.35	527	89	129	81	608	180	283	297	409	1117	135	314.5	120	84	83	88	660.5	120	82	80	90	0.088	1		
5		50	8.60	7.48	15.74	5.59	549	90	130	82	641	181	285	310	389	1150	135	316.9	120	84	83	89	662.9	120	82	80	90	0.088	1		
6		60	6.80	8.28	15.09	7.30	509	90	128	83	657	184	307	323	373	1023	135	319.3	120	85	84	89	665.3	120	84	83	90	0.088	1		
7		70	5.90	9.49	15.04	11.20	406	90	118	83	620	184	317	335	364	840	135	321.7	120	86	85	89	667.7	120	85	84	90	0.088	1		
8		80	5.30	10.60	14.20	11.20	393	90	115	83	569	192	321	338	360	770	135	324.0	120	87	85	89	670.1	120	86	84	90	0.088	1		
9		90	5.00	11.77	14.20	11.20	393	90	110	83	540	193	321	337	362	716	135	326.4	120	87	86	89	672.5	120	87	84	90	0.088	1		
10		100	4.40	12.72	13.73	10.51	351	90	108	82	504	195	319	333	369	651	135	328.8	120	87	86	87	674.9	120	87	84	90	0.088	1		
11		110	4.40	14.06	12.94	12.46	315	89	106	82	445	196	309	338	375	606	135	331.2	120	86	86	87	677.3	120	87	84	90	0.088	1		
12		120	4.20	15.40	12.94	13.21	301	90	104	82	423	196	304	323	379	580	135	333.6	120	86	86	87	679.7	120	87	84	90	0.088	1		
13		130	4.00	16.74	13.21	13.21	287	89	103	82	407	195	300	318	383	561	135	336.0	120	86	86	87	682.1	120	88	84	90	0.088	1		
14		140	3.80	18.08	13.21	13.21	273	89	102	82	393	194	295	315	387	543	135	338.4	120	86	86	87	684.5	120	88	84	90	0.088	1		
15		150	3.60	19.42	13.21	13.21	259	89	101	82	379	192	291	312	391	525	135	340.8	120	86	86	87	686.9	120	88	84	90	0.088	1		
16		160	3.50	20.76	13.21	13.21	245	89	100	82	365	191	285	308	395	507	135	343.2	120	87	87	87	689.3	120	87	84	90	0.088	1		
17		170	3.30	22.10	13.21	13.21	231	89	100	82	351	190	280	300	399	489	135	345.6	120	86	87	87	691.7	120	87	84	90	0.088	1		
18		180	3.20	23.44	13.21	13.21	217	89	100	82	337	189	276	297	392	471	135	348.0	120	86	87	87	694.1	120	87	84	90	0.088	1		
19		190	3.10	24.78	13.21	13.21	203	89	100	82	323	188	271	294	386	453	135	350.4	120	86	87	87	696.5	120	87	84	90	0.088	1		
20		200	3.00	26.12	13.21	13.21	189	88	100	82	309	187	267	292	380	435	135	352.8	120	86	87	87	698.9	120	87	84	90	0.088	1		
21		210	2.90	27.46	13.21	13.21	175	88	99	82	295	186	262	290	374	417	135	355.2	120	86	87	87	701.3	120	87	84	90	0.088	1		
22		220	2.80	28.80	13.21	13.21	161	88	99	82	281	185	257	288	368	399	135	357.6	120	86	87	87	703.7	120	87	84	90	0.088	1		
23		230	2.70	30.14	13.21	13.21	147	88	99	82	267	184	252	286	362	381	135	360.0	120	86	87	87	706.1	120	87	84	90	0.088	1		
24		240	2.60	31.48	13.21	13.21	133	88	99	82	253	183	247	284	356	363	135	362.4	120	86	87	87	708.5	120	87	84	90	0.088	1		
25		250	2.50	32.82	13.21	13.21	119	88	99	82	239	182	242	282	350	345	135	364.8	120	86	87	87	710.9	120	87	84	90	0.088	1		
26		260	2.40	34.16	13.21	13.21	105	88	99	82	225	181	237	280	344	327	135	367.2	120	86	87	87	713.3	120	87	84	90	0.088	1		
27		270	2.30	35.50	13.21	13.21	91	88	99	82	211	180	232	278	338	309	135	369.6	120	86	87	87	715.7	120	87	84	90	0.088	1		
28		280	2.20	36.84	13.21	13.21	77	88	99	82	197	179	227	276	332	291	135	372.0	120	86	87	87	718.1	120	87	84	90	0.088	1		
29		290	2.10	38.18	13.21	13.21	63	88	99	82	183	178	222	274	326	273	135	374.4	120	86	87	87	720.5	120	87	84	90	0.088	1		
30		300	2.00	39.52	13.21	13.21	49	88	99	82	169	177	217	272	320	255	135	376.8	120	86	87	87	722.9	120	87	84	90	0.088	1		
31		310	1.90	40.86	13.21	13.21	35	88	99	82	155	176	212	270	314	237	135	379.2	120	86	87	87	725.3	120	87	84	90	0.088	1		
32		320	1.80	42.20	13.21	13.21	21	88	99	82	141	175	207	268	308	219	135	381.6	120	86	87	87	727.7	120	87	84	90	0.088	1		
33		330	1.70	43.54	13.21	13.21	7	88	99	82	127	174	202	266	302	201	135	384.0	120	86	87	87	730.1	120	87	84	90	0.088	1		
34		340	1.60	44.88	13.21	13.21	0	88	99	82	113	173	197	264	296	183	135	386.4	120	86	87	87	732.5	120	87	84	90	0.088	1		
35		350	1.50	46.22	13.21	13.21	0	88	99	82	99	172	192	262	290	165	135	388.8	120	86	87	87	734.9	120	87	84	90	0.088	1		
36		360	1.40	47.56	13.21	13.21	0	88	99	82	85	171	191	260	284	147	135	391.2	120	86	87	87	737.3	120	87	84	90	0.088	1		
37		370	1.30	48.90	13.21	13.21	0	88	99	82	71	170	190	258	278	129	135	393.6	120	86	87	87	739.7	120	87	84	90	0.088	1		
38		380	1.20	50.24	13.21	13.21	0	88	99	82	57	169	189	256	272	111	135	396.0	120	86	87	87	742.1	120	87	84	90	0.088	1		
39		390	1.10	51.58	13.21	13.21	0	88	99	82	43	168	188	254	266	93	135	398.4	120	86	87	87	744.5	120	87	84	90	0.088	1		
40		400	1.00	52.92	13.21	13.21	0	88	99	82	29	167	187	252	260	75	135	400.8	120	86	87	87	746.9	120	87	84	90	0.088	1		
41		410	0.90	54.26	13.21	13.21	0	88	99	82	15	166	186	250	254	57	135	403.2	120	86	87	87	749.3	120	87	84	90	0.088	1		
42		420	0.80	55.60	13.21	13.21	0	88	99	82	1	165	185	248	248	39	135	405.6	120	86	87	87	751.7	120	87	84	90	0.088	1		
43		430	0.70	56.94	13.21	13.21	0	88	99	82	0	164	184	246	242	21	135	408.0	120	86	87	87	754.1	120	87	84	90	0.088	1		
44		440	0.60	58.28	13.21	13.21	0	88	99	82	0	163	183	244	236	3	135	410.4	120	86	87	87	756.5	120	87	84	90	0.088	1		
45		450	0.50	59.62	13.21	13.21	0	88	99	82	0	162	182	242	230	0	135	412.8	120	86	87	87	758.9	120	87	84	90	0.088	1		
46		460	0.40	60.96	13.21	13.21	0	88	99	82	0	161	181	240	224	0	135	415.2	120	86	87	87	761.3	120	87	84	90	0.088	1		
47		470	0.30	62.30	13.21	13.21	0	88	99	82	0	160	180	238	218	0	135	417.6	120	86	87	87	763.7	120	87	84	90	0.088	1		
48		480	0.20	63.64	13.21	13.21	0	88	99	82	0	159	179	236	212	0	135	420.0	120	86	87	87	766.1	120	87	84	90	0.088	1		

370 min light
0 49 49

door open 90 sec air control fall open for 3 1/2 min then slowly closed till 5 min

Page 29 of 50
 Date 8/8/01
 Tech AL/

Manufacturer Morso Model 3600

Job # J20049092 Run 3

PRETEST DILUTION TUNNEL TRAVERSE RUN

Barometric pressure (P_{bar}) 29.05 (inches Hg.) Static pressure (P_s) 1.05 (inches w.c.)
 Inside diameter: Port A 6in. Port B 6in. Tunnel cross sectional area: 0.1963Ft²

Pitot tube type: Standard

Traverse Point	Position (inches)	Velocity Head Δ_p (inches H ₂ O)	Tunnel Temperature (°F)	$\sqrt{\Delta_p}$
A-Centroid	3.00	.059	209	0.2429
B-Centroid	3.00	.060	195	0.2449
A-1	0.40	.054	202	0.2324
A-2	1.50	.059	206	0.2429
A-3	4.50	.059	205	0.2429
A-4	5.60	.055	204	0.2345
B-1	0.40	.056	196	0.2366
B-2	1.50	.060	196	0.2449
B-3	4.50	.060	199	0.2449
B-4	5.60	.054	196	0.2324
AVERAGE			200.8	0.2399

Adjustment factor application

$$V_s = K_p C_p F_p (\sqrt{\Delta_p})_{AVG} \sqrt{\frac{T_s}{P_s M_s}} \quad V_s = K_p C_p (\sqrt{\Delta_p})_{avg} \sqrt{\frac{T_s}{P_s M_s}}$$

Pitot correction 0.9837

Where,
 C_p = Pitot tube coefficient = 0.99 for standard pitot
 Δ_p = manometer reading (inches H₂O)
 T_s = average absolute dilution tunnel temperature (°F + 460)

$$F_p = \frac{(\sqrt{\Delta_p})_{avg}}{(\sqrt{\Delta_p})_{centroid}}$$

P_s = absolute dilution tunnel gas pressure or $\frac{\text{inches H}_2\text{O}}{13.6}$
 $P_{bar} + P_s$
 P_s = static pressure

M_s = 28.56, wet molecular weight of stack gas (alternatively, it may be measured) Adjustment factor for alternative Pitot tube placement:
 K_p = 85.49 Pitot tube constant, (conversion factor for English units)

$(\sqrt{\Delta_p})_{avg}$ = Average of the square roots of the velocity heads (Δ_p) measured at each traverse point.
 $(\sqrt{\Delta_p})_{centroid}$ = Average of the square roots of the velocity heads measured at the tunnel centroid (inches of H₂O)

Manufacturer Morso
 Job # J20049092

Model 3600
 Run 3

Date 8/8/01
 Tech SM

Pre/Post Checks

Moisture Meter Calibration Check:

Time: <u>7:50</u>	X: <input checked="" type="checkbox"/>	Y: <input checked="" type="checkbox"/>	12: <input type="checkbox"/>	22: <input type="checkbox"/>
-------------------	--	--	------------------------------	------------------------------

Facility Conditions:

Air Velocity.....
 Smoke Capture Check.....

	Pre-Test	Post-Test
Air Velocity.....	<u>0</u> fpm	<u>0</u> fpm
Smoke Capture Check.....	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Wood Heater Conditions:

Date Wood Heater Stack Cleaned.....
 Date Dilution Tunnel cleaned.....
 Induced Draft Check.....
 Tunnel Velocity.....
 Flow Rate 140-cfm ±10%.....

Date Wood Heater Stack Cleaned.....	<u>8/4/01</u>
Date Dilution Tunnel cleaned.....	<u>8/4/01</u>
Induced Draft Check.....	<u>0</u>
Tunnel Velocity.....	<u>.052</u>
Flow Rate 140-cfm ±10%.....	<u>147.244</u>

Pitot Leak Check:

Side A.....
 Side B.....

Side A.....	<input checked="" type="checkbox"/>
Side B.....	<input checked="" type="checkbox"/>

Temperature System:

Ambient (65°- 90°F).....
 Wood Heater Surface (±125°F).....

Ambient (65°- 90°F).....	<u>89.8</u> °F
Wood Heater Surface (±125°F).....	<u>-14.6</u> °F

Proportional Checks:

CO Analyzer Drift Check.....
 CO₂ Analyzer Check.....
 O₂ Analyzer Check.....
 Thermocouple check.....

CO Analyzer Drift Check.....	<input checked="" type="checkbox"/>
CO ₂ Analyzer Check.....	<input checked="" type="checkbox"/>
O ₂ Analyzer Check.....	<input checked="" type="checkbox"/>
Thermocouple check.....	<input checked="" type="checkbox"/>

Sampling Train ID Numbers:

Probe.....
 Filter Front.....
 Filter Back.....
 Filter Thermocouple.....
 Filter 5G-3 (<90°F).....

	Train 1	Train 2
Probe.....	<u>5</u>	<u>6</u>
Filter Front.....	<u>17</u>	<u>19</u>
Filter Back.....	<u>18</u>	<u>20</u>
Filter Thermocouple.....	<u>19</u>	<u>22</u>
Filter 5G-3 (<90°F).....	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Thermocouple Identification Number

Flue.....1
 Dilution Tunnel Wet Bulb.....4
 Unit Right Side.....7
 Catalyst/Combustion Chamber.....10

Room.....2
 Unit Top.....5
 Unit Left Side.....8

Dilution Tunnel Dry Bulb.....3
 Unit Back.....6
 Unit Bottom.....9

Page 31 of 50
 Date 8/8/07
 Tech [Signature]

Manufacturer Morso Model 3600
 Job # J20049092 Run 3

Pre-Test Scale Audit

Scale Type	Audit Weight	Measured Weight
Platform	<u>10</u> lbs., Class F	<u>10.0</u> lbs.
Wood	<u>10</u> lbs., Class F	<u>10.00</u> lbs.
Analytical	100 Grams mg, Class S	Grams <u>100.0</u> mg.

LIMITS OF WEIGHT RANGES

ANALYTICAL SCALE..... 50%-150% of dry filter weight, ± 0.1 mg
PLATFORM SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%
WOOD SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%

Manufacturer Morso

Model 3600

Page 32 of 50

Date 8/8/07

Job # J20049092

Run 3

Tech MLAL

SAMPLING EQUIPMENT CHECK OUT

Leakage Checks Tunnel Samplers

	SYSTEM 1		SYSTEM 2	
	Pre-Test	Post-Test	Pre-Test	Post-Test
Unplugged Flow Rate = .25cfm				
Vacuum (inches Hg.)	10"	10"	10"	10"
Final 1 minute DGM (ft ³)	393.620	414.063	739.374	759.585
Initial 1 minute DGM (ft ³)	393.620	414.063	739.374	759.585
Change (C) (ft ³)	0	0	0	0
Allowable leakage .04 x Sample rate or .02cfm	0.0100	0.0100	0.0100	0.0100
Check OK	✓	✓	✓	✓

Leakage Checks Flue Gas Sampler

	Pre Test	Post Test
Plugged Probe		
Vacuum (inches Hg.)	10"	10"
Rotometer Reading (mm)	0	0
Flow Rate (CFM)	0	0
Allowable (.04 x Sample Rate)		
Check OK	✓	✓

Manufacturer Morso

Model 3600

Page 33 of 50

Date 8/8/07

Job # J20049092

Run 3

Tech AL

CONTINUOUS ANALYZERS

Pre-Test (Adjust and Record)

	ZERO		SPAN		CAL. (Record Only)	
CO	00.00	00.00	9.96	9.96	.95	.999
CO ₂	00.00	00.00	24.65	24.65	9.64	9.99
O ₂	00.01	00.00	20.92	20.93	10.20	10.2
	Actual	Should Be	Actual	Should Be	Actual	Should Be

Post Test (Record Only)

	Zero	Span	Cal.	Zero Drift	Span Drift	Cal. Drift	OK?	Not OK*
CO	00.00	10.08	.97	0	.12	.02	✓	
CO ₂	00.02	25.04	9.98	.02	.39	.13	✓	
O ₂	00.02	20.62	10.16	.02	.30	.04	✓	

* Greater than ± 5% of the range used.

Manufacturer Morso

Model 3600

Date 8/8/01

Job # J20049092

Run 3

Tech wd

TEST DATA LOG

RAW DRY GAS METER READINGS

	System 1	System 2
Final (ft ³)	414.044	759.571
Initial (ft ³)	393.620	739.374

AMBIENT CONDITIONS

	Start	End
Barometer. (inches Hg)	29.04	29.03
Wet Bulb (°F)		
Dry Bulb (°F)	74	86.2
Humidity (%)	74	61.7

Manufacturer Moroso

Model 3600

Date 8/5/01

Job # J20049092

Run 3

Tech ML

DILUTION TUNNEL PARTICULATE SAMPLER DATA

FILTER TYPE: Gelman 47mm A/E

Samples in Desecrator.		Date:		Time:					
SYSTEM 1				SYSTEM 2					
Probe and Front Half Housing #		Filter Numbers		Probe and Front Half Housing #		Filter Numbers			
Post Test Weight:		5		17, 18		6		19, 20	
grams		91.0570		grams		2415		grams	
Pre Test Weight:		5		17, 18		6		19, 20	
grams		91.0566		grams		2278		grams	
Gain:		5		17, 18		6		19, 20	
grams		.0004		grams		.0137		grams	
		a1		b1		a2		b2	

Total Gain: a1 + b1 = 14.1m grams a2 + b2 = 13.9m grams

Pre-test Weight Record		SYSTEM 1			SYSTEM 2			TEMP °F	HUMID %
		Probe & Housing Number	Front Filter Number	Back Filter Number	Probe & Housing Number	Front Filter Number	Back Filter Number		
Date	Time	5	17	18	6	19	20		
8/5/01	9:30	91.0573	.1150	.1132	91.5665	.1026	.1142	76	48
8/6/01	6:20	91.0570	.1151	.1130	91.5661	.1023	.1139	76	49
8/7/01	5:55	91.0566	.1149	.1129	91.5661	.1022	.1137	75	48
8/8/01	7:10	91.0566	.1149	.1129	91.5661	.1020	.1135	74	45
		Total	.2278		Total	.2155			

Pre-test Weight Record		SYSTEM 1		SYSTEM 2		TEMP °F	HUMID %
		Probe & Housing Number	Combined Filter Weight Number	Probe & Housing Number	Combined Filter Weight Number		
Date	Time	5	17, 18	6	19, 20		
8/8/01	11:40	91.2654	.2464	91.6229	.2301	85	49
8/9/01	7:18	91.0581	.2418	91.5672	.2300	73	48
8/10/01	7:30	91.0571	.2417	91.5670	.2289	72	46
8/13/01	8:20	91.0570	.2415	91.5669	.2286	75	48

Manufacturer Morso

Model 3600

Date 8/8/01

Job # J20049092

Run 3

Tech W/L

Air control full open

SWITCH NUMBER		1	2	3	4	5	6	7	8	9	10					
READING #	REAL TIME	ELAPSED TIME	WEIGHT REMAINING	FLUE GAS TEMP	ROOM TEMP	TUNNEL DRY BULB	TUNNEL WET BULB	UNIT TOP	UNIT BACK	UNIT RIGHT SIDE	UNIT LEFT SIDE	UNIT BOTTOM	CATALYST DOWNSTREAM	TUNNEL VELOCITY	DRAFT	SMOKE
0	5:45	0	12.20	581	73	208	69	172	73	76	78	74	694		1050	17
1		10	14.20	743	75	202	71	310	85	113	125	93	1293		1101	T
2		20	16.20	836	77	235	74	517	102	155	201	133	1317		1106	C
3		30	7.60	843	80	229	76	651	125	222	296	194	1320		1106	C
4		40	5.10	795	84	205	79	712	147	301	376	286	1129		1101	C
5		50	8.20	788	86	209	80	659	107	360	411	427	1204		1101	C
6		60	6.40	735	88	202	82	665	182	389	423	486	1162		1099	C
7		70	4.30	681	88	188	82	652	192	347	440	530	1099		1096	C
8		80														
9		90														
10		100														
11		110														
12		120														
13		130														
14		140														
15		150														
16		160														
17		170														
18		180														
19		190														
20		200														
21		210														
22		220														
23		230														
24		240														
25		250														

Comments:

~~FED 6.52~~ OF PRETEST AT 9:34 A.M. 2x4x10
 6.52 LB 20.3 MVST
 10:04 Fire started 20sec CONT

Manufacturer Morso Model 3600
 Job # J20049092 Run 4

Page 4 of 50
 Date 8.9.01
 Tech [Signature]

PRETEST DILUTION TUNNEL TRAVERSE RUN

Barometric pressure (P_{bar}) 29.00 (inches Hg.) Static pressure (P_s) 119 (inches w.c.)
 Inside diameter: Port A 6in. Port B 6in. Tunnel cross sectional area: 0.1963Ft^2
 Pitot tube type: Standard

Traverse Point	Position (inches)	Velocity Head Δ_p (inches H ₂ O)	Tunnel Temperature (°F)	$\sqrt{\Delta_p}$
A-Centroid	3.00	.040	121	.2000
B-Centroid	3.00	.040	123	.2000
A-1	0.40	.036	123	.1897
A-2	1.50	.040	121	.2000
A-3	4.50	.040	121	.2000
A-4	5.60	.035	123	.1871
B-1	0.40	.038	121	.1949
B-2	1.50	.040	122	.2000
B-3	4.50	.040	123	.2000
B-4	5.60	.035	120	.1871
		AVERAGE	121.8	.1989

Adjustment factor application

$$V_s = K_p C_p F_p (\sqrt{\Delta_p})_{AVG} \sqrt{\frac{T_s}{P_s M_s}} \quad V_s = K_p C_p (\sqrt{\Delta_p})_{avg} \sqrt{\frac{T_s}{P_s M_s}}$$

Pitot correction 9794

Where,
 C_p = Pitot tube coefficient = 0.99 for standard pitot
 Δ_p = manometer reading (inches H₂O)
 T_s = average absolute dilution tunnel temperature (°F + 460)

$$F_p = \frac{(\sqrt{\Delta_p})_{avg}}{(\sqrt{\Delta_p})_{centroid}}$$

P_s = absolute dilution tunnel gas pressure or $P_{bar} + P_s$
 inches H₂O 13.6
 P_s = static pressure

M_s = 28.56, wet molecular weight of stack gas (alternatively, it may be measured)
 K_p = 85.49 Pitot tube constant, (conversion factor for English units)

Adjustment factor for alternative Pitot tube placement:

$(\sqrt{\Delta_p})_{avg}$ = Average of the square roots of the velocity heads (Δ_p) measured at each traverse point.
 $(\sqrt{\Delta_p})_{centroid}$ = Average of the square roots of the velocity heads measured at the tunnel centroid (inches of H₂O)

Manufacturer Morso Model 3600

Job # J20049092 Run 4

Tech WZ

Pre/Post Checks

Moisture Meter Calibration Check:

Time:	X: <input checked="" type="checkbox"/>	Y: <input checked="" type="checkbox"/>	12: <input checked="" type="checkbox"/>	22: <input checked="" type="checkbox"/>
-------	--	--	---	---

Facility Conditions:

	Pre-Test	Post-Test
Air Velocity.....	0 fpm	0 fpm
Smoke Capture Check.....	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Wood Heater Conditions:

Date Wood Heater Stack Cleaned.....	8/4/07	
Date Dilution Tunnel cleaned.....	8/4/07	
Induced Draft Check.....	0	0
Tunnel Velocity.....	0.040	0.040
Flow Rate 140-cfm ±10%.....		136, 767

Pitot Leak Check:

Side A.....	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Side B.....	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Temperature System:

Ambient (65°- 90°F).....	88.1 °F
Wood Heater Surface (±125°F).....	-18.0 °F

Proportional Checks:

CO Analyzer Drift Check.....	<input checked="" type="checkbox"/>
CO ₂ Analyzer Check.....	<input checked="" type="checkbox"/>
O ₂ Analyzer Check.....	<input checked="" type="checkbox"/>
Thermocouple check.....	<input checked="" type="checkbox"/>

Sampling Train ID Numbers:

	Train 1	Train 2
Probe.....	7	8
Filter Front.....	21	23
Filter Back.....	22	24
Filter Thermocouple.....	19	22
Filter 5G-3 (<90°F).....	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Thermocouple Identification Number

Flue.....1
Dilution Tunnel Wet Bulb4
Unit Right Side.....7
Catalyst/Combustion Chamber.....10

Room.....2
Unit Top.....5
Unit Left Side.....8

Dilution Tunnel Dry Bulb.....3
Unit Back.....6
Unit Bottom.....9

Manufacturer Morso

Model 3600

Date 8-9-01

Job # J20049092

Run 4

Tech ML

Pre-Test Scale Audit

Scale Type	Audit Weight	Measured Weight
Platform	<u>10.0</u> lbs., Class F	<u>10.0</u> lbs.
Wood	<u>10.</u> lbs., Class F	<u>10.00</u> lbs.
Analytical	100 Grams mg., Class S	Grams <u>1000</u> mg.

LIMITS OF WEIGHT RANGES

ANALYTICAL SCALE..... 50%-150% of dry filter weight, ± 0.1 mg
PLATFORM SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%
WOOD SCALE..... 20%-80% of ideal test load weight, ± 0.1 lbs. or 1%

Page 43 of 50
 Date 8-9-01
 Tech [Signature]

Manufacturer Morso Model 3600
 Job # J20049092 Run 4

SAMPLING EQUIPMENT CHECK OUT

Leakage Checks Tunnel Samplers

	SYSTEM 1		SYSTEM 2	
	Pre-Test	Post-Test	Pre-Test	Post-Test
Unplugged Flow Rate = .25cfm				
Vacuum (inches Hg.)	<u>10"</u>	<u>10"</u>	<u>10"</u>	<u>10"</u>
Final 1minute DGM (ft ³)	<u>414.366</u>	<u>460.608</u>	<u>759.708</u>	<u>805.913</u>
Initial 1minute DGM (ft ³)	<u>414.365</u>	<u>460.608</u>	<u>759.706</u>	<u>805.911</u>
Change (C) (ft ³)	<u>.001</u>	<u>0</u>	<u>.002</u>	<u>.002</u>
Allowable leakage .04 x Sample rate or .02cfm	0.0100	0.0100	0.0100	0.0100
Check OK	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>

Leakage Checks Flue Gas Sampler

	Pre Test	Post Test
Plugged Probe		
Vacuum (inches Hg.)	<u>10"</u>	<u>10"</u>
Rotometer Reading (mm)	<u>0</u>	<u>0</u>
Flow Rate (CFM)	<u>0</u>	<u>0</u>
Allowable (.04 x Sample Rate)		
Check OK	<u>✓</u>	<u>✓</u>

Manufacturer Morso

Model 3600

Page 44 of 50

Date 8-9-01

Job # J20049092

Run 4

Tech AL/

CONTINUOUS ANALYZERS

Pre-Test (Adjust and Record)

	ZERO		SPAN		CAL. (Record Only)	
	Actual	Should Be	Actual	Should Be	Actual	Should Be
CO	00.00	00.00	9.96	9.96	.96	.999
CO ₂	00.00	00.00	24.65	24.65	9.61	9.99
O ₂	00.01	00.00	20.93	20.93	10.23	10.2
	Actual	Should Be	Actual	Should Be	Actual	Should Be

Post Test (Record Only)

	Zero	Span	Cal.	Zero Drift	Span Drift	Cal. Drift	OK?	Not OK*
CO	.02	10.04	.96	.02	.08	0	✓	
CO ₂	.05	24.95	9.85	.05	.30	.24	✓	
O ₂	.08	20.61	10.26	.08	.32	.03	✓	

* Greater than ± 5% of the range used.

Manufacturer Morso

Model 3600

Page 45 of 50

Date 8-9-07

Job # J20049092

Run 4

Tech RL

TEST DATA LOG

RAW DRY GAS METER READINGS

	System 1	System 2
Final (ft ³)	460.600	805.982
Initial (ft ³)	414.366	759.708

AMBIENT CONDITIONS

	Start	End
Barometer. (inches Hg)	29.00	28.96
Wet Bulb (°F)		
Dry Bulb (°F)	73	70-74
Humidity (%)	63	70

RL

Page 46 of 50
 Date 8/17/01
 Tech ml

Manufacturer Morso Model 3600
 Job # J20049092 Run 4

DILUTION TUNNEL PARTICULATE SAMPLER DATA

FILTER TYPE: Gelman 47mm A/E

Samples in Desecrator. Date: 8/9/01 Time: 14:10

	SYSTEM 1		SYSTEM 2	
	Probe and Front Half Housing # <u>7</u>	Filter Numbers <u>21, 22</u>	Probe and Front Half Housing # <u>8</u>	Filter Numbers <u>23, 24</u>
Post Test Weight:	<u>90.9492</u> grams	<u>.2581</u> grams	<u>92.1880</u> grams	<u>.2450</u> grams
Pre Test Weight:	<u>90.9477</u> grams	<u>.2296</u> grams	<u>92.1866</u> grams	<u>.2167</u> Grams
Gain:	<u>.0015</u> grams	<u>.0285</u> grams	<u>.0014</u> grams	<u>.0283</u> Grams
	a1	b1	a2	b2

Total Gain: a1 + b1 = 30.0 m grams a2 + b2 = 29.7 m grams

Pre-test Weight Record		SYSTEM 1			SYSTEM 2			TEMP	HUMID
		Probe & Housing Number	Front Filter Number	Back Filter Number	Probe & Housing Number	Front Filter Number	Back Filter Number		
Date	Time	<u>7</u>	<u>21</u>	<u>22</u>	<u>8</u>	<u>23</u>	<u>24</u>	°F	%
<u>8/7/01</u>	<u>6:00</u>	<u>90.9485</u>	<u>.1139</u>	<u>.1162</u>	<u>92.1867</u>	<u>.1026</u>	<u>.1143</u>	<u>75</u>	<u>48</u>
<u>8/8/01</u>	<u>7:15</u>	<u>90.9479</u>	<u>.1136</u>	<u>.1150</u>	<u>92.1867</u>	<u>.1024</u>	<u>.1144</u>	<u>74</u>	<u>45</u>
<u>8/9/01</u>	<u>7:20</u>	<u>90.9477</u>	<u>.1136</u>	<u>.1160</u>	<u>92.1866</u>	<u>.1024</u>	<u>.1143</u>	<u>73</u>	<u>48</u>
		Total	<u>.2296</u>		Total	<u>.2167</u>			

Pre-test Weight Record		SYSTEM 1		SYSTEM 2		TEMP	HUMID
		Probe & Housing Number	Combined Filter Weight Number	Probe & Housing Number	Combined Filter Weight Number		
Date	Time	<u>7</u>	<u>21 22</u>	<u>8</u>	<u>23 24</u>	°F	%
<u>8/9/01</u>	<u>1410</u>	<u>90.9507</u>	<u>.2611</u>	<u>92.1898</u>	<u>.2485</u>	<u>85</u>	<u>49</u>
<u>8/10/01</u>	<u>7:15</u>	<u>90.9493</u>	<u>.2582</u>	<u>92.1881</u>	<u>.2451</u>	<u>72</u>	<u>46</u>
<u>8/13/01</u>	<u>8:25</u>	<u>90.9492</u>	<u>.2581</u>	<u>92.1880</u>	<u>.2450</u>	<u>75</u>	<u>48</u>
<u>8/14/01</u>	<u>1345</u>	<u>90.9492</u>	<u>.2581</u>	<u>92.1880</u>	<u>.2450</u>	<u>75</u>	<u>47</u>

Manufacturer Morso Model 3600

Date 8-9-01

Job # J20049092 Run 4

Tech WJL

Air control 1 7/8 from lip

SWITCH NUMBER			1	2	3	4	5	6	7	8	9	10				
READING #	REAL TIME	ELAPSED TIME	WEIGHT REMAINING	FLUE GAS TEMP	ROOM TEMP	TUNNEL DRY BULB	TUNNEL WET BULB	UNIT TOP	UNIT BACK	UNIT RIGHT SIDE	UNIT LEFT SIDE	UNIT BOTTOM	CATALYST DOWNSTREAM	TUNNEL VELOCITY	DRAFT	SMOKE
0	9:24	0	136	549	76	164	71	457	101	161	185	174	642		.079	C
1		10	1230	491	77	137	71	429	118	198	217	220	927	.040	.082	C
2		20	1080	516	77	140	72	468	129	212	234	249	991		.082	C
3		30	920	611	79	155	74	523	140	227	265	270	1109	.040	.092	C
4		40	760	573	80	149	75	586	150	250	300	289	1070		.089	C
5		50	520	566	81	148	76	615	160	271	330	311	1073	.040	.089	C
6		60	470	506	84	142	78	602	171	293	354	339	906	.040	.081	C
7		70	330	431	84	129	78	528	178	307	365	377	769	.040	.072	C
8		80														
9		90														
10		100														
11		110														
12		120														
13		130														
14		140														
15		150														
16		160														
17		170														
18		180														
19		190														
20		200														
21		210														
22		220														
23		230														
24		240														
25		250														

Comments: *10:01 Fire started
10:26 Fire started 15 sec
10:46 Fire started door open 1 min*

APPENDIX B

INTRODUCTION

This document provides a step by step guide for the technician conducting tests to EPA standard requirements. Procedures outlined here, when followed, will result in tests in conformance with EPA Methods 28 and 5G-3. This guide cannot cover every possible contingency that may develop during a particular test program. Many questions that may arise can be answered by a complete understanding of the test standards and their intent. When in doubt on any detail check with the laboratory manager and be sure you understand the procedures involved.

The primary measurements to be obtained are particulate emission data and efficiency data. The technician's duties include the following steps. It is critical that all spaces on the data forms be properly filled in. Each test must be represented by a complete record of what was done and when.

I. APPLIANCE INSPECTION AND SET-UP

- A. Incoming Inspection
- B. Unit Set-Up

II. SAMPLING SYSTEMS - SET-UP

- A. Gas Analysis
- B. Dilution Tunnel

III. TEST CONDUCT

- A. Pre-Test Fuel Load
- B. Test Fuel Load
- C. Unit Start - up
- D. Test Run

IV. POST TEST PROCEDURE

- A. Leak Checks
- B. Particulate Sample Recovery

The technician running this test must be familiar with the following EPA documents that are to be kept in the laboratory at all times.

- 1. Method 28
- 2. Method 28A
- 3. Method 5G-3
- 4. Method 5H

I. APPLIANCE INSPECTION AND SET-UP

A. Incoming Inspection

1. Check for completeness of unit including parts, accessories, installation and operating instructions, drawings and specifications, etc. Note any discrepancies or missing parts.
2. Check for shipping damage. If damage has occurred, notify the laboratory manager. In some cases repairs may be made, provided the manufacturer and laboratory manager concur that repairs will not affect the units performance. If damage is irreparable, a new unit will need to be obtained.
3. Note whether unit is catalytic or non-catalytic.
4. Mark unit with manufacturer's name, model number, work order number and date received.
5. If unit is safety listed, note label data including listing agency and serial number.

B. Unit Set-Up

1. All units must be operated in-house for a break-in period as follows (the unit may be connected to a lab chimney). NOTE: Inserts are tested as if they are freestanding stoves.
 - a. Non-catalytic units: 10 hours minimum burn time with a stack temperature of at least 250⁰ Fahrenheit (medium burn rate, Douglas Fir scrap or cordwood.) A stack thermocouple must be installed and stack temperature recorded at 1-hour intervals or on chart recorder.
 - b. Catalytic units: 50 hours minimum burn time with catalyst temperature in excess of 800⁰ Fahrenheit (medium burn rate, Douglas Fir scraps or cordwood). Record catalyst temperature at 1-hour intervals or on chart recorder.
2. Once break-in is completed, allow unit to cool then clean unit thoroughly.
3. Thermocouples must be attached to surfaces of unit prior to testing. EPA requires a thermocouple on the outside bottom of the firebox. This must be installed prior to putting the unit on the scale. In some cases the required thermocouple locations will be inaccessible on finished units. Check with the laboratory manager if problems are encountered in proper thermocouple attachment.
4. Prior to placing unit on scale, the scale must be turned on and allowed to warm up for 1-hour minimum.
5. Place unit on scale and align so chimney will be centered in hood. Record the weight of the unit and all accessories. (Do not weight with chimney attached.)

6. Chimney and connector should be cleaned with a wire brush prior to mounting. Attach chimney and connector then seal all joints. Be sure single wall stove pipe terminates and insulated pipe starts at proper level above scale platform. Chimney must be supported from scale so that it does not touch test enclosure or hood walls.
7. Measure firebox dimensions and record on appropriate data form. Make a three dimensional sketch of the firebox including firebrick, baffles, and obstructions. Calculate firebox volume in cubic feet. See Section 6.2.4 of EPA Method 28 for details.
8. If unit is equipped with a catalyst additional thermocouples must be installed downstream of, and inside catalyst (upstream optional).
9. Plug thermocouples into data acquisition system jacks and verify that all instrumentation is working properly.
10. Dilution tunnel must be cleaned prior to each certification test series, and at anytime a higher burn rate follows a lower burn rate.

II. SAMPLING SYSTEMS SET-UP

A. Gas Analysis

1. All instruments should be turned on and allowed to warm up for 1-hour minimum.
2. Prior to calibrating, make sure that the outlet pressure on each calibration gas bottle reads 10 PSI. Adjust flow meters at each gas analyzer to required flow.

All gas analyzers (CO₂, CO, O₂) are zeroed on nitrogen. The O₂ analyzer is spanned on air and set for 20.93%. CO₂ and CO analyzers are spanned with their respective gases.

Calibrate analyzers as follows:

- a. With calibration switch at "SPAN", adjust all span controls to values specified on span gas label.
 - b. Switch to "ZERO" and adjust zero controls to provide 0.00 readout on all analyzers.
 - c. Repeat a. and b. until no further adjustment is required.
 - d. Record these values on the appropriate data sheet.
 - e. Switch to "CAL." and record all analyzer values.
3. Response time synchronization check.
 - a. With switch at "SAMPLE" and no fire in unit, allow readings to stabilize (O₂ analyzer should read 20.93, CO and CO₂ should read 0.00).
 - b. Switch to "CAL" setting and start the stopwatch. Note the time required for each unit to reach the calibration gas bottle value. If all three analyzers reach this value within 5 seconds of each other, synchronization is adequate. If not, contact the laboratory manager. Synchronization is adjusted by either internal instrument setting or adjustment of sample line length.
 - c. Use EPA Method 5H 6.7-6.9 procedures to check calibration of instruments.

4. Sample clean-up train.
 - a. Load a new filter in 4-inch glass filter holder.
 - b. Load four Impingers as follows:
 - #1: 100 ml. distilled water and 5 ml. H_2SO_4
 - #2: 100 ml. distilled water and 5 ml. H_2SO_4
 - #3: Empty
 - #4: 200-300 grams Drierite.
 - c. Place Impingers in container and connect with greased "U TUBES".
(Grease carefully on bottom half of ball joint so that grease will not get into tubes.)
 - d. Connect filter to impinger #1 and sample line to impinger #4.
 - e. Connect stack probe to filter.
 - f. Leak check system as follows:
 - 1) Plug probe.
 - 2) Turn on sample system and increase flow rate slowly.
 - 3) Set vacuum adjust valve to obtain a vacuum of 10 inches mercury.
 - 4) If sapphire float in rotometer does not stabilize below 10 on scale, system must be resealed.
 - 5) Repeat leak check procedure until satisfactory results are obtained.
 - 6) Unplug probe slowly, then decrease flow rate slowly before shutting off system.
 - g. Just prior to starting test, fill impinger container with ice.

B. Dilution Tunnel Sample Train Set-Up:

1. Filters and holders.

- a. Clean probes and filter holder front housings carefully and desiccate to a constant weight prior to use.
- b. Filters and filter probe combinations should be numbered and labeled prior to use.
- c. Weigh desiccated filters and probe filter units on analytical balance. Record weights on appropriate form. Note that probe and front half of front filter holder is to be weighed as a unit.
- d. Carefully assemble filter holder units and connect to sampling systems.
- e. Check Silica gel columns for adequate dry absorbent (blue color).

2. Leak checking.

- a. Each sample system is to be checked for leakage prior to inserting probes in tunnel.
- b. Plug probes and start samplers. Adjust pump bypass valve to produce a vacuum reading of 10 inches mercury. NOTE: During test, highest vacuum recorded is required for posttest leak check.
- c. Allow vacuum indication to stabilize at 10" mercury, record dry gas meter readings, (DGM₁, DGM₂). At a convenient DGM value start stopwatch. Time for 1 minute then stop vacuum pumps. Record dry gas meter readings again, (DGM₃, DGM₄). NOTE: If rotometer ball is floating above the 5-mm mark, system is leaking too much and all seals should be checked.
- d. Calculate leakage rate as follows.

$$\text{System 1: } DGM_3 - DGM_1 = CFM_1$$

$$\text{System 2: } DGM_4 - DGM_2 = CFM_2$$

If CFM₁ or CFM₂ is greater than 0.02 cfm, or ₁S greater than 0.04 x Sample Rate, leakage is unacceptable and system must be resealed. For most tests the sample rate will be 0.25 cfm, thus leakage rates in excess of 0.04 x 0.25 = 0.010 cfm are not acceptable.

- e. To prevent contamination, do not insert probes in tunnel until the start of the test run.

III. TEST CONDUCT

A. Pre-Test Fuel Load

1. Using 2x4 Douglas Fir cut enough pieces to approximate test load weight. (Piece length must be greater than 1/3 of the test load length.)
2. Measure percent moisture content using Delmhorst moisture meter. The average percent moisture must be within 19 to 25 percent.

B. Test Fuel Load

1. Determine optimum load weight by multiplying firebox volume (cubic feet) by 7. This is the ideal load weight.
2. Determine piece size mix i.e. <1.5 cubic feet volume use 2x4's only; 1.5 ft³ to 3.0 ft³ use a mix of 2.4's and 4x4's; >3.0 ft³ use only 4x4's. Ideal length is 5/6 of the longest firebox dimension.
3. Weigh out test load and appropriate number of spacers and adjust weight by shortening or lengthening all pieces equally if necessary.
4. Construct test loads by attaching spacers as shown in EPA Method 28.
5. Measure and record moisture content of each fuel piece (use three sides). Determine if fuel load moisture content is within required range (19-25%). If not, construct new fuel pieces using wood with required moisture content. All wood in the humidity chamber is Douglas Fir and should be within range. Contact laboratory manager if you cannot find suitable pieces.

C. Unit Start-Up

1. With all doors and air controls closed, zero draft Magnehelic using screw located at bottom of meter.
2. Before lighting a fire, turn on dilution tunnel and set flow rate to 140 scfm (approximately 715 fpm) if burn rate is to be less than 3 kg/hr. For higher burn rates set flow for a 150:1 air fuel ratio (see chart for approximate values).
3. Check draft imposed on cold stove. All inlets must be closed and a draft gauge in the chimney. If draft is greater than 0.005 inches water column, adjust tunnel to stack gap until draft is less than 0.005 inches water column.
4. With hot wire anemometer check for ambient airflow around unit (must be less than 50 ft/min).
5. Zero scale and start fire with newspaper and Douglas Fir kindling. (Make sure stack sample probe is on the unit.)

6. Once kindling is burning well, add preload fuel. Operate at high fire for sufficient time to get fuel load burning well. Then adjust settings to intended test run levels.
7. Perform the dilution tunnel traverse as prescribed in Method 28, Section 6.3. (Pitot tube should be carefully cleaned prior to each test.)
8. Pretest load must burn for a minimum of 1 hour. Record stove surface, catalyst, room and flue temperatures.
9. Stir fire often during preburn (after a reading) to get a good coal bed. Fire can only be raked once (door open 1 minute or less) during the 15 minutes prior to the start of the test.

D. Test Run

1. Stack gas analyzers should be on and in the sample mode.
2. When the fuel bed is between 20-25% of the test load weight the test is to be started.
 - a. Insert the sample probes into the tunnel being careful not to hit sides of tunnel with probe tip.
 - b. Check tunnel Pitot tube for proper position.
 - c. Record initial readings.
 - d. Turn on probe sample systems and start timing test.
 - e. Tare platform scale.
 - f. Open stove doors and load stove. Close door or follow manufacturer's start-up procedures. Five minutes is the maximum time before all doors and controls must be set to final positions for duration of test.
 - g. Record length of time door and bypass are open, include any air control setting adjustments.
 - h. Every 10 minutes record the following:
 - 1) Dry gas meter readings.
 - 2) Weight remaining.
 - 3) All thermocouple temperatures.
 - 4) Tunnel Pitot tube reading.
 - 5) Draft reading.
 - 6) Rotometer readings.
 - i. Filter temperatures shall not exceed 901F anytime during the test. If approaching 901F turn on cooling pump. Filters must be kept above the dilution tunnel wet bulb temperature in order to prevent condensation.
 - j. Regularly check impinger for ice level during test.
 - k. After 30 seconds of 0.00 lbs. weight, and on the minute, shut off sample trains and record last reading.
 - l. Record final dry gas meter values.

IV. POST TEST PROCEDURES

A. Leak Checks

1. Dilution Tunnel

- a. Remove both sample probes from tunnel and plug with rubber stopper.
- b. Turn on sample system and set vacuum to 10" mercury or to the highest value reached during the test.
- c. At a convenient value start stop watch. Record DGM starting value.
- d. After 1 minute stop sample system and record ending DGM value.
- e. Calculate leakage rate per pre-test description (see II.B.2.c.).

2. Gas Analyzers

- a. Set stack sample flow to about 75 mm on the rotometer.
- b. Plug with rubber stopper.
- c. Adjust vacuum to 10" mercury.
- d. Let system stabilize then record rotometer readings.
- e. If rotometer readings do not equal zero check with laboratory manager.
- f. SLOWLY unplug probe and decrease flow rate to zero.
- g. Turn off stack sampling system.
- h. Zero, span and calibrate the analyzers (see Gas Analysis). RECORD ONLY these meter values.

B. Particulate Sample Recovery

1. Disassemble filter holder and scrape gasket with scalpel. Collect all loose material on filters.
2. Weigh and record probes and filters for each train. NOTE: 24 hours of desiccation must pass before final "no change" weight values can be recorded.
3. Weigh and record probes and fillers at 2-hour intervals until weight change between weighing is less than 0.5 mg.

V. DISPOSITION OF TESTED UNIT.

In order to meet the requirements of section 60.535(g) of the EPA's 40CFR Part 60 Standards of Performance for New Stationary Sources; New Residential Wood Heaters, Intertek Testing Services seals certified wood heaters by strapping the unit to a pallet and covering the unit with stretch wrap. A copy of the EPA certificate is attached and our WHI logo stamped on the stretch wrap in various positions and then another layer of stretch wrap is used to cover the markings and copy of the certificate. Any breaking of the stretch wrap seal will be easily noticeable. The unit is then shipped back to the manufacturer.

APPENDIX C

Manufacturer:		Morso							
Model:		3600							
Date:		8/6/01							
Run:		1							
Project #:		J20049092							
Test Duration:		270							
Total Gas Volume (DGM 1):		62.32975							
Total Gas Volume (DGM 2):		63.03275							
Average Barometric Pressure:		29.3							
Molecular Weight:		28.56							
Pitot Correction:		0.9824							
Calibration Factor (DGM #1):		1.0206							
Calibration Factor (DGM #2):		1.0311							
(1) VS:		0.023272							
(2) VS:		0.023013							
								Filter	Filter
								Face	Face
								Velocity	Velocity
								DGM 1	DGM 2
Elapsed	DGM 1	DGM 1	DGM 1	DGM 2	DGM 2	DGM 2	Tunnel		
Time	Reading	Inlet T	Outlet T	Reading	Inlet T	Outlet T	Dry Bulb		
0	240.1	79	78	586.4	76	76	108		
10	242.5	79	78	588.7	77	76	128	20.27	19.70
20	244.9	80	79	591.1	79	77	127	20.23	20.49
30	247.2	81	80	593.5	79	78	128	19.35	20.48
40	249.6	82	81	595.9	81	79	129	20.15	20.42
50	252.0	83	82	598.2	82	80	126	20.12	19.53
60	254.4	84	83	600.6	83	81	120	20.08	20.34
70	256.8	85	84	603.0	84	82	114	20.04	20.31
80	259.1	86	85	605.3	85	84	110	19.17	19.41
90	261.5	86	86	607.7	85	83	108	19.99	20.27
100	263.9	87	87	610.1	86	85	106	19.95	20.21
110	266.3	88	88	612.5	87	85	105	19.92	20.19
120	268.7	88	88	614.9	87	86	102	19.92	20.18
130	271.1	88	88	617.3	87	86	101	19.92	20.18
140	273.5	89	89	619.7	88	87	101	19.88	20.14
150	275.9	89	90	622.1	88	87	99	19.86	20.14
160	278.3	90	90	624.5	88	88	99	19.84	20.12
170	280.7	90	90	626.9	88	88	99	19.84	20.12
180	283.1	89	90	629.3	88	88	98	19.86	20.12
190	285.5	89	90	631.7	88	89	98	19.86	20.10
200	287.9	89	90	634.1	88	88	98	19.86	20.12
210	290.3	89	90	636.5	88	88	97	19.86	20.12
220	292.7	89	89	638.9	88	89	97	19.88	20.10
230	295.1	88	89	641.3	88	88	97	19.90	20.12
240	297.5	88	88	643.7	88	88	97	19.92	20.12
250	299.9	89	89	646.1	88	88	97	19.88	20.12
260	302.3	89	89	648.5	88	88	97	19.88	20.12
270	304.7	88	89	650.9	88	88	96	19.90	20.12

Proportional Rate Calculations				(EPA Formulas from PR5G)				
Stack area (ft ²):	0.1963			Manufacturer:	Morso			
Wood moisture (% wet):	17.36			Model:	3600			
Load Weight (lbs wet):	14.87			Date:	8/6/01			
Burn Rate (Dry kg/hr):	1.239			Run:	1			
Final Temperature (DGM #1) Degrees Rankin:				546.429				
Final Temperature (DGM #2) Degrees Rankin:				545.000				
Final Tunnel Temperature Degrees Rankin:				566.500				
Final Tunnel Velocity (feet per second):				13.6957793				
Standardized Tunnel Flow (dscfm):				141.284923				
		Average Inlet + Outlet Temp. Meter 1	Average Inlet + Outlet Temp. Meter 2			#1 dDGM Vol.Std. (ft ³)	#2 dDGM Vol.Std. (ft ³)	Time
Tunnel Velocity	Ft/Sec	Deg. R	Deg. R	PR1	PR2			
0.040	13.703	538.5	536.0					0
0.040	13.942	538.5	536.5	103.84	99.78	2.351	2.285	10
0.039	13.755	539.5	538.0	104.88	105.07	2.347	2.377	20
0.040	13.942	540.5	538.5	99.14	103.74	2.245	2.375	30
0.040	13.954	541.5	540.0	103.35	103.54	2.338	2.369	40
0.040	13.918	542.5	541.0	102.90	98.79	2.334	2.266	50
0.040	13.847	543.5	542.0	102.18	102.36	2.329	2.360	60
0.040	13.775	544.5	543.0	101.46	101.64	2.325	2.355	70
0.040	13.727	545.5	544.5	96.72	96.80	2.224	2.251	80
0.040	13.703	546.0	544.0	100.65	100.93	2.319	2.351	90
0.041	13.849	547.0	545.5	99.06	99.24	2.314	2.345	100
0.040	13.667	548.0	546.0	100.02	100.29	2.310	2.343	110
0.040	13.630	548.0	546.5	99.76	99.93	2.310	2.340	120
0.040	13.618	548.0	546.5	99.67	99.84	2.310	2.340	130
0.040	13.618	549.0	547.5	99.49	99.66	2.306	2.336	140
0.040	13.594	549.5	547.5	99.22	99.48	2.304	2.336	150
0.039	13.423	550.0	548.0	100.39	100.66	2.302	2.334	160
0.040	13.594	550.0	548.0	99.13	99.39	2.302	2.334	170
0.040	13.582	549.5	548.0	99.13	99.30	2.304	2.334	180
0.040	13.582	549.5	548.5	99.13	99.21	2.304	2.332	190
0.041	13.750	549.5	548.0	97.91	98.08	2.304	2.334	200
0.040	13.569	549.5	548.0	99.04	99.21	2.304	2.334	210
0.040	13.569	549.0	548.5	99.13	99.12	2.306	2.332	220
0.041	13.738	548.5	548.0	98.00	98.00	2.308	2.334	230
0.040	13.569	548.0	548.0	99.31	99.21	2.310	2.334	240
0.041	13.738	549.0	548.0	97.91	98.00	2.306	2.334	250
0.040	13.569	549.0	548.0	99.13	99.21	2.306	2.334	260
0.040	13.557	548.5	548.0	99.13	99.13	2.308	2.334	270

Manufacturer: Morso
 Model: 3600
 Date: 8/8/01
 Run: 2
 Project #: J20049092
 Test Duration: 370
 Total Gas Volume (DGM 1): 85.475451
 Total Gas Volume (DGM 2): 86.303969
 Average Barometric Pressure: 29.27
 Molecular Weight: 28.56
 Pitot Correction: 0.9794
 Calibration Factor (DGM #1): 1.0206
 Calibration Factor (DGM #2): 1.0311
 (1) VS: 0.0164913
 (2) VS: 0.016333

Elapsed Time	DGM 1 Reading	DGM 1 Inlet T	DGM 1 Outlet T	DGM 2 Reading	DGM 2 Inlet T	DGM 2 Outlet T	Tunnel Dry Bulb	Filter Face	Filter Face
								Velocity DGM 1	Velocity DGM 2
0	305.0	79	79	650.9	77	77	106		
10	307.4	81	79	653.3	79	78	125	20.19	20.45
20	309.8	82	80	655.7	80	78	124	20.15	20.44
30	312.1	83	81	658.1	82	80	128	19.28	20.36
40	314.5	84	83	660.5	82	80	129	20.06	20.36
50	316.9	84	83	662.9	83	82	130	20.06	20.30
60	319.3	85	84	665.3	84	83	128	20.02	20.27
70	321.7	86	85	667.7	85	84	122	19.99	20.23
80	324.0	87	86	670.1	86	84	118	19.12	20.21
90	326.4	88	87	672.5	87	86	115	19.91	20.16
100	328.8	87	87	674.9	86	86	110	19.93	20.17
110	331.2	86	86	677.3	87	87	108	19.97	20.14
120	333.6	86	86	679.6	87	88	106	19.97	19.28
130	336.0	86	86	682.0	88	88	104	19.97	20.10
140	338.4	86	86	684.4	88	88	103	19.97	20.10
150	340.8	87	87	686.8	88	89	102	19.93	20.08
160	343.2	87	87	689.2	87	88	101	19.93	20.12
170	345.6	87	87	691.6	87	88	101	19.93	20.12
180	347.9	86	87	693.9	86	87	100	19.12	19.32
190	350.3	86	87	696.3	86	87	100	19.95	20.16
200	352.7	86	87	698.7	85	87	100	19.95	20.17
210	355.1	86	86	701.0	85	86	100	19.97	19.35
220	357.5	86	86	703.4	85	85	99	19.97	20.21
230	359.9	86	86	705.8	85	86	99	19.97	20.19
240	362.3	86	86	708.2	86	86	100	19.97	20.17
250	364.7	86	86	710.6	85	85	99	19.97	20.21
260	367.1	86	86	713.0	85	85	99	19.97	20.21
270	369.5	86	86	715.4	85	86	98	19.97	20.19
280	372.0	86	86	717.8	85	86	98	20.80	20.19
290	374.4	85	86	720.2	86	86	97	19.99	20.17
300	376.8	86	86	722.6	86	87	97	19.97	20.16
310	379.2	86	86	725.0	86	86	97	19.97	20.17
320	381.6	86	86	727.4	86	86	96	19.97	20.17
330	383.9	86	86	729.7	86	86	96	19.14	19.33
340	386.3	86	86	732.1	86	86	96	19.97	20.17
350	388.7	86	86	734.5	86	86	96	19.97	20.17
360	391.1	86	86	736.9	85	85	97	19.97	20.21
370	393.5	87	86	739.3	86	86	96	19.95	20.17

Proportional Rate Calculations				(EPA Formulas from PR5G)				
Stack area (ft2):		0.1963		Manufacturer:		Morso		
Wood moisture (% wet):		16.96		Model:		3600		
Load Weight (lbs wet):		15.54		Date:		8/8/01		
Burn Rate (Dry kg/hr):		0.949		Run:		2		
Final Temperature (DGM #1) Degrees Rankin:				545.434				
Final Temperature (DGM #2) Degrees Rankin:				545.105				
Final Tunnel Temperature Degrees Rankin:				565.789				
Final Tunnel Velocity (feet per second):				13.2923224				
Standardized Tunnel Flow (dscfm):				137.154509				
		Average Inlet + Outlet Temp.				#1 dDGM Vol. Std.		#2 dDGM Vol. Std.
Tunnel Velocity		Meter 1		Meter 2		(ft3)		(ft3)
Velocity	Ft/Sec	Deg. R	Deg. R	PR1	PR2			Time
0.040	13.641	539.0	537.0					0
0.039	13.694	540.0	538.5	101.75	102.09	2.342	2.373	10
0.039	13.682	541.0	539.0	101.47	101.91	2.338	2.371	20
0.038	13.552	542.0	541.0	98.67	103.21	2.236	2.362	30
0.038	13.563	543.5	541.0	102.76	103.30	2.327	2.362	40
0.038	13.575	543.5	542.5	102.85	103.10	2.327	2.355	50
0.038	13.552	544.5	543.5	102.49	102.74	2.323	2.351	60
0.038	13.483	545.5	544.5	101.78	102.02	2.318	2.347	70
0.038	13.436	546.5	545.0	97.02	101.58	2.218	2.344	80
0.039	13.576	547.5	546.5	99.49	99.73	2.310	2.338	90
0.040	13.689	547.0	546.0	97.90	98.14	2.312	2.340	100
0.039	13.494	546.0	547.0	99.16	99.03	2.316	2.336	110
0.039	13.470	546.0	547.5	98.98	94.65	2.316	2.236	120
0.038	13.272	546.0	548.0	100.10	99.79	2.316	2.332	130
0.039	13.434	546.0	548.0	98.72	98.42	2.316	2.332	140
0.039	13.422	547.0	548.5	98.45	98.24	2.312	2.329	150
0.038	13.237	547.0	547.5	99.65	99.62	2.312	2.334	160
0.039	13.410	547.0	547.5	98.36	98.33	2.312	2.334	170
0.039	13.398	546.5	546.5	94.27	94.32	2.218	2.241	180
0.038	13.225	546.5	546.5	99.65	99.71	2.314	2.338	190
0.037	13.050	546.5	546.0	100.99	101.14	2.314	2.340	200
0.038	13.225	546.0	545.5	99.74	95.73	2.316	2.245	210
0.039	13.386	546.0	545.0	98.37	98.61	2.316	2.344	220
0.038	13.213	546.0	545.5	99.65	99.80	2.316	2.342	230
0.038	13.225	546.0	546.0	99.74	99.80	2.316	2.340	240
0.036	12.861	546.0	545.0	102.38	102.63	2.316	2.344	250
0.036	12.861	546.0	545.0	102.38	102.63	2.316	2.344	260
0.037	13.027	546.0	545.5	100.90	101.05	2.316	2.342	270
0.037	13.027	546.0	545.5	105.11	101.05	2.413	2.342	280
0.037	13.015	545.5	546.0	100.90	100.87	2.318	2.340	290
0.037	13.015	546.0	546.5	100.81	100.78	2.316	2.338	300
0.037	13.015	546.0	546.0	100.81	100.87	2.316	2.340	310
0.038	13.178	546.0	546.0	99.39	99.45	2.316	2.340	320
0.037	13.003	546.0	546.0	96.52	96.58	2.220	2.243	330
0.036	12.827	546.0	546.0	102.11	102.17	2.316	2.340	340
0.038	13.178	546.0	546.0	99.39	99.45	2.316	2.340	350
0.038	13.190	546.0	545.0	99.48	99.72	2.316	2.344	360
0.037	13.003	546.5	546.0	100.63	100.78	2.314	2.340	370

Manufacturer:		MORSO							
Model:		3600							
Date:		8/8/01							
Run:		3							
Project #:		0							
Test Duration:		85							
Total Gas Volume (DGM 1):		19.615629							
Total Gas Volume (DGM 2):		19.68314							
Average Barometric Pressure:		29.035							
Molecular Weight:		28.56							
Pitot Correction:		0.9837							
Calibration Factor (DGM #1):		1.0206							
Calibration Factor (DGM #2):		1.0311							
(1) VS:		0.0777721							
(2) VS:		0.0775054							
								Filter	Filter
								Face	Face
								Velocity	Velocity
Elapsed	DGM 1	DGM 1	DGM 1	DGM 2	DGM 2	DGM 2	Tunnel	Velocity	Velocity
Time	Reading	Inlet T	Outlet T	Reading	Inlet T	Outlet T	Dry Bulb	DGM 1	DGM 2
0	393.6	78	78	739.3	76	76	185		
10	396.0	80	78	741.7	78	76	266	20.07	20.35
20	398.4	81	79	744.0	79	77	258	20.03	19.46
30	400.8	82	81	746.4	81	78	237	19.97	20.25
40	403.2	84	82	748.7	83	80	210	19.92	19.34
50	405.6	85	83	751.1	84	81	190	19.88	20.14
60	408.0	86	85	753.5	85	83	178	19.83	20.09
70	410.4	87	86	755.9	86	84	168	19.79	20.05
80	412.8	88	87	758.3	87	85	161	19.75	20.01
85	414.0	88	88	759.5	87	86	158	19.74	19.99

Proportional Rate Calculations				(EPA Formulas from PR5G)				
Stack area (ft ²):		0.1963		Manufacturer:		MORSO		
Wood moisture (% wet):		18.32		Model:		3600		
Load Weight (lbs wet):		15.69		Date:		8/8/01		
Burn Rate (Dry kg/hr):		4.103		Run:		3		
Final Temperature (DGM #1) Degrees Rankin:				543.300				
Final Temperature (DGM #2) Degrees Rankin:				541.600				
Final Tunnel Temperature Degrees Rankin:				661.100				
Final Tunnel Velocity (feet per second):				16.8090142				
Standardized Tunnel Flow (dscfm):				147.244229				
		Average	Average					
		Inlet +	Inlet +					
		Outlet	Outlet					
		Temp.	Temp.			#1	#2	
	Tunnel	Meter 1	Meter 2			dDGM	dDGM	
	Velocity	Deg. R	Deg. R			Vol.Std.	Vol.Std.	
Velocity	Ft/Sec	Deg. R	Deg. R	PR1	PR2	(ft ³)	(ft ³)	Time
0.052	16.744	538.0	536.0					0
0.050	17.419	539.0	537.0	106.88	108.01	2.328	2.360	10
0.049	17.149	540.0	538.0	107.17	103.79	2.323	2.258	20
0.050	17.068	541.5	539.5	104.24	105.34	2.317	2.349	30
0.052	17.065	543.0	541.5	99.94	96.70	2.310	2.243	40
0.053	16.969	544.0	542.5	97.33	98.26	2.306	2.336	50
0.053	16.812	545.5	544.0	96.16	97.08	2.300	2.330	60
0.051	16.362	546.5	545.0	97.08	98.01	2.296	2.326	70
0.051	16.271	547.5	546.0	96.36	97.28	2.291	2.321	80
0.051	16.231	548.0	546.5	96.04	96.96	1.145	1.160	85

Manufacturer:		Morso							
Model:		3600							
Date:		8/9/01							
Run:		4							
Project #:		J20049092							
Test Duration:		193							
Total Gas Volume (DGM 1):		44.341478							
Total Gas Volume (DGM 2):		44.744423							
Average Barometric Pressure:		28.98							
Molecular Weight:		28.56							
Pitot Correction:		0.9794							
Calibration Factor (DGM #1):		1.0206							
Calibration Factor (DGM #2):		1.0311							
(1) VS:		0.0320172							
(2) VS:		0.0317289							
								Filter Face	Filter Face
								Velocity	Velocity
Elapsed Time	DGM 1 Reading	DGM 1 Inlet T	DGM 1 Outlet T	DGM 2 Reading	DGM 2 Inlet T	DGM 2 Outlet T	Tunnel Dry Bulb	DGM 1	DGM 2
0	414.3	74	74	759.7	73	72	129		
10	416.7	76	75	762.1	75	74	151	20.16	20.40
20	419.0	77	76	764.4	76	74	159	19.28	19.54
30	421.4	79	77	766.8	78	75	173	20.06	20.33
40	423.8	81	78	769.2	80	77	165	20.01	20.25
50	426.2	82	80	771.6	81	78	160	19.95	20.21
60	428.6	84	82	774.0	82	80	151	19.88	20.16
70	431.0	85	83	776.4	85	82	143	19.84	20.07
80	433.4	85	84	778.8	86	83	134	19.82	20.03
90	435.8	86	86	781.2	87	85	127	19.77	19.97
100	438.2	87	86	783.6	88	87	124	19.75	19.92
110	440.6	87	87	786.0	88	88	121	19.73	19.90
120	443.0	88	88	788.4	88	88	120	19.70	19.90
130	445.4	88	88	790.8	89	88	119	19.70	19.88
140	447.8	88	88	793.2	89	89	117	19.70	19.86
150	450.1	89	89	795.6	89	89	116	18.84	19.86
160	452.5	89	89	798.0	88	89	116	19.66	19.88
170	454.9	89	89	800.4	88	88	115	19.66	19.90
180	457.4	88	89	802.8	87	88	113	20.50	19.92
190	459.8	89	89	805.1	87	88	114	19.66	19.09
193	460.6	88	89	805.9	87	87	113	21.87	22.15

Proportional Rate Calculations

Stack area 155

LEA Formulas from PR5G)

		0.1963	Manufacturer:		Morso			
W	moisture (% wet):	17.02	Model:		3600			
Load Weight (lbs wet):		15.61	Date:		8/9/01			
Burn Rate (Dry kg/hr):		1.827	Run:		4			
Final Temperature (DGM #1) Degrees Rankin:			544.405					
Final Temperature (DGM #2) Degrees Rankin:			543.810					
Final Tunnel Temperature Degrees Rankin:			592.381					
Final Tunnel Velocity (feet per second):			14.0166304					
Standardized Tunnel Flow (dscfm):			136.767302					
		Average	Average			#1	#2	
		Inlet +	Inlet +			dDGM	dDGM	
		Outlet	Outlet			Vol. Std.	Vol. Std.	
Tunnel	Tunnel	Temp.	Temp.					
Velocity	Velocity	Meter 1	Meter 2	PR1	PR2	(ft3)	(ft3)	Time
0.040	13.987	534.0	532.5					0
0.040	14.246	535.5	534.5	103.28	103.60	2.338	2.367	10
0.040	14.339	536.5	535.0	99.44	99.84	2.237	2.266	20
0.039	14.318	538.0	536.5	105.97	106.40	2.327	2.358	30
0.040	14.408	539.5	538.5	103.69	104.00	2.321	2.349	40
0.040	14.351	541.0	539.5	102.99	103.39	2.315	2.345	50
0.040	14.246	543.0	541.0	101.86	102.36	2.306	2.338	60
0.040	14.153	544.0	543.5	101.00	101.22	2.302	2.328	70
0.040	14.047	544.5	544.5	100.15	100.27	2.300	2.323	80
0.040	13.964	546.0	546.0	99.29	99.41	2.293	2.317	90
0.040	13.928	546.5	547.5	98.94	98.88	2.291	2.311	100
0.040	13.892	547.0	548.0	98.60	98.54	2.289	2.308	110
0.040	13.880	548.0	548.0	98.34	98.45	2.285	2.308	120
0.040	13.868	548.0	548.5	98.25	98.28	2.285	2.306	130
0.041	14.016	548.0	549.0	96.88	96.82	2.285	2.304	140
0.041	14.004	549.0	549.0	92.59	96.73	2.186	2.304	150
0.038	13.482	549.0	548.5	100.36	100.57	2.281	2.306	160
0.040	13.820	549.0	548.0	97.73	98.03	2.281	2.308	170
0.040	13.796	548.5	547.5	101.72	97.95	2.378	2.311	180
0.040	13.808	549.0	547.5	97.65	93.95	2.281	2.214	190
0.040	13.796	548.5	547.0	108.50	108.93	0.761	0.771	193

APPENDIX D

Intertek Testing Services

Warnock Hersey
Middleton, Wisconsin

Post Test Dry Gas Meter Calibration Data

Manufacturer: Morso Model: 3600 Job Number: J20049092 Date: 8/13/01 Tech: WK
 Barometric Press: 29.13 Calibration Factors: DGM#1: 1.0206 DGM#2: 1.0311 Std. Meter DGM#3: 1.0523

Std Meter # 3

Trial No.	Press Drop	Initial Ft. ³	Final Ft. ³	Change Ft. ³	Temp °F	Std. Ft. ³	Initial Ft. ³	Final Ft. ³	Change Ft. ³	Temp °F	Std Ft. ³	Cal Factor
1	1.6	586.769	589.12	2.3510	70	2.3995	471.938	474.365	2.4270	73	2.3890	1.0044
2	1.6	589.12	591.479	2.3590	70	2.4077	474.365	476.808	2.4430	73	2.4047	1.0012
3	1.6	591.479	593.821	2.3420	70	2.3904	476.808	479.228	2.4200	73.5	2.3798	1.0044
Average:												1.0034

System # 1

Previous Cal Factor: 1.0206 / Avg. Cal. Factor: 1.0034 divided by Previous Cal Factor: 1.0206 equals 1.6890 Percent Deviation

Std Meter #3

Trial No.	Press Drop	Initial Ft. ³	Final Ft. ³	Change Ft. ³	Temp °F	Std. Ft. ³	Initial Ft. ³	Final Ft. ³	Change Ft. ³	Temp °F	Std Ft. ³	Cal Factor
1	1.6	579.466	581.835	2.3690	69.5	2.4202	810.118	812.539	2.4210	71	2.4167	1.0015
2	1.6	581.835	584.253	2.4180	70	2.4679	812.539	815.009	2.4700	71	2.4656	1.0010
3	1.6	584.253	586.643	2.3900	70	2.4394	815.009	817.456	2.4470	71.5	2.4403	0.9996
Average:												1.0007

Previous Cal Factor: 1.0311 / Avg. Cal. Factor: 1.000679 divided by Previous Cal Factor: 1.0311 equals 2.95030 Percent Deviation

APPENDIX E

Manufacturer: Morso
 Project No: J20049092, 3005306
 Model: 3600
 Date: 08/13/01

	CO		CO2		O2	
	Actual	Should be	Actual	Should be	Actual	Should be
Zero Gas	0	0	0	0	0	0
Span Gas	9.96	9.96	24.65	24.65	20.93	20.93
Cal GAS #1 Deviation	0.94	0.99 5.05%	9.66	9.99 3.30%	10.24	10.2 0.39%
Cal GAS #2 Deviation	2.48	2.489 0.36%	5.83	6.086 4.21%	5.39	5.2 3.65%
Cal GAS #3 Deviation	7.74	7.68 0.78%	19.37	19.86 2.47%	17.44	17.16 1.63%
Average Deviation		2.06%		3.33%		1.89%

EQUIPMENT	MANUFACTURER	MODEL	INVEN #	MEASUREMENT UNCERTAINTY
CO analyzer	Horiba	PIR 2000	9	± 5 ppm, 95% CL
CO ₂ analyzer	Horiba	PIR 2000	10	± 0.5%, 95% CL
O ₂ analyzer	Beckman	755R	11	± 0.5%, 95% CL
Dry gas meter	Rockwell	T-110	12	± 0.1 ft ³ /hr, 95% CL
Dry gas meter	Rockwell	T-110	13	± 0.1 ft ³ /hr, 95% CL
Anemometer	Davis	1800	442	± 2 % of reading
Manometer Inclined 0-1 inch	Dwyer	125-AV	22	± 0.01-in
Manometer Inclined 0- 10inch	Dwyer	400	24	±0.02"
Barometer 35" Mercury	Princo	Nova 469	437	.01"
Magnehelic (draft indicator)	Dwyer	2000-00C	554	±2% of FS = 0.005"
Scale	Toledo Masstron	ML222	25	±0.1 lbs.
Readout	WeighTronix	WI110	259	±0.1 lbs
Scale	NCI	3220	6	± 0.1-lb
Readout	GSE	450	8	± 0.1-lb
Analytical balance	Ohaus	G-110	28	±0.0005 grams
Audit weights	Ainsworth	4254S	29	Class S
Moisture Meter	Delmhorst	RC-1C	49	±1%-0-20 & ± 2% > 20
Type K T/C wire	Omega		500	± 2°F, 95% CL
Type K meter	Omega	199	54	± 2°F
Temp/RH/DP indicator	Dickson	TH300	639	± 1.8 (F), +/- 2% (RH)

ITS EQUIPMENT CALIBRATION RECORD

ITS# #9, 10, 11

DESCRIPTION: CO, CO₂, O₂ Analyzers

MANUFACTURER: Horiba + Beckman

SERIAL #: CO PIR-2000 #9 MODEL: CO₂ PIR-2000 #10 O₂ 755 #11
6110019 607023 1001926

EQUIPMENT LOCATION: _____

PURPOSE & ACCURACY: ± 1% of FS

CALIBRATION SPECIFICATIONS/INTERVAL: 6 mos.

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
7/16/99	1/16/00	In House	RA	
1/17/00	7/17/00	"	RA	
7/6/00	1/06/01	"	RA	OK
6/1/01	11/1/01	"	BK	

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

CALIBRATION DATE: 6/1/01
REVIEWED BY: AJF

CALIBRATED BY: WK

DESCRIPTION: Gas Analyzers

Located in EE console

SERIAL NUMBER: 6110019 CO

WHI INVENTORY #009

SERIAL NUMBER: 607023 CO₂

WHI INVENTORY #010

SERIAL NUMBER: 1001926 O₂

WHI INVENTORY #011

GAS ANALYZER RESPONSE TIME

CALIBRATION GAS USED

	CO	CO ₂	O ₂
Analysis:	<u>9.94</u>	<u>9.99</u>	<u>10.2</u>
Meter Reading			
Direct Connection:	<u>9.8</u>	<u>9.63</u>	<u>10.17</u>
90% of Analysis:	<u>8.8</u>	<u>8.67</u>	<u>9.15</u>

- Meters set with zero gas and span gas.
- Calibration gas routed through impinger train.
- Zero gas was introduced after each time trial to return meter to zero.

CO	90% (<u>8.8</u>)	Trial	Time
		1.	<u>5</u> sec
		2.	<u>5</u> sec
		3.	<u>6</u> sec
		Average	<u>5.3</u> sec

100% (<u>9.8</u>)	Trial	Time
	1.	<u>7</u> sec
	2.	<u>7</u> sec
	3.	<u>9</u> sec
	Average	<u>7.6</u> sec

CO ₂	90% (<u>8.67</u>)	Trial	Time
		1.	<u>6</u> sec
		2.	<u>5</u> sec
		3.	<u>4</u> sec
		Average	<u>5</u> sec

100% (<u>9.63</u>)	Trial	Time
	1.	<u>18</u> sec
	2.	<u>15</u> sec
	3.	<u>15</u> sec
	Average	<u>16</u> sec

O ₂	90% (<u>9.15</u>)	Trial	Time
		1.	<u>11</u> sec
		2.	<u>12</u> sec
		3.	<u>12</u> sec
		Average	<u>11.7</u> sec

100% (<u>10.17</u>)	Trial	Time
	1.	<u>14</u> sec
	2.	<u>16</u> sec
	3.	<u>15</u> sec
	Average	<u>15</u> sec

ITS EQUIPMENT CALIBRATION RECORD

ITS# 12, 13, 14

DESCRIPTION: Dry Gas Meter Calibration

MANUFACTURER: ① Rockwell T-110 #26866 #12

SERIAL #: ② Rockwell T-110 #26873 #13
③ Rockwell T-110 #27002 #14 MODEL:

EQUIPMENT LOCATION: E + E


PURPOSE & ACCURACY: ± .05 CFH

CALIBRATION SPECIFICATIONS/INTERVAL: 6 months

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
7/06/00	1/06/01	In-house	RA	OK
1/31/01	7/31/01	"	AL	OK
7/30/01	1/30/02	"	WL	ok

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR



Certificate of Calibration

1000055507

Page 2 of 2

Calibration Standards

<u>NIST Traceable #</u>	<u>Instrument ID#</u>	<u>Description</u>	<u>Model</u>	<u>Calibration Date</u>	<u>Date Due</u>
1000026619	01-0098	Stopwatch	810033	20 APR 2000	20 APR 2001
1000027795	01-0287	Resonant Sensor Barometer	DPI 141	27 APR 2000	27 APR 2001
1000051990	01-0818	Humidity & Temperature Meter	HM34C	01 MAR 2001	01 MAR 2002
1000052381	01-0178	Thermistor Thermometer	600-8525	22 MAR 2001	22 MAR 2002
1000055291	01-0103	Electronic Manometer	Medm 500	05 APR 2001	05 APR 2002

ITS EQUIPMENT CALIBRATION RECORD

ITS# 22

DESCRIPTION: Manometer 0-1" Inclined

MANUFACTURER: _____

SERIAL #: 882 MODEL: 125 AV

EQUIPMENT LOCATION: Emission Lab - E+E

PURPOSE & ACCURACY: ± 1% of FS (0.01 in)

CALIBRATION SPECIFICATIONS/INTERVAL: 6 mos. Yearly

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
3/17/94	9/17/94	Inhouse	WK	
10/1/94	4/1/95	"	WK	
4/11/95	10/11/95	"	RA	
10/16/95	4/16/96	"	RA	
4/19/96	10/19/96	"	WK	
10/9/96	4/9/97	"	RB	
5/14/97	11/14/97	"	RA	
12/16/97	6/16/98	"	RA	
8/12/98	2/12/99	"	RA	
1-22-99	7-22-99	"	RA	
7/16/99	1/16/00	"	RA	
1/14/00	7/14/00	"	RA	
2/13/01	2/13/02	"	AL	0.0015-in

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

✓

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

CALIBRATION DATE: 2/12/01
REVIEWED BY: [Signature]

CALIBRATED BY: AWK

DESCRIPTION: Manometer Inclined 0-1"

Located in EE lab

MODEL: 125 AV

SERIAL NUMBER: 8 82

WHI INVENTORY #022

MICROTECTOR	MANOMETER	DEVIATION IN.
.379	.757	0.001
.287	.576	0.002
.225	.454	0.004
.131	.260	0.002
.054	.105	0.003
.021	.042	0
.004	.008	0
.442	.886	0.002
.335	.670	0

AVERAGE DEVIATION = 0.0015 INCHES

Note: Microtector reading is exactly $\frac{1}{2}$ of the manometer reading

ITS EQUIPMENT CALIBRATION RECORD

ITS No. 024

DESCRIPTION: Manometer 0-10"

MANUFACTURER: Dwyer

SERIAL No: 400 MODEL: _____

EQUIPMENT LOCATION: _____

PURPOSE & ACCURACY: ±.02 in from 0-1" ±.1 from 1-10"

CALIBRATION SPECIFICATIONS/INTERVAL: 6 months

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST
5/15/00	5/15/01	in-house	W/K	ok
8/20/01	2/20/01	" "	AL	ok

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

CALIBRATION DATE: 8/20/01
 REVIEWED BY: [Signature]
 DESCRIPTION: Manometer Inclined 0-10"

CALIBRATED BY: [Signature]
 MODEL: Dwyer

SERIAL NUMBER: 400

WHI INVENTORY #024

Item used to calibrate: Microtector WHI No. 103

MICROTECTOR	MICROTECTOR MANOMETER (in. w.c.)	<i>manometer</i> ACTUAL	<i>Difference</i> DEVIATION %
0.138	0.276	0.270	-.006
0.277	0.554	0.540	-.014
0.313	0.626	0.620	-.006
0.428	0.856	0.840	-.016
0.626	1.252	1.250	-.002
0.939	1.878	1.870	-.008

AVERAGE DEVIATION = ^{Difference} .009 in. w.c.

STD DEV =
$$\sqrt{\frac{n \sum x^2 - (\sum x)^2}{n(n-1)}} = .005 \text{ in. w.c.}$$

TRACEABILITY TO
NATIONAL INSTITUTE OF STANDARDS & TECHNOLOGY

All PRINCO Barometers, Model Series 453 and 469, have been tested in comparison with the Fortin type mercurial barometer, serial no. W12655, which was calibrated on May 3rd 1994 against a Hass primary standard Type MS-3 Micrometer Standard Barometer, serial number 2510, certified by the National Institute of Standards & Technology (NIST Identification No. P-7485).

Barometer scales are positioned to read correctly with no correction for capillary depression. Compensation has been made for the average condition of capillary by tapping the instrument slightly before each reading to bring the meniscus height to its average value. The length of the scale of this barometer has a zero correction at 62°F on the English side and 0°C on the metric side. The density of the mercury is standard at 0°C. To correct for temperature of both density and scale length, use the combination temperature correction table as published in National Weather Service, Circular F. (See PRINCO Instruction Manual). To correct for gravity use the gravity correction tables in the same publication. No gravity correction is needed at 45° latitude.

This barometer is accurate to ± 0.3 mb, 0.2 mm, or 0.01 inch of mercury when carefully set and read, and after temperature and gravity corrections have been applied. The thermometer on the barometer is accurate to $\pm 0.5^\circ\text{C}$.

The National Institute of Standards & Technology does not state any recommendations for a barometer to be re-certified.

If the barometer is not abused in any way it should never go out of calibration.

Princo Instruments, Inc. recommends that you return the barometer every 3 to 5 years.

ITS EQUIPMENT CALIBRATION RECORD

ITS# 554

DESCRIPTION: Magnehelic

MANUFACTURER: Dwyer 2000-00

SERIAL #: R990430MP21 MODEL: 2000-00

EQUIPMENT LOCATION: E+E

PURPOSE & ACCURACY: ± 0.005 in. NL

CALIBRATION SPECIFICATIONS/INTERVAL: 6 mo.

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
8-10-99	2-10-00	In-house	RA	
1-14-00	7-14-00	"	"	
5/15/00	11/15/00	"	RA	
2/2/01	8/2/01	"	AL	0.0028"
7/29/01	1/29/02	"	WK	ave .003 STDEV .002

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

1/2

CALIBRATION DATE: 7/29/01
 REVIEWED BY: [Signature]

CALIBRATED BY: [Signature]

DESCRIPTION: Magnehelic

MODEL: Dwyer 2000-00

SERIAL NUMBER: R990430MP21

WHI INVENTORY #554

Located in E&E Console

USING: MICROTECTOR #103

wrote down averages

MICROTECTOR	MICROTECTOR ACTUAL	MAGNEHELIC	DEVIATION
.111	.222	.222	0.0
.086	.172	.175	2.1%
.077	.142	.144	2.9%
.034	.068	.072	4.0%
.054	.108	.112	4.5%
.048	.096	.101	2.1%
.021	.042	.046	3.1%
.012	.024	.025	3.7%

AVERAGE DEVIATION = 3.73

~~std dev = NA~~

See page 2/2 For correct std. deviation & differences.

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

CALIBRATION DATE: _____
REVIEWED BY: _____

CALIBRATED BY: _____

DESCRIPTION: Magnehelic

MODEL: Dwyer 2000-00

SERIAL NUMBER: R990430MP21

WHI INVENTORY #554

Located in E&E Console

USING: MICROTECTOR #103

MICROTECTOR (in.)	MICROTECTOR ACTUAL (in. W.C.)	MAGNEHELIC (in. W.C.)	Difference (in. W.C.)
			.000
			.003
			.002
			.004
			.004
			.005
			.004
			.001

AVERAGE DIFFERENCE = .003 in. W.C. *MP 8/20/01*

STANDARD DEVIATION OF DIFFERENCE = .002 in. W.C. *MP 8/20/01*

ITS EQUIPMENT CALIBRATION RECORD

ITS# ^{6, 8, 25,} 8 * 259

DESCRIPTION: Weigh

MANUFACTURER: Tronix

SERIAL #: ⁽⁶⁾(8)6800082 ⁽²⁵⁾(259)03082 MODEL: ⁽⁸⁾NCI 5780 ⁽²⁵⁹⁾WI 110

EQUIPMENT LOCATION: _____

PURPOSE & ACCURACY: .1 16

CALIBRATION SPECIFICATIONS/INTERVAL: 6 Months

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
8-11-98	2-11-99	In-house	RA	
5-19-98	11-19-98	Cream City	-	
11-98	5-99	CREAM CITY	JEFF	
5/21/99	11/21/99	" "	CC	
11/99	5/00	Cream City	Jeff	
3/00	9/00	" "	"	Big scale only
9/27/00	3/27/01			
4/12/01	10/12/01	" "		OK

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

6 ÷ 8

Certificate of Calibration CREAM CITY SCALE, CO INC.

2009 S. Stoughton Rd., Madison, WI 53716 (608) 222-9427 or (888) 934-4448

CUSTOMER ITS
ADDRESS _____
CITY, STATE & ZIP Madison

DATE 9/12/01

INDICATOR MFG. <u>CSE</u>	CAPACITY <u>100LB</u>	CLASS <u>III</u>
MODEL <u>950</u>	DIVISIONS <u>101</u>	ACCURACY <u>1/10</u>
SERIAL NO. <u>101722</u>	LOCATION <u>Fire Dept</u>	TOLERANCES USED _____
BASE MFG. <u>NIT</u>	I.D. # <u>6, 8</u>	<u>17549</u>
MODEL <u>320</u>	CALIBRATION INTERVAL <u>Same Annual</u>	
SERIAL NO. <u>79043</u>	NEXT CALIBRATION DUE <u>10/01</u>	

SHIFT TEST

FLOOR SCALE

BENCH SCALE

1	2
4	3

2	
1	3
4	

SECTION	LOAD	READING	ERROR
1	50	50	—
2	50	50	—
3	50	50	—
4	50	50	—

IS SHIFT TEST WITHIN TOLERANCE () YES () NO () ADJUSTED

INCREASING LOAD TEST

PRELIMINARY LOAD TEST

FINAL LOAD TEST AFTER ADJUSTMENT

SUBSTITUTION WEIGHT	TEST WEIGHT	READING	ERROR
	5	5	—
	10	10	—
	25	25	—
	50	50	—
	75	75	—
	100	100	—

SUBSTITUTION WEIGHT	TEST WEIGHT	READING	ERROR

IS SCALE WITHIN MAINTENANCE TOLERANCE (X) Y () N
(if no, see final load test)

IS SCALE WITHIN ACCEPTANCE TOLERANCE () Y () N

WAS SCALE WITHIN CUSTOMERS REQUIRED ACCURACY? (X) Y () N

COMMENTS:

TEST WEIGHT CLASSIFICATION F
 NIST TRACEABILITY CERTIFICATE NO. W00-223
 LIST TEST WEIGHTS USED BY SERIAL NO. 6, 7, 5, 71, 72

SCALES WERE CALIBRATED WITH THE CERTIFIED TEST WEIGHTS, ADJUSTMENTS TO RESTORE AND/OR MAINTAIN THE ACCURACY OF THE SCALE CONFORM TO THE TOLERANCES ESTABLISHED BY THE NATIONAL INSTITUTE OF STANDARDS & TECHNOLOGY AS SPECIFIED IN HANDBOOK 44

TECHNICIAN 

#. 25, 259

Certificate of Calibration CREAM CITY SCALE, CO INC.

2009 S. Stoughton Rd., Madison, WI 53716 (608) 222-9427 or (888) 934-4448

CUSTOMER ITS
ADDRESS _____
CITY, STATE & ZIP Madison WI

DATE 9/14/14

INDICATOR MFG. <u>Weightronic</u>	CAPACITY <u>100</u>	CLASS <u>III</u>
MODEL <u>W3110</u>	DIVISIONS <u>1</u>	ACCURACY <u>1%</u>
SERIAL NO. <u>30821</u>	LOCATION <u>Fine Phase Dept</u>	TOLERANCES USED _____
BASE MFG. <u>Pledo</u>	I.D. # <u>25+259</u>	<u>HB94</u>
MODEL <u>Dormant</u>	CALIBRATION INTERVAL _____	<u>Semi Annual</u>
SERIAL NO. <u>N/A</u>	NEXT CALIBRATION DUE _____	<u>10/1</u>

SHIFT TEST

FLOOR SCALE

1	2
4	3

BENCH SCALE

2	3
1	4

SECTION	LOAD	READING	ERROR
1	250	250.2	+0.2
2	250	250	—
3	250	250	—
4	250	250	—

IS SHIFT TEST WITHIN TOLERANCE () YES () NO () ADJUSTED

INCREASING LOAD TEST

PRELIMINARY LOAD TEST

SUBSTITUTION WEIGHT	TEST WEIGHT	READING	ERROR
	100	100	—
	200	200	—
	300	300.1	+0.1
	400	400.1	+0.1
	500	500.1	+0.1

FINAL LOAD TEST AFTER ADJUSTMENT

SUBSTITUTION WEIGHT	TEST WEIGHT	READING	ERROR
	100	100	—
	200	200	—
	300	300	—
	400	400	—
	500	500	—

IS SCALE WITHIN MAINTENANCE TOLERANCE (Y () N
(if no, see final load test)

IS SCALE WITHIN ACCEPTANCE TOLERANCE (Y () N

WAS SCALE WITHIN CUSTOMERS REQUIRED ACCURACY? (Y () N

COMMENTS:

TEST WEIGHT CLASSIFICATION F
 NIST TRACEABILITY CERTIFICATE NO. 100-227
 LIST TEST WEIGHTS USED BY SERIAL NO. 71-20

SCALES WERE CALIBRATED WITH THE CERTIFIED TEST WEIGHTS, ADJUSTMENTS TO RESTORE AND/OR MAINTAIN THE ACCURACY OF THE SCALE CONFORM TO THE TOLERANCES ESTABLISHED BY THE NATIONAL INSTITUTE OF STANDARDS & TECHNOLOGY AS SPECIFIED IN HANDBOOK 44.

TECHNICIAN [Signature]

ITS EQUIPMENT CALIBRATION RECORD

ITS# 28

DESCRIPTION: Analytical Balance

MANUFACTURER: Ohaus

SERIAL #: 5336 MODEL: G110

EQUIPMENT LOCATION: E & E

PURPOSE & ACCURACY: ±.0005 g

CALIBRATION SPECIFICATIONS/INTERVAL: 6 months

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
6-2-97	12-2-97	In-house	RA	
6/25/98	12-25-98	"	WK	
12/11/98	6/11/99	"	RA	
6/1/99	12/1/99	"	RA	
1/14/00	7/14/00	"	RA	
7/6/00	1/6/01	"	RA	OK
2/1/01	8/1/01	"	AL	0.00019
7/30/01	1/30/01	"	WK	.00018 ave dif .00014 std dev

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

CALIBRATION DATE: 7/30/01

CALIBRATED BY: ML

REVIEWED BY: ~~Ma~~ ~~Pa~~

DESCRIPTION: Analytical Balance

MODEL: (Ohaus) Galaxy 110

SERIAL NUMBER: 5336

WHI INVENTORY #028

USING: Ainsworth Class S Weight WHI #29

WEIGHT	MEASURED	DIFFERENCE (g)
2 mg	<i>BROKEN WEIGHT</i>	
5 mg	0.0051 g	0.0001
10 mg	0.0104	0.0004
20 mg	0.0202	0.0002
50 mg	0.0499	0.0001
100 mg	0.1001	0.0001
1 g	0.9999	0.0001
20 g	20.0000	- 0 -
50 g	49.9996	00.0004
100 g	100.0002	000.0002

Average Difference = 0.0001778 grams

Standard Deviation = ,00014 grams *MP*



WARNOCK HERSEY INTERNATIONAL, INC.
 MIDDLETON, WISCONSIN 53562
AINSWORTH
 PRODUCTS, INC.

2050 South Pecos Street,
 Denver CO 80223
 (303) 934-2276

CLASS S WEIGHT SET

RANGE: 100 GRAMS TO 1 GRAMS
 MILLIGRAMS

CATALOG NO. 4254-S SERIAL NO. 39392

	CONSTRUCTION	MATERIAL	DENSITY g/cm ³ @ 20° C
GRAM WTS.	<input type="checkbox"/> 1-piece	<input checked="" type="checkbox"/> Naval Brass, rhodium plated	8.40
	<input checked="" type="checkbox"/> 2-piece screwknob	<input type="checkbox"/> Brunton* Metal	7.89
		<input type="checkbox"/> Stainless Steel	7.85
MILLIGRAM WTS. 30 mg & larger	<input checked="" type="checkbox"/> 1-piece	<input checked="" type="checkbox"/> Tantalum	16.6
MILLIGRAM WTS. 20 mg & smaller	<input checked="" type="checkbox"/> 1-piece	<input checked="" type="checkbox"/> Aluminum	2.7

Naval Brass average composition—60% copper, 39.25% zinc, .75% tin. ASM #4612B.

Brunton* Metal average composition—25.5% chromium, 21% nickel, 2% manganese,
 1.5% silicon, .25% sulphur, phosphorus, carbon.

Stainless Steel average composition—18% chromium, 9% nickel, 1% manganese
 .5% silicon, .1% carbon, AISI #303

Rhodium plated weights have an undercoat of electrolytic nickel plate.

All Ainsworth weights meet or exceed the National Bureau of Standards Handbook 77, Volume III, issued February 1, 1966, Concerning: Material (hardness, corrosion resistance, magnetic properties, density, adjusting materials); Design (Shape, dimensions, number of pieces); Surface (irregularities, porosity, surface finish); Denominations; Markings; Constancy under variations of humidity; Packaging.

We can supply new class, S, and S-1 Sets with any range between 100g and 1 mg. New weights or weight sets and even those you are now using may be calibrated and certified by Ainsworth Products, Inc., Standards Laboratory to show traceability to National Bureau of Standards.

Made by AINSWORTH PRODUCTS, INC.
 2050 South Pecos St., Denver, CO 80223

WHI #029

ITS EQUIPMENT CALIBRATION RECORD

ITS# 49

DESCRIPTION: Moisture Meter

MANUFACTURER: Delmhorst

SERIAL #: 14356 MODEL: RC-1C AND CAL. Block

EQUIPMENT LOCATION: E & E

PURPOSE & ACCURACY: ±1% -0-20 + ±2% > 20

CALIBRATION SPECIFICATIONS/INTERVAL: _____

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
8/20/01	2/20/02	In-house	AL	OK

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

LETTER OF CERTIFICATION

October 12, 2000

Intertek Testing Service
8431 Murphy Dr.
Middleton, WI 53562

Gentlemen:

Subject: Moisture Content Standard Model MCS-1 Serial No. 101200

This is to certify that the primary calibration - electrical resistance - of the Delmhorst Moisture Meters has been tested on equipment whose accuracy is certified by the:


General Radio Model No. 1644-A S/N 2526
Keithley Model No. 97, S/N 283483.

The calibration of these instruments, certified by Ballantine Laboratories, Inc. with Report No. D19016 dated December 9, 1999, is traceable to the NIST.

The MCS-1 (Moisture Content Standard) is an external means to check the Delmhorst Moisture Meters for wood at two points - 12 % and 22% on the Douglas Fir, 4 Pin mode; the two points will yield readings of 12.7% and 23.6% if the meters are set on the Douglas Fir, 70°F, 2 Pin mode. The analog meters in their standard form are always set at Douglas Fir 70°F 4 Pin mode. The resistance values at said points, i.e., 120 Megohms and 1.1 Megohms verified with the same equipment as above, are within $\pm 10\%$ of the above values.

The analog Moisture Meters, checked with the "MCS-1" Standard, should read within (\pm) one division on the dial at the point(s) checked; the digital Moisture Meters should read within ± 0.5 M.C. of the indicated values.

Sincerely,



John C. Laurenzi
V.P. Manufacturing

JCL: dm

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

CALIBRATION DATE: 8/20/01
REVIEWED BY: [Signature]

CALIBRATED BY: [Signature]

DESCRIPTION: Delmhorst moisture meter calibration block MODEL : MSC-1

SERIAL No. 101200

WHI INVENTORY # 049

Calibrated using Fluke multimeter WHI No. 109

Calibration block position	Desired reading	Actual reading	Accepted range
12%	8.33 nS	8.72	7.50 - 9.16 nS
22%	1.1 Megohms	1.107	0.99 - 1.21 MΩ

ITS EQUIPMENT CALIBRATION RECORD

ITS# FE 500

DESCRIPTION: THERMOCOUPLES

MANUFACTURER: OMEGA

SERIAL #: _____ MODEL: _____

EQUIPMENT LOCATION: E+E LAB

PURPOSE & ACCURACY: _____ 6 mos.

CALIBRATION SPECIFICATIONS/INTERVAL: BOILING WATER ICE BATH 6 MONTHS

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
6-4-97	12-4-97	IN HOUSE	RA	
12-12-97	6-12-98	"	RA	
6-26/98	12-26-98	"	WK	
12-11-98	6-11-99	"	RA	
6/1/99	12/1/99	"	RA	
5/30/00	11/30/00	"	AL	± 2°F
1/24/01	7/24/01	"	AL	± 2°F (within)
7/29/01	1/29/02	"	WK	OK

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

ITS Intertek Testing Services NA Inc.

Middleton, Wisconsin

CALIBRATION DATE: 7/29/01
REVIEWED BY: MP

CALIBRATED BY: RK

Description: Thermocouple wire
No. 500

WHI inventory

ROOM TEMPERATURE 70

Thermocouple number and location	Thermocouple immersed in boiling water	Thermocouple immersed in ice
1) Flue Gas	212	33
2) Room Temperature	211	32
3) Dry Bulb (in tunnel)	211	32
4) Wet Bulb (in tunnel)	211	32
5) Unit Top	211	33
6) Unit Back	211	33
7) Unit Right Side	211	32
8) Unit Left Side	211	32
9) Unit Bottom	211	33
10) Catalyst Downstream	211	32
11) Catalyst Center	211	33
12)	211	33
13)	211	33
14)	212	33
15)	211	33
16)	211	33
17) DGM (in)	211	33
18) DGM (out)	211	33
19) Filter (1)	211	33
20) DGM (in)	211	33
21) DGM (out)	211	33
22) Filter (2)	211	33

ITS EQUIPMENT CALIBRATION RECORD

ITS# 54

DESCRIPTION: Digital Type K Thermocouple Meter

MANUFACTURER: Omega

SERIAL #: 21662 MODEL: 199-KF-A-X

EQUIPMENT LOCATION: E+E

PURPOSE & ACCURACY: ~~$\pm 2^\circ F$~~ $\pm 2^\circ F$ (WAA)

CALIBRATION SPECIFICATIONS/INTERVAL: 6 months

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST.
12/11/98	6/11/99	On house	RA	
6/11/99	12/11/99	"	RA	
1/14/00	7/14/00	"	RA	
5/24/00	11/24/00	Cal Lab		Cal Lab
11/21/00	5/21/00	Cal Lab		OK
5/8/01	11/8/01	Cal Lab		

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

3 5-K North 126th Street
Brookfield, WI 53005
262-790-1916
262-790-1949 FAX
@callabco.com
www.callabco.com



CERTIFICATE OF CALIBRATION
Certificate # 1062557



Customer

Intertek Testing Services
8431 Murphy Dr.
Middleton, WI 53562

Instrument

Manufacturer: Omega
Model: 199
Description: Digital Temp. Meter
Serial #: 21662
ID #: 000054

Calibration Information

Technician: Mark Adams
Temperature: 71°F (21.7°C)
Humidity: 39%RH

Calibrated On-Site

Cal Interval: 6 months
Cal Date: 05/08/2001
Due Date: 11/08/2001

Received Condition: Fully operational and within tolerance

Work Performed: No adjustments required and calibrated to manufacturers specifications using manufacturers procedure

Calibration Standards Used

Cal:10/18/2000 Due:10/18/2001 ID#1334 Fluke 5500A/3 Calibrator Serial#6535009



This instrument was calibrated with a minimum 4:1 TUR/TAR unless otherwise stated. These represent best uncertainties. Actual uncertainties are available upon request.

Best Measurement Uncertainty

Temperature $\pm 0.2^{\circ}\text{C}$

Reviewed and approved by Mike Booth Quality Team Member - Issue Date: 05/09/2001

All Functions/Ranges were checked unless otherwise stated.

This Certificate may not be reproduced except in its entirety without the written approval of CAL LAB Co., Inc.

This Report Certifies that all Calibration Standards used in the test is traceable to NIST, and the test was performed in accordance with ANSI/NCSL Z540-1-1994 (ISO/IEC 17025-1999).

ITS EQUIPMENT CALIBRATION RECORD

ITS# 639

DESCRIPTION: Temp/Rel. Humid/Dew Point Tester

MANUFACTURER: Dickson

SERIAL #: 00050593 MODEL: TH 300

EQUIPMENT LOCATION: E-E

PURPOSE & ACCURACY: ± 1.8°F, ± 2% RH

CALIBRATION SPECIFICATIONS/INTERVAL: 6 mo.

CALIBRATION DATE	NEXT CALIBRATION	CALIBRATION AGENCY	CAL. BY	RESULTS/ADJUST
11/21/00	5/21/00	Cal Lab		OK
5/8/01	11/8/01	" "		OK

MAINTENANCE AND REPAIR:

DATE OUT OF SERVICE	DATE BACK IN SERVICE	REPAIR AGENCY	DESCRIPTION OF REPAIR

95-K North 126th Street
Brookfield, WI 53005
262-790-1916
262-790-1949 FAX
@callabco.com
www.callabco.com



CERTIFICATE OF CALIBRATION
Certificate # 1062543



Customer

Intertek Testing Services
8431 Murphy Dr.
Middleton, WI 53562

Instrument

Manufacturer: Dickson
Model: TH300
Description: Temp/Humidity Indicator
Serial #: 00050593
ID #: 000639

Calibration Information

Technician: Mark Adams
Temperature: 71°F (21.7°C)
Humidity: 39%RH
Calibrated On-Site
Cal Interval: 6 months
Cal Date: 05/08/2001
Due Date: 11/08/2001
Received Condition: Fully operational and within tolerance
Work Performed: No adjustments required and calibrated to manufacturers specifications using CAL LAB procedure #30

Calibration Standards Used

Cal:04/27/2001 Due:04/30/2003 ID#1385 Cole Parmer 3312-20 Psychrometer F Serial#NONE
Cal:01/16/2001 Due:01/31/2002 ID#1390 Fluke 743B Process Calibrator Serial#7005629
Cal:09/28/2000 Due:09/30/2001 ID#1589 Thermocouple Prod. 400-T-12 T Thermocouple Probe Serial#NONE



This instrument was calibrated with a minimum 4:1 TUR/TAR unless otherwise stated. These represent best uncertainties.
Actual uncertainties are available upon request.

Best Measurement Uncertainty

Humidity ±3%


Temperature ±0.2°C

Reviewed and approved by Mike Beebe Quality Team Member - Issue Date: 05/09/2001

All Functions/Ranges were checked unless otherwise stated.

*This Certificate may not be reproduced except in its entirety without the written approval of CAL LAB Co., Inc.
This Report Certifies that all Calibration Standards used in the test is traceable to NIST, and the test was performed in accordance with ANSI/NCSL Z540-1-1994 (ISO/IEC 17025-1999).*

APPENDIX F




A-A

3600-39 Airflow diagram - Sheet 1

Materiale:		-		Titel:		Konstr.:		KDU		Sign.:		Date:		17.08.01	
Vægt:		- kg.		Bearbejdes:		-		Airflow diagram		Frigivet:		-		-	
Overfladebeh.:		-		-		- m ²		Morsø 3600		Tegn.format:		A4			
Måltolerance:		Mål uden toleranceangivelse						morsø		Målforhold:		1:5			
Ruhedstolerance:								Byggeri og Industri		Varenr.:		-			
Værktøjsnr.:		-						Tegningsnr.:		3600-39					
Tegningstype:		Airflow diagram													

Denne tegning tilhører Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse




Navn:	Revisjonsnr.:	Sign.:	Dato:
Prosjekt:	CDU:	11/07/01	
Reservedelstegning			
Verktøy:	Figur:		
Overførbart:	Legemål:	A3	
Arkivert:	Skala:	1:10	
Revisjonsnr.:	Skisse:		
<small>Denne tegning er utarbeidet i AutoCAD og er ikke et uttrykk for Morsø AS' ansvar. Uttrykket er kun et uttrykk for Morsø AS' ansvar.</small>			

Keramab N.V.
 Havensteedlaan 4
 B - 9140 Temse
 Belgium
 Telephone +32(0)3 711.02.78
 Telefax +32(0)3 711.08.56

REFRACTORY FIBER PRODUCTS

Technical Datasheet

INSULFRAX® BLANKET



KERAMAB's latest addition to its fibres product range, **INSULFRAX®**, is a revolutionary breakthrough in insulating materials technology.

This new product is based on a calcium-magnesium-silica chemistry, giving excellent thermal and physical stability up to its operational limit of 1100°C.

INSULFRAX® products can be used in a wide range of applications as thermal insulation, particularly in Fire Protection and in Domestic Appliances.

General Characteristics

INSULFRAX® Blanket offers users a number of important advantages over other man-made mineral fibres:

- Excellent thermal and physical stability up to 1100°C
- Light weight, flexibility and exceptional acoustic absorption properties
- Improved tensile strength of **INSULFRAX®** Blanket due to our specialist manufacturing technology
- **INSULFRAX®** needle felted Blanket contains no organic binders

Chemical Analysis (wt.%)

SiO ₂	-	61.0 - 67.0
CaO	-	27.0 - 33.0
MgO	-	2.5 - 6.5
Al ₂ O ₃	-	< 1.0
Fe ₂ O ₃	-	< 0.6

Form A1-090
 Effective: 29051998/MJH,mvd
 Supersedes: 07041998/MJH/mvd
 All Rights Reserved

Price List No. III 016

The information, recommendations and opinions set forth herein are offered solely for your consideration, inquiry and verification, and are not, in part or total, to be construed as constituting a warranty or representation for which we assume legal responsibility. Nothing contained herein is to be interpreted as authorization to practice a patented invention without a license.

Page 1 of 2

9100010105100



Member of
the KERAMAB group

KERAMAB

REFRACTORY & CERAMIC INNOVATION

Keramab N.V.
 Haverhaidelezen 4
 B - 9140 Temse
 Belgium
 Telephone +32(0)3 711.02.78
 Telefax +32(0)3 711.06.55

REFRACTORY FIBER PRODUCTS

Technical Datasheet

Typical Applications

Domestic Appliances

- Boiler insulation
- Fire seals
- Storage heater insulation
- Wood-burning stove seals
- Domestic cooker insulation
- Chimney fill

Fire Protection

- Offshore rig accommodation modules
- Building expansion joints
- Column and beam wrap
- Fire door in fill

Typical Physical Properties					
Colour	-	Bluish-white			
Classification Temperature	-	1100°C			
Melting Point	-	>1330°C			
Fibre Diameter	-	3.2 microns (mean)			
Tensile Strength	-	> 35 kPa (128 kg/m ³)			
Thermal Conductivity Data, W/m ² K					
(based on CEN draft method ASTM C-201)	64 kg/m ³	96 kg/m ³	128 kg/m ³	160 kg/m ³	192 kg/m ³
200°C Mean Temperature	0.07	0.06	0.05	—	—
400°C Mean Temperature	0.10	0.09	0.08	0.07	0.06
600°C Mean Temperature	0.18	0.14	0.12	0.11	0.10
800°C Mean Temperature	0.27	0.22	0.18	0.16	0.15
Permanent Linear Shrinkage		1000°C	1100°C		
24 hour soak	< 2.0 %	< 4.0%			

Where appropriate Physical Properties and Thermal Conductivity Data measured according to ENV 1094-7:1994

Fire Test Data

INSULFRAX® Blanket is non-combustible in accordance with BS476:Pt4 and is approved for use against cellulosic and hydrocarbon fires and for dry wrapping of structural steel. Certification details can be supplied on request.

Form A1-050
 Effective: 29051998/NUH/mvd
 Supersedes: 07041998/NUH/mvd
 All Rights Reserved

Page 2 of 2


Price List No. 2 III 076

The information, recommendations and opinions set forth herein are offered solely for your consideration, inquiry and verification, and are not, in part or total, to be construed as constituting a warranty or representation for which we assume legal responsibility. Nothing contained herein is to be interpreted as authorization to practice a patented invention without a license.

CLASSIFIED



SKAMOLEX VIP-12 Vermiculite Block Insulation



Packing Colour Code:
GREEN/BLACK.

Product Data

SKAMOLEX VIP-12 is a Vermiculite based refractory block insulation of high bath resistance, characterized by good insulation value and very high mechanical strength.

Precision moulding ensures blocks of smooth, non-dusting surfaces and clean edges, and permits manufacture to close dimensional tolerances, i.e. ± 2.5 mm (0.10") on length and width, and ± 1.0 mm (0.04") on thickness.

Block Sizes

Metric:

1000 mm x 305 mm,

Thicknesses:

30 - 40 - 50 mm

610 mm x 305 mm,

Thicknesses:

25 - 30 - 40 - 50 - 60 - 75 mm

US/British:

36" x 12",

Thicknesses:

1 1/4" - 1 1/2" - 2"

24" x 12",

Thicknesses:

1" - 1 1/4" - 1 1/2" - 2" - 2 1/2" - 3"

Derivatives cut from standards are made to order

Grade: VIP-12

Temp. limit: 1150°C (2102°F)

The continuous efforts to improve energy efficiency of aluminium reduction cells have intensified demands for better heat insulation in pot cathodes.

Although a number of insulating products are available on the market, many smelters are still facing the problem of reducing the temperature of penetrating bath substances to solidifying point at a line between the carbon and the insulation layer, thus achieving a freezing of bath substances before they penetrate further into the more vulnerable bottom insulation.

With this end in view there is a need for a dense intermediate insulator, of a chemistry to resist bath attacks.

SKAMOLEX VIP-12 offers a perfect solution because it combines Vermiculite chemistry and good bath resistance with ample insulation and high strength.

Placed above the bottom insulation it will cause penetrating bath to stop and solidify, due to chemical reactions that transform the low-melting mixture of sodium fluoride and aluminium fluoride into a solid mixture of magnesium fluorides and silicates of sodium and aluminium (nepheline).



skamol
insulation

Skamol a/s · Østergade 58-60 · DK-7900 Nykøbing Mors · Tel.: +45 97 72 15 33 · Fax: +45 97 72 49 75
Technotherm GmbH & Co. KG · Postfach 10 14 37 · D-41414 Neuss · Tel.: +49 2131 10 64 0 · Fax: +49 2131 10 64 64
Skamol a/s, UK Sales Office · Aden Mount · Thorrington · Essex CO7 8JJ · Tel.: +44 1 (206) 302 330 · Fax: +44 1 (206) 304 576
Skamol Inc. · 2045 Niagara Falls Blvd. · Suite 16 · Niagara Falls · NY 14304 · Tel.: +1 (716) 298 4115 · Fax: +1 (716) 298 4118

Certified under DS/ISO 9001

SKAMOLEX VIP-12 Vermiculite Block Insulation


Chemical Analysis (typical)

SiO ₂	48%	CaO	8%
Al ₂ O ₃ + TiO ₂	22%	Na ₂ O	0.3%
Fe ₂ O ₃	3.4%	K ₂ O	6%
MgO	9%	Loss on ignition (1025°C)	3.0%

TECHNICAL PROPERTIES


Max. service temp.	°C	1150	Specific heat	kJ/(kg·K)	0.9
	°F	2102		BTU/(lb·°F)	0.22
Bulk density, dry	kg/m ³	1200	Coefficient of reversible thermal expansion, 20°C-750°C (68°F-1382°F)	K ⁻¹	14x10 ⁻⁶
	lbs/cu.ft.	75		°F ⁻¹	7.8x10 ⁻⁶
Compressive strength	MPa	15.0	Linear reheat shrinkage, 12 h at 1100°C (2012°F) (DIN 51067, Teil 2)	%	1.0
	lbs/sq.in.	2175			
Modulus of rupture	MPa	3.0	Pyrometric cone equivalent	°C	1180
	lbs/sq.in.	435		°F	2156
Total porosity	%	52	Thermal conductivity at mean temp. (ASTM C-201 supplemented by ASTM C-182)	200°C	0.23
Bath resistance (»Light Metals 1986«, pp. 501-514)				400°C	0.26
			600°C	0.29	
Cryolite Attack Ratio (k)		1.27	800°C	0.32	
			Material Factor (m)	1.03	BTU/(sq.ft.·h·°F/in)
		392°F			1.59
			752°F	1.80	
			1112°F	2.01	
			1472°F	2.22	

The physical and chemical properties represent typical average values obtained in accordance with accepted test methods and are subject to normal manufacturing variations. They are supplied as a technical service and are subject to change without notice.



Architectural Institute 12422, Brno

Project Name	První - 1000 p. n. l.
Client	Státní ústřední archiv
Scale	1:500
Author	J. Štěrba
Year	1958
Sheet No.	31.00-01 b




10.10.10
 Бульварный
 Конкретостен

Всё оригинальное в 1/1
 Архив для публикации 24.02.2024

№ документа	10.10.10
Исполнитель	М.И.С.С.
Проверенный	М.И.С.С.
Дата	10.10.10
Масштаб	1:1
Лист	1
Кол-во листов	1
Исполнитель	М.И.С.С.
Проверенный	М.И.С.С.
Дата	10.10.10
Масштаб	1:1
Лист	1
Кол-во листов	1


М.И.С.С.
 10.10.10



Konstruktionstegning
31:01:01

Proj. Rev. nr.:		Blad nr.:		Blad:	
1		1		1	
Titel:		Mål:		Mål:	
Brændplade sider		A4		A4	
Morsø 3600		Målestok:		Målestok:	
3600-14		1:1		1:1	
Morsø		Morsø		Morsø	
Morsø		Morsø		Morsø	
Morsø		Morsø		Morsø	
Morsø		Morsø		Morsø	




Denne tegning kan ikke gengives eller oversættes til andre medier uden tilladelse fra Morsø



Konstruktionstegning
21.02.01


3600-20 Glas - Sheet1


Materiale:		5mm keramisk glas		Rev. Revisionstekst:		Sign.:	Dato:
Vægt:	813.5 g	Bearbejdes:		Titel:		Konstr.:	KDU 21.02.01
Overfladebeh.:			m ²	Glas 3600		Frigivet:	
Måltolerance:	Se tegning			Morsø 3600		Tegn.format:	A4
Ruhedstolerance:				morsø		Målførhold:	1:2
Værkløjsnr.:				Udvalgt af Morsø Glas		Varenr.:	79360000
Tegningstype:	Emnetegning					Tegningsnr.:	3600-20



Tekniske oplysninger		Dokumentation	
Mærke	2mm skelbredde / A13304	Figur	EDU
Vægt	3272 g	Emball.	112521
Overfladebehandling	Ikkebehandlet	Figur nr.	A2
Målestok	100 deler (1:100)	Målestok	1:2
Materialnummer	00.0007128.1m	Version	71360161
Materialnavn	Regleplade	Figurtype	3600-21

Denne tegning eller Morse-teknisk A13304 skal altid bruges sammen med andre Morse-tekniske A13304-tekniske. Brug altid den originale Morse-tekniske A13304-tekniske.






Konstruktionstegning
17.08.01

3600-23 Sidedør - Sheet1



Materiale: 25mm Isoleringsmåtte		Rev. Revisionslekt:		Sign.:	Data:	
Vægt:	- g	Bearbejdes:	Nej	Konstr.:	KDU 05.07.01	
Overfladebeh.:	Ubehandlet		- m ²	Frigivet:		
Måltolerance:	Se tegning			Tegn.format:	A4	
Ruhedstolerance:				Målforhold:	1:2	
Værktøjsnr.:	-			Varenr.:	79074900	
Tegningstype:	Emnetegning			Tegningsnr.:	3600-23	
			Morsø 3600  <small>Byggesystemer til alle typer døre og vinduer</small>			



3600-24 Sten sideplade - Sheet1

Materiale: 25mm Isoleringsmåtte		Rev. Revisionstekst:		Sign.:	Dato:
Vægt: - g	Bearbejdes: Nej	Titel: Isoleringsmåtte sideplade		Konstr.:	KDU 05.07.01
Overfladebeh.: Ubehandlet	- m ²	Morsø 3600		Tegn.format:	A4
Måltolerance: Se tegning				Målforhold:	1:2.5
Ruhedstolerance:				Varenr.:	79075000
Værktøjsnr.: -				Tegningsnr.:	3600-24
Tegningstype: Emnetegning					


Denne tegning filhører Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse




Konstruktionstegning
26.06.01

3600-25 Rustfri vinkelbeslag - Sheet11

Material:		3mm rustfri stål - AISI 304		Rev. Revisionstekst:		Sign.:		Dato:	
Vægt:		214.8 g		Bearbejdes:		Buk/bor		Titel:	
Overfladebeh.:		Ubehandlet		-		m ²		Konstr.:	
Måltolerance:		Mål uden toleranceangivelse		DS/ISO 2768-1 m				Frigivet:	
Ruhedstolerance:								Tegn.format:	
Værktøjsnr.:		-						Målf forhold:	
Tegningstype:		Emnetegning						Varenr.:	
				morsø <small>By eksportør til: The Poxa Group Ltd</small>				Tegningsnr.:	
								3600-25	
						KDU		26.06.01	
				Vinkelbeslag røgledepl.					
				ved brændplade					
				Morsø 3600				A4	
								1:2	
								71360361	




Materiale:		3mm rustfrit stål - AISI 304	Rev. Revisionslekt:	Dato:	
Vægt:	156.2	g	Beaufejdet:	svæpe	Sign.: KDU
Overfladebehold:	Mål uden toleranceanngivelse	- m²	Ubehandlet		26.06.01
Måletolerance:	Mål uden toleranceanngivelse		Målforhold:	A3	
Ruhetolerance:	ISO 2768-1 m		Værens:	71360461	
Vanketolerance:			Tegningnr.:	3600-26	
Tegningstype:	Ersmøglig				
Denne tegning tilhører Morsø Jernstøberi A/S og må ikke afhændes, udlånnes eller kopieres uden firmaets skriftlige tilladelse.					




Materiale:	3mm rustfri stål - AISI 304	Rev. / Revisionsstøt:	Titel:		Dato:	
Vægt:	154.2 g	Behandling:	Kont.: RDU	Sign.: RDU	26.06.01	
Overfladebehl.:	Ubehandlet	svøje	Vinkelbeslag højre			
Målebænder:	Mål uden tolerancangivelse	- m³	ved sideramme			
Ruhedtolerance:	DS/ISO 2768-1,m		Morsø 3600			
Værktøjer:			Tegningsnr.: 71360561			
Tegningstype:	Ersmøtegning		Tegningssk.: 3600-27			


Denne tegning illustrerer Morsø Jernløber A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse




Material: 1,5mm STD plade		Rev. Revisionssted:		Sign:		Dato:	
Vægt: 294,4 g	Beholdes: Svejtes	Titel: Airrightstuds		Kont.: KDU	24.06.01		
Overlæbebeh.: Males	Målt uden toleranceangivelse	Tegnlamot: A3		Målestok: 1:1			
Måltolerance: DS/ISO 228-1 m	Ø 3600	Morsø 3600		Værktøj: 71360600			
Ruldetolerance:		morsø		Tegningnr.: 3600-28			
Værktøjnr.:		Tegningstype: Emsletning		Dette tegning (hvor Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmoets skriftlige tilladelse)			



Materiale:	1 mm SPD plade	Rev.:	Revision:	Sign.: KDU	Date:	26.06.01
Vægt:	10102 <input type="checkbox"/> Børstet:	Konstr.:	Askeskuffe 3600	Friløst:		
Overfladebehl.:	Ubehandlet	Tegn. format:	A3	Målestok:	1:2	
Måltolerance:	Mål uden toleranceangivelse	Varianz:	71360700	Tegningv.:	3600-29	
Ruhedtolerance:	DS/ISO 2248:1 m					
Værktøjer:	-					
Tegningstype:	Ersmøtegning	Denne tegning tilhører Morsø Jernløber A/S og må ikke afhændes, udlånes eller kopieres uden firmatøt skriftligt tilladelse				




Rev. / Evidensfelt:		Sign.: EDU		Dato: 24.06.01	
Titel: Stråleplade bund		Konstl.:		Figur: A3	
Materiale: 1mm galvaniseret plade		Tegn. format:		Målehold: 1:2	
Vægt: 147,4 g	Bearbejdet: Buktet	Varenr.: 71360800		Tegningnr.: 3600-30	
Overfladebeh.: Måles	Målt uden tolerancengrænse				
Målerolerance: DS/ISO 2768:1 m					
Ruhedtolerance:					
Vankelighed:					
Tegningstype: Ernelegring	Denne tegning ligger i Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmets skriftlige tilladelse				
morsø LAMPES & BELYSNING					




Konstruktionstegning
15.08.01


Materiale:	1,5mm SPD plade		Rev. Revisionskøbt:	Sign.:	Date:
Vægt:	191,7 g	Behandling:	Titel:	Kendt:	14.04.01
Overfladebeh.:	Mål uden tolerancespille		Luftspjæld	Figur:	
Måleolerance:	DIN ISO 2768-1 m		Morsø 3600	Tegn-format:	A3
Ruheelolerance:				Målehold:	1:1
Vækkelin.:				Værem.:	71360900
Tegningstype:	Erneletgning			Tegningsnr.:	3600-31



Denne tegning tillæner Morsø Jernstøberi A/S og må ikke alenebrudes, udbruges eller kopieres uden firmaets tilladelse




rev./revisionsblad:		Titel:		Sgh.:		Dato:	
Materiale: 1,5 mm rustf. stål - AISI 304		Røgendeplade stål ved indv. tagplade Morsø 3600		Konstn.:		26.06.01	
Vægt: 1322,7 g	Behandling: sukker	Røgendeplade stål ved indv. tagplade Morsø 3600		Frigivet:		AS	
Overfladebeh.: Ikkebehandlet	Mål uden tolerancesangivelse	Morsø 3600		Målshob:		1:2	
Måltolerance: DKS 226-1 m	Ruhetolerance:	Vægt: 71361061		Vægt:		3600-32	
Værktøjer:	Emneegnelse:	Tegningsnr.:		Tegningsnr.:		3600-32	
Denne tegning illustrerer Morsø Jernlæberi A/S og må ikke ændres, udlånes eller kopieres uden firmaets skriftlige tilladelse.							




Material:		1.5mm rustfri stål - A316 304		Rev/ Revisionsløst:		Sign.: KDU		Dato: 04.07.01	
Vægt:		58x3 ø		Titel:		Konst.:		Figvel:	
Overfladebeh.:		Ubehandlet		Afdækningsplade		Tegn./formid:		A3	
Måle tolerance:		Målt uden Tolerancespændelse		Luffkanal mellembund		Målestok:		1:2	
Ruhedstolerance:		DIN/ISO 2768-Tm		Morsø 3600		Varem.:		71361161	
Værktøjerne:		-		Tegningstype:		Tegning.:		3600-33	
Tegningstype:		Enneltægning							

Denne tegning illustrer Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse




Material:	88 eulomstål	Rev. / Rev. tilføjet:	Sign.:	Dato:
Vægt:	235.0 kg	Konstr.:	SDU	04.07.01
Overfladebeh.:	Maler	Flgvel:		
Måleolerance:	Målt uden toleranceangivelse	Tegn. format:	A3	
Ruhedolerance:	DS/ISO 2768-1 m	Målløst:	1:2	
Værktøjer:	-	Værent:	71361200	
Tegningstype:	Emne-tegning	Tegningens:	3600-34	

Denne tegning illustrerer Morsø Jernstøbet A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse



3600-35 Sten bag - Sheet 1


		Rev.	Revisionstekst:		Sign.:	Dato:	
Materiale:	25mm Vermiculit VIP 12		Bagsten Morsø 3600 		Konstr.:	KDU 04.07.01	
Vægt:	2964.0 g	Bearbejdes:			Nej	Frigivet:	
Overfladebeh.:	Ubehandlet				Tegn.format:	A4	
Måltolerance:	Se tegning					Målf forhold:	1:2.5
Ruhestolerance:						Varenr.:	79360300
Værktøjsnr.:	-			Tegningsnr.:	3600-35		
Tegningstype:	Emnetegning						



Konstruktionstegning
04.07.01

3600-36 Holder for bagsten - Sheet 1





Materiale:		1,5mm rustfri stål - AISI 304		Rev.	Revisionstekst:	Sign.:	Dato:
Vægt:	182.9 g	Bearbejdes:	bores	Titel: Holder for bagsten		Konstr.:	KDU
Overfladebeh.:	Ubehandlet					Frigivet:	
Måltolerance:	Mål uden toleranceangivelse DS/ISO 2768-1 m			Morsø 3600		Tegn.format:	A4
Ruhedstolerance:						Målføhold:	1:2
Værktøjsnr.:	-					Varenr.:	71361361
Tegningstype:	Emnetegning					Tegningsnr.:	3600-36



Konstruktionstegning
16.08.01




3600-37 Isoleringmåtte - Sheet11

Materiale:	25 mm Isoleringmåtte			Rev. Revisions tekst:	Sign.:	Dato:	
Vægt:	-	kg.	Bearbejdes:	-	Konstr.:	KDU	
Overfladebeh.:	-			- m ²	Frigivet:		
Måltolerance:	Mål uden toleranceangivelse			Tegn.format:	A4		
Ruhedstolerance:				Målforhold:	1:5		
Værktøjsnr.:	-			Varenr.:	79074800		
Tegningstype:	Ernelegning			Tegningsnr.:			
				Isoleringmåtte 3600 USA Morsø 3600 		3600-37	








2011022 2011022		2011022 2011022	2011022 2011022
2011022 2011022	2011022 2011022	2011022 2011022	2011022 2011022
2011022 2011022		2011022 2011022	2011022 2011022
2011022 2011022		2011022 2011022	2011022 2011022

INORSO
 INGENIERIA
 S.p.A.

	Anvendes til:
<p>EDB nr. 541403</p> 	1410
<p>EDB nr. 542056</p> 	1B 2B 1126
<p>EDB nr. 541082</p> 	1610 1710


Mart.: Ø6 Rf. automatstål
EDB nr. 714005

<p>Titel: Ø6 hængselstifter</p>	<p>Sign.: N.Aa.</p>	<p>Dato: 06.10.87</p>	<p>Revision</p>	<p>Sign.</p>	<p>Dato</p>
	<p>Tegn.form.: A4</p>	<p>Målforhold 1:1</p>	<p>Gamdrup TegneTeknik</p>	<p>HCH</p>	<p>April 96</p>
<p>Tegningsnummer: 1126-38-4</p>	<p>Varenummer: se teg.</p>		<p>Tilføjet grader</p>	<p>KD</p>	<p>20.12.96</p>
	<p>Filnavn: 1126-38</p>				



Materiale: Rustfast stål

g	Tolerancer tilføjet	KDU	11.10.99	Titel: Døraksel 1126	Sign.:	Dato:
f	Notater tilføjet	KDU	07.09.99		N.Aa	03.12.87
e	Fjerne M4 - fiksering	KDU	07.09.99	Filnavn: 1126/1126-44.drw	Tegn.format:	Målförhold:
d	Tilføje M4m - fiksering	KAA	16.09.97		A4	1:1
c	Tilføje målsætning	KDU	20.12.96	Varenummer: 752627		
b	Gamdrup Tegneteknik	HCH	April 96			
Rev.	Revisionstekst:	Sign.:	Dato:	morsø Jernsløberi A/S	Tegningsnummer: 1126-44 g	




d	Ændret mål	RSV	22.05.2001
c	Ændring af tegningsnr.	KDU	19.12.1996
b	Gamdrup Tegne Teknik	HCH	April 1996
Rev.	Revisionstekst:	Sign.:	Dato:

Materiale:	Rustfast stål
Vægt:	317 g
Overfladebeh.:	m ²
Måltolerance:	Mål uden toleranceangivelse DS/ISO 2768-1 m
Ruhestolerance:	
Værktøjsnr.:	
Tegningstype:	Emnetegning

Titel:	1126 dørhåndtag
	Morsø 1126
morsø <small>DRACHTWERK</small>	

Konstr.:	N.Aa	14.10.87
Frigivet:		
Tegn.format:	A4	
Målforshold:	1:1	
Varenr.:	752625	
Tegningsnr.:	1126-45 d	

1126-45 Dørhåndtag - Sheet 1



Snit A-A



Alle rundinger R1,5

Boreanviser for Ø7


312627

Solid part		REGENT		TECHNISK
DATE	18/10 89	MODEL	2627	112-64-2
REGENT		TECHNISK		
Røgtud Ø155DK		1:1		
Solid part		1:1		
MORSØ		TECHNISK		

A B C D E F G H J K L M






A-A




1400-204 - Sheet 1

Materiale:		Sort fladjern		Rev.:		Revisionstekst:		Sign.:		Dato:	
Vægt:		0,015 kg.		Bearbejdes:				Konstr.:		RSV	
Overfladebeh.:				m ²		Titel:		Frigivet:			
Måltolerance:		Mål uden toleranceangivelse		DS/ISO 2768-1 m		Lus med gevind		Tegn.format:		A4	
Ruhedstolerance:						Morsø 1400		Målforhold:		2:1	
Værkløjsnr.:						Morsø		Varenr.:		44256700	
Tegningsstype:		Emnetegning						Tegningsnr.:		1400-204	






c	Ændret varenummer	RSV	14.03.2001
b	Ændret mål	RSV	06.09.2000
Rev.	Revisionstekst:	Sign.:	Dato:
Materiale:	1 mm rustfri plade	Titel:	Konstr.:
Vægt:	0,006 kg. Bearbejdes:	Glasbeslag 2	RSV
Overfladebeh.:	m ²	Morsø 1400	07.03.2000
Måltolerance:	Mål uden toleranceangivelse DS/ISO 2768-1 m		Frigivet:
Ruhedstolerance:			RSV
Værktøjsnr.:			30.06.2000
Tegningstype:	Emnetegning		Tegn.format:
			A4
			Målforhold:
			2:1
			Varenr.:
			54146361
			Tegningsnr.:
			1400-206 c

1400-206 - Sheet 1



Matr:10x1 Hydraulikrør galv. varenr.712602

Titel: Afstandsrør ø10x1 L=13	Sign.: RS	Dato: 970113	Revision	Sign.	Dato
	Tegn.form.: A4	Målførhold 2:1			
Tegningsnummer: 1400-303-4	Varenummer: 541438				
MORSØ Jernstøberi A/S	Filnavn: 1400-303				





Note: Skarpe kanter brydes.

b	Påført at skarpe kanter brydes	RSV	06.10.2000
Rev.	Revisionstekst:	Sign.:	Date:
Ophæng til greb Morsø 2100 		Konstr.:	RSV 07.07.2000
		Frigivet:	RSV 15.03.2001
		Tegn.formal:	A4
		Målforhold:	1:1
		Varenr.:	54185800
		Tegningsnr.:	2100-163 a

Materiale:	1 mm SPD plade		
Vægt:	0,019 kg.	Bearbejdes:	Buk/bore
Overfladebeh.:	-		- m ²
Måltolerance:	Mål uden toleranceangivelse DS/ISO 2768-1 m		
Ruhedstolerance:			
Værktøjsnr.:	-		
Tegningstype:	Emnelegning		


2100-163 ophæng til greb - Sheet 1



3100-36 - Sheet 1


		b	Varenr. ændret fra 71313100	KDU	05.09.2000
		Rev.	Revisionstekst:	Sign.:	Date:
Materiale:	ø10x1 rør		Titel: Afstandsrør ø10x1 L = 25mm Morsø 3100 	Konstr.:	KDU 09.06.2000
Vægt:	0,01 kg.	Bearbejdes:		Frigivet:	KDU 09.06.2000
Overfladebeh.:				Tegn.format:	A4
Måltolerance:	Mål uden toleranceangivelse DS/ISO 2768-1 m			Målforhold:	2:1
Ruhedstolerance:				Varenr.:	54313100
Værktøjsnr.:			Tegningsnr.:		
Tegningstype:	Emnetegning		3100-36 b		

Denne tegning tilhører Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse.




		Matr.: 15x1 mm Båndstål uhærdet		Vægt: 0,01 Kg.	
Rev.	Revision	Sign.	Dato	Titel:	
b	Hul påført	AØS	10.11.98	Mont.stål f. reg.stang	
				Morsø 3400	
				Filnavn:	
				3400-18	
				Varenummer:	
				71346500	
				Tegningsnummer:	
				3400-18 b	

MORSØ
Jernstøberi A/S



Matr.: Rustfri stål


Rev.	Revision	Sign.	Dato	Titel: MORSØ 3400 Greb til Reguleringsstang	Sign.:	Dato:
b	Påført matr.	RSV	10.10.00		AØS	30.10.98
					Tegn.form.:	Målforhold
					A4	2:1
				Filnavn:	Varenummer:	
				3400-41	75180400	
				morsø Jernstøberi A/S	Tegningsnummer:	
					3400-41 b	




10x3 L=168mm


Matr.: Sort båndstål


Vægt: xxxx Kg.


Titel: MODULOVN BØJLE TIL RØGDÆKSEL	Sign.: CHK	Dato: 21.11.94	Revision	Sign.	Dato
	Tegn.form.: A4	Målforhold 1:1		KA	26.09.95
Tegningsnummer: 5000-63-4	Varenummer: 545006		Varenr.+mål ændret	RSV	14.02.97
	Filnavn: 5000-63		d Ændret mål	RSV	05.03.99
 Jernstøberi A/S					



Ø10x1 Hydraulikrør galv.

Titel: Afstandsrør Til bøjle på røgdæksel	Sign.: RS	Dato: 970214	Revision	Sign.	Dato
	Tegn.form.: A4	Målforshold 5:1			
Tegningsnummer: 5000-64-4	Varenummer: 545007				
	Filnavn: 5000-64				



				Matr.: ø8 mm automatstål		Vægt: 0,2 Kg.	
Rev.	Revision	Sign.	Dato	Titel: Ildrager New Generation/Classic		Sign.:	Dato:
b	Ombuk forlængel 70 mm	KDU	11.06.99			CAA	30.07.98
				Filnavn: 9000-05		Tegn.form.:	Målforhold
						A4	1:2
				 <small>Jernstøberi A/S</small>		Varenummer: 79900321	
						Tegningsnummer: 9000-05 b	

APPENDIX G

Ferguson, Andors & Company

P.O.Box 678, South Royalton, VT 05068 • 802-763-2339 (Voice and Facsimile)

August 1, 2001

Mr. Bill Keen
Intertek Testing Services
8431 Murphy Drive
Middleton, WI 53562

Dear Bill:

As you know, we will be representing Morso Jernstøberi A/S during the upcoming EPA certification testing of their new Model 3600 non-catalytic woodstove. This product does not have a fan either as standard or optional equipment.

We would like to provide the following information regarding operating procedures and air settings that will be helpful in obtaining the required burn rate ranges.

First, for the lower burn rate tests (category 1 and 2), two pre-burn fuel loads should be burned in the stove prior to the actual test load. The stove should be shoveled out and the ash pan emptied after the first pre-burn load. This will help insure that the stove reaches a good equilibrium temperature and that the test runs will not exceed the allowable stove body "Delta T" requirements.

For the lowest air setting, the door should be left slightly open for the first 90 seconds and the air control should remain fully open for the full five-minute start-up period and then fully closed.

If this results in a burn rate above one kilogram per hour, repeat the procedure but close the air control in small increments starting at three and one-half minutes.


If the initial burn rate is below one kilogram per hour, repeat the test conditions to obtain a second run in category 2.

For the maximum burn rate test, it is not necessary to leave the door cracked open after loading the test fuel. Just be sure to add enough pre-burn fuel to obtain a good charcoal bed and make the one-hour required pre-burn time period.

For category 3, we recommend setting the air control lever to a position where the uppermost corner of the end of the control lever is 1.75" from the lowest plane of the ashlip. The door should be cracked open for 90 seconds and the air control set at maximum for the first five minutes.

These settings should be used as a guideline. Adjustments to meet the required burn rate categories should be made if needed based on your best judgements.

Sincerely,



Robert W. Ferguson


morsø

By appointment to  the Royal Danish Court

Installation and Operating Instructions

3600

For use in North America



Read this entire manual before you install and use your new room heater. If this room heater is not properly installed, a house fire may result. To reduce the risk of fire, follow the installation instructions. Failure to follow instructions may result in property damage, bodily injury, or even death.

Contact local building officials about restrictions and installation inspection-requirements in your area.

Save these instructions

MORSØ JERNSTØBERI A/S . DK-7900 NYKØBING MORS
E-Mail: stoves@morsoe.com · Website: www.morsoe.com

Distributed by: HEARTHLINK INTERNATIONAL
9 Maple St. - Randolph, Vermont - 05060 - USA

We congratulate you on your choice of a Morsø stove. Morsø has been producing some of the world's best stoves since 1853. If you follow this installation- and operating instruction carefully, we can assure you many years of warmth and pleasure.

Optional Accessories

A wide range of accessories (such as handling gloves, fireside tools, glass cleaner and heatproof paint) are available for use with your Morsø stove. They help with day-to-day running and maintenance. Contact your Morsø dealer for more information.

The Morsø 3600 meets the U.S. Environmental Protection Agency's emission limits for wood heaters sold on or after July 1, 1990



The Morsø 3600 have been tested by Intertek Testing Services and is listed by Warnock Hersey, Inc. The test standards are ANSI/UL-1482 for the United States and ULC S627 for Canada.

The stove is listed for burning wood only. Do not burn other fuels.

CONTENTS:

1.0	Installation of your Morsø stove	
1.1	Checking loose parts in the stove	4
1.2	The chimney / flue system	4
1.3	Flue Connection	5
1.4	Connection to existing chimney	6
1.5	Positioning the stove	8
2.0	Operation	
2.1	Before you start firing	10
2.2	Lighting and loading intervals	11
3.0	Maintenance	12
3.1	Exterior maintenance	12
3.2	Internal maintenance	12
3.3	Cleaning the Stove and the Flue	14
3.4	Leaving the stove for extended periods	16
3.5	Parts diagram	17
3.6	Parts list	18

1.0 Installation of your Morsø stove

Installation of woodburning stoves must be safe and legal.

If your Morsø stove is not installed correctly, it may cause a house fire. To reduce the risk of fire, the installation instructions must be followed carefully. Contact the local building officials about restrictions and installation inspection in your area.

Before you start installing your stove, make sure that:

- The stove and chimney connection are placed far enough from combustible materials to meet all clearance requirements.
- The floor protection must be adequate and must be made correctly according to the requirements.

All necessary approvals are needed from the local building officials.

The data plate, which is located on the back of the stove, provides information regarding safety testing information, name of certified testing laboratory, and installation requirements.

Installation requirements vary in different districts, and the local building officials have the final authorization to approve your installation. You should discuss the installation with them before beginning. Please ask your dealer for further information.

Do not connect to any air distribution duct or system.

Important: If the installation instructions are not followed carefully, it may cause dangerous situations like chimney - and house fires. Follow the instructions carefully and do not deviate from them as it may cause injuries to people or property.

1.1 Checking loose parts in the stove

After unpacking, check that the fire bricks are firmly in position and have not shifted in transit. Check also that the air control works freely.

Standard Accessories

Poker, ceramic flue connection gasket and ash can tools are standard accessories, and can usually be found in the ashpan or firebox area.

1.2 The chimney / flue system

Note that the flue system must be independently secured and must not rely on the stove for support.

The stove must not be connected to a chimney flue serving any other appliance. (Several flues may run up a single chimney stack; use one flueway per appliance).

Use a residential type masonry or listed type HT factory-built chimney.


High Temperature (H.T.) Chimney Standard UL-103-1985 (2100° F.) for the USA, and High Temperature (650°C) Standard ULC S-629 for Canada.

The internal dimensions of the chimney connector and chimney must not be less than 6 inches diameter (or equivalent cross section), and should not be significantly larger than this. Too large a section will tend to allow the flue gases to cool excessively, causing sluggishness or unpredictability in the stove's performance.

We recommend the length of the chimney system should be at least 16 feet (not required) above the stove in normal domestic situations, measured from the flue collar to the top of the chimney.

Local conditions like for example - roof constructions, large trees nearby and high altitude, may influence the chimney draft and height. Therefore, contact the local professional chimney sweep or your Morsø dealer.

Typical Factory-Built or Masonry Chimney Installations



1.3 Flue Connection

The stove is supplied from the factory with a flue collar fitted to the top plate and a round blanking plate blocking off the rear flue exit (behind the rear shield plate).

Use a 24 MSG black or blue chimney connector or listed double wall chimney connector. Refer to local codes and the chimney manufacturer's instructions for precautions required for passing a chimney through a combustible wall or ceiling. Remember to secure the chimney connector with a minimum of three screws to the product and to each adjoining section.

The collar can be fitted to the rear outlet. Simply knock out the round panel on the rear heat shield plate to reveal the cast iron plate. Untwist the blanking plate and the flue collar and swap their positions. Re-secure by pushing down and tighten the enclosed screws.

Position the stove and connect to the flue system.

Wear gloves and protective eyewear when drilling, cutting or joining sections of chimney connector

1.4 Connection to the existing chimney

A chimney connector is the double-wall or single-wall pipe that connects the stove to the chimney. The chimney itself is the masonry or prefabricated structure that encloses the flue. Chimney connectors are used only to connect the stove to the chimney.

Double-wall connectors must be tested and listed for use with solid-fuel burning appliances. Single-wall connectors should be made of 24 gauge or heavier gauge steel. Do not use galvanized connector; it cannot withstand the high-temperatures that smoke and exhaust gases can reach, and may release toxic fumes under high heat. The connector must be 6 inches (150mm) in diameter.

If possible, do not pass the chimney connector through a combustible wall or ceiling. If passage through a combustible wall is unavoidable, refer to the sections on Wall Pass- Throughs. Do not pass the connector through an attic, a closet or similar concealed space when installing the chimney connectors.


It is important to keep the flue gases moving smoothly in the right direction. Do not vent into a large void at this location; rather form one continuous section all the way up. Use mild bends (e.g. 45° vs. 90°) rather than sharp angles where a change of direction is required. All parts of the venting must be accessible for cleaning purposes.

In horizontal runs of chimney, maintain a distance of 18 inches from the ceiling. Keep it as short and direct as possible, with no more than two 90 degree turns. Slope horizontal runs of connector upward 1/4 per foot (20 mm per metre) going from the stove toward the chimney. The recommended maximum length of a horizontal run is 3 feet (1 metre), and the total length should be no longer than 8 feet (2.5 metres).


Information on assembling and installing connectors is provided by the manufacturer's instructions exactly as you assemble the connector and attach it to the stove and chimney.

Be sure the installed stove and chimney connector are correct distances from near by combustible materials. See the clearance paragraph page 8.


Chimney Connector Systems and Clearances from Combustible Walls for Residential Heating Appliances




- A Minimum 3.5-in thick brick masonry all framed into combustible wall with a minimum of 12-in brick separation from clay liner to combustibles. The fireclay liner shall run from outer surface of brick wall to, but not beyond, the inner surface of chimney flue liner and shall be firmly cemented in place.



- B Solid-insulated, listed factory-built chimney length of the same inside diameter as the chimney connector and having 1-in. or more of insulation with a minimum 9-in. air space between the outer wall of the chimney length and combustibles.



- C Sheet steel chimney connector, minimum 24 gauge in thickness, with a ventilated thimble, minimum 24 gauge in thickness, having two 1-in. air channels, separated from combustibles by a minimum of 6-in. of glass fiber insulation. Opening shall be covered, and thimble supported with a sheet steel support, minimum 24 gauge in thickness.



- D Solid insulated, listed factory-built chimney length with an inside diameter 2-in. larger than the chimney connector and having 1-in. or more of insulation, serving as a pass-through for a single wall sheet steel chimney connector of minimum 24 gauge thickness, with a minimum 2-in. air space between the outer wall of chimney section and combustibles. Minimum length of chimney section shall be 12-in. chimney section spaced 1-in. away from connector using sheet steel support plates on both ends of chimney section. Opening shall be covered, and chimney section supported on both sides with sheet steel supports securely fastened to wall surfaces of minimum 24 gauge thickness. Fasteners used to secure chimney section shall not penetrate chimney flue liner.

1.5 Positioning the stove

Distance to walls and lintel

When the stove is positioned near *combustible* materials, observe all current local and national building regulations with regards to clearances. Whatever regulations apply to your area, do not in any case install the stove within 8 inches of combustible materials around the sides or 16 inches above the top of the stove (fireplace installations require greater clearances above the stove - see below in the clearance chart). These distances may need to be increased if the materials are sensitive to heat. Note also that wall paper and other decorative materials may become detached with the effects of heat and care should be taken to ensure that they do not fall towards the stove in such an event.

When the stove is positioned near *non-combustible* materials, a gap of 4 inches or more is recommended for cleaning purposes and to ensure that heat circulates around the stove and out into the room.

Appliance Clearances

Chimney connector clearances	Unprotected Surfaces			Protected Surfaces (NFPA-211)		
	Parallel		Corner	Parallel		Corner
	Side	Rear		Side	Rear	
Single wall connector	-in -mm	-in -mm	-in -mm	-in -mm	-in -mm	-in -mm
Double wall connector	-in -mm	-in -mm	-in -mm	-in -mm	-in -mm	-in -mm

Fireplace Hearth Installation					
	In	Mm		In	Mm
Unit to top trim			Unit to side trim		
Unit to mantle			Unit to sidewall		


On the floor

If the stove is to be placed on a combustible floor, a solid, non-combustible layer should cover the floor beneath the stove. This layer should cover an area of at least 16 inches in front of the stove doors and at least 8 inches either side of the opening and 6" to the rear.

You must ensure that the floor in this area can hold the weight of the stove comfortably.

The floor protection in front of the unit must have an insulative R-value of 1.0 (English units).

In Canada non-combustible floor protector is required under the stove as well. The floor protector must extend 18 inches (460mm) to the front and 6 inches (155mm) from the sides and rear.



	U.S.	Canada
A.	"	" (mm)
B.	"	" (mm)
C.	"	" (mm)
D.	"	" (mm)
E.	"	" (mm)

Distance to furniture

The recommended minimum distance from stove to furniture is 30 inches. Note that some furniture is more easily affected by heat and may need to be moved to a greater distance. This is your responsibility.

In addition other combustible materials, away from the stove. In general, a distance of 30 inches must be maintained between the stove and moveable combustible item such as drying clothes, newspapers, firewood etc.

Note:

Acid Protection

If acid-washing the masonry around the stove, protect the stove surface with an acid-proof cover

Fresh Air Inlet

Unless there is deemed to be sufficient ambient leakage of air into the room via doorways, windows and the like, a dedicated fresh air inlet will be needed. This inlet should have 2 square inches (1250 square mm) of free air space. This is particularly important where the room is well sealed, or where an extractor hood or ventilation system disturbs the natural air pressure. Such an inlet should not be on a wall that is usually subject to negative pressure from normal wind pattern. Avoid placing the inlet directly across the room from the stove, thus causing a cold air draft.

2.0 Operation

2.1 Before you start firing

For Use with Solid Wood Fuel Only. Do Not Overfire, If Heater or Chimney Connector Glows You Are Overfiring. Inspect and Clean Chimney Frequently. Under Certain Conditions of use creosote buildup may occur rapidly. Because of risk of smoke and flame spillage, operate only with door fully closed.

Caution:

Hot while in operation. Keep children, clothing and furniture away. Contact may cause skin burns.

Do not use chemicals or fluids to start the fire.

Do not burn garbage or flammable fluids.

Do not use gasoline, gasoline-type lantern fuel, kerosene, charcoal lighter or fluid or similar liquids to start or freshen up a fire in this heater. Keep all such liquids away from the heater while it is in use.

Choosing your fuel

All types of natural wood can be burned on your stove, but they must be well-seasoned and dry. Once the wood is cut to length, it should be split down middle - to suit the dimensions given below - to allow moisture to evaporate.

Cut the wood to a length of max 22 inches (56 cm) and approx. 3 to 3.5 inches (7-8 cm) in section. If you can weigh your wood, aim for around 1.0 kg. The maximum moisture content of the wood should be around 20%.

Store the logs under cover in a location where fresh air can move through the stack. Some soft woods may take as little as one good summer to season whereas harder woods such as oak, maple, and elm may require seasoning up to 18 months. Avoid overly dry wood that is gray in color as it can cause performance problems, such as backpuffing and sluggishness, under certain conditions. Well seasoned wood will be remarkably light to hold and will probably have radial cracking at the ends. If your wood spits or sizzles when burnt, and your stove's door glass persistently mists up, your wood is not properly seasoned. Never use drift wood (from the sea), whose salt content may cause corrosion, nor construction wood that may have been impregnated with chemicals.

Starting the First Fire

The initial fire should be small, so that the stove paint can cure and the main plates of the stove can settle into position. Some fumes will be given off by the paint. Ventilate the room during this phase.

The setting of the air control, lighting techniques and loading intervals will depend on chimney draft, the fuel used, the heat required and so on. Some basic techniques are outlined below.

In principle

Your stove is fitted with Primary and Secondary air inlets.

Primary Air is controlled using the lever situated under the ash lip of the stove. Moving the control lever into a downward position will open the air inlet and will allow a supply of preheated air to enter the firebox via the 'airwash' system situated inside the stove and the above glass.

Secondary Air is right to the firebox using the specially designed baffle at the back of the firebox. The secondary air is injected into the flue gases both above and in front of the fire resulting in a cleaner, more efficient combustion process. The supply of secondary air is fixed open and is not adjustable.

For extra safety, your stove has been fitted with a removable handle. When not in use the handle can be stored using the lug by the right leg of the stove.


2.2 Lighting and loading intervals

When first lighting the stove, a large volume of air is needed. When the stove is cold, you should leave the door open an inch or two for the first few minutes and open the primary air supply completely. While the doors is open, do not leave the stove unattended.

To form a reasonable bed of ash on the floor of the stove, you should use 5-6 inches thickness (2-4 pound) of dry kindling at the initial lighting. Always maintain a 1-1.5 inch (2-3 cm) layer of ash on the floor of the combustion chamber at all other times.

Step-by-step procedure

1. The air supply must be fully open.
2. Light the fire. An ember bed will quickly be formed by lighting with firelighters, morsø kindling bags or 7-10 pieces of twisted paper under the dry kindling wood (see above).
3. After lighting, partially close the doors, leaving them open an inch or two to allow in plenty of combustion air.
4. When the chimney is warmed through after 5-10 minutes, the doors should be closed. A suitable ember bed will be formed after a further 15-20 minutes.
5. When ready to reload, use a poker to spread the ember across the firebox floor, bringing plenty towards the front of the stove.
6. Lay three pieces of wood (see dimensions above) onto the embers. Leave half an inch (1 cm) or more between each piece. When using 10 inches (25 cm) logs, place the ends of your logs towards the opening, but not too close to the front.



7. Close the door. Leave the primary air supply fully open.
8. After a few minutes, and adjust the primary air supply to suit your heating requirements.
9. Anticipate each refueling, remembering to add a modest layer of wood while there are still plenty of live embers, Repeat steps 5-8.

Do not for any reason attempt to increase the firing of your heater by altering the air control adjustment range outlined in these directions.

Warning: Fireplace stoves must never be left unattended with doors open.

If doors are left partly open, gas and flame may be drawn out of the fireplace stove opening, creating risks from both fire and smoke. We recommend you to fit a smoke detector in the room where the stove is installed.

DO NOT OVERFIRE THIS HEATER. Overfiring may cause a house fire, or can result in permanent damage to the stove. If any part of the stove glows, you are overfiring.

Draft conditions

If smoke or fumes come out of your stove when lighting up and reloading, or if the fire simply will not respond, a poor draft is almost certainly to blame. (In a very few cases, there may be insufficient fresh air getting into the room - see installation advice above). Take advice from your stove supplier on how best to upgrade your flue system to improve draft.

Rules of woodburning

If you want less heat, put fewer logs on the stove and reduce the amount of air. It is still important to maintain a good layer of embers.

Less heat - less wood - less air

Greater heat - more wood - more air

Soot deposits will settle on the glass if the stove is run too slowly or if your wood is not well seasoned.

3.0 MAINTENANCE

When performing maintenance on your stove, always protect yourself, using safety goggles or gloves

3.1 Exterior Maintenance

The stove surface is painted with heat-resistant Senotherm paint. It is best kept clean by vacuuming with a soft brush attachment or by wiping with a lint-free cloth.

Over a period of time, the painted surface may become slightly grey. A can of Morsø touch-up spray paint should be available from your stove supplier. This can be applied - in accordance with the instructions - in just a few minutes. When first firing after touching up, the stove will give off a slight smell as the paint cures. Make sure to ventilate the room well during this phase.

3.2 Internal maintenance

Glass

If the stove is generally run at the correct temperatures, there should be little or no dirt on the glass. If dirt does settle during lighting, most will burn off as temperatures increase. For heavier deposits that will not burn off, use morsø glass cleaner, applied when the glass is cold, in accordance with the instructions. Never use abrasive cleaners on the glass surface.

Reasons for dirty glass

- Fuel too wet
- Logs too large or not split
- Combustion temperatures too low

Replace broken glass immediately.


Do not operate your stove if the glass in the door is damaged.

If you need to replace the glass, it should be replaced with the high temperature ceramic glass supplied by Morsø, contact your Morsø dealer.

Installing the glass

Never install the glass when the stove is in function.

1. Lift the door off its hinges and place face-down on a sheet of cardboards or other non-abrasive fabric.



2. Unscrew the 4 bolts that secure the glass. (In the event that a bolt sheers off when being unscrewed, remove the remaining body of the bolt by drilling down its centre with 1/8 inch high speed steel drill bit. Smaller drill bits may be successful, but do not use a larger bit. Make sure the bit stays away from the edges of the bolt - this may damage the thread in the cast iron).

3. Remove the old ceramic gaskets and clean up the surface underneath with wire wool or emery paper to remove loose particles.

4. Place the new gasket material in position around the perimeter of the window area, making sure to pinch them to the length in such a way that they make a continuous seal. Leave no gaps.

5. Place the new glass in position on the strips and screw home the fresh bolts and fitting by hand.

6. Finally, give each of the bolts an extra half turn or so. The glass should be held tight enough that cleaning will not dislodge it. Do not over-tighten the bolts as this may put excessive pressure on the glass, resulting in cracking - important!

To reduce the risk of breaking the glass, avoid striking the glass or slamming the door.

Internal service parts

The flame-path equipment - consisting of the ashpan, grate, firebricks, Cast iron fire plates, glass, baffle and flue collar - are subject to the extremes of heat produced by the fire. From time to time, one or other of these parts may need replacing as a matter of routine maintenance.

NOTE: The flame-path equipment, the ceramic rope and the paint finish are not covered by guarantee.

All of these service parts can be bought from your morsø dealer, and we recommend that damaged parts are replaced as soon as possible to avoid collateral damage.

Should the baffle be distorted by an overfire, the stove will still function, although its efficiency may be compromised. Replace it as soon as possible. The radiation shield on the back of the stove is first removed by loosening the 4 screws. The rear casing is removed (four bolts). Remove these and remove the 2 M8 bolts keeping the baffle plate. withdraw the baffle from the firebox.

Before replacing the baffle, scrape out the old fire furnace and replace with new to make an effective seal.

Reasons for fast internal wear and tear

Persistent heavy firing

Soot and ashes left to accumulate

Ceramic Gasket

The gasket around the perimeter of the doors may harden over a period of time. It should be replaced if it becomes difficult to close the doors or if air starts to leak in around the perimeter of the doors, causing the fire to become a little less controllable. A morsø rope gasket kit is available from your stove supplier.

3.3 Cleaning the Stove and the Flue

Check for soot above the baffle plate and around the flue outlet every month or so to start with. If the stove suddenly becomes sluggish, check for a soot fall around the flue collar or in the flue/chimney. - at least once a year. Inspect every month.

Clean the flue/chimney - all the way from the stove to the flue terminal point above the house.

A good routine is to clean the flue after each heating season in any case, and inspect prior to the season to ensure that bird's nests or other blockages have not occurred during the off season.

Ash disposal

Empty the ashpans on a daily basis or as needed. Ash allowed to build up towards the underside of the grate will trap heat and could cause premature failure of the grate.

Empty the ashpan according to this procedure:

Open the front doors, and use a shovel or poker to stir excess ash through the ash slots in the grate down into the ash pans. Remove the ash pans, making sure to keep it level.

grate down into the ash pans. Remove the ash pans, making sure to keep it level. Dispose the ash in a metal container with a tight fitting lid. The closed container of ashes should be placed on a noncombustible floor or on the ground, well away from all combustible materials, pending final disposal. If the ashes are disposed of by burial in soil or otherwise locally dispersed, they should be retained in the closed container until all cinders have thoroughly cooled. Return the ash pans to its original position in the stove, and close.

Caution:

Never empty a stove in operation.

Never use your household or shop vacuum cleaner to remove ash from the stove; always remove and dispose of the ash properly.

Creosote - formation and need for removal

When wood is burned slowly, it produces tar and other organic vapors, which combine with expelled moisture to form creosote. The creosote vapors condense in the relatively cool chimney flue of a slow-burning fire. As a result, creosote residue accumulates on the flue lining. When ignited this creosote makes an extremely hot fire. When burning wood, inspect the chimney connector periodically to determine if a creosote buildup has occurred.

Chimney sweeping

Inspect the system regularly during the heating season as part of a regular maintenance schedule. To inspect the chimney, let the stove cool completely. Then, using a mirror, sight up through the flue collar into the chimney flue. If you cannot inspect the flue system in this fashion, the stove must be disconnected to provide better viewing access.

Clean the chimney using a brush the same size and shape as the flue liner. Run the brush up and down the liner, causing any deposits to fall to the bottom of the chimney where they can be removed through the clean-out door.

Clean the chimney connector disconnecting the sections, taking them outside, and removing any deposits with a stiff wire brush. Reinstall the connector sections after cleaning, being sure to secure the joints between individual sections with sheet metal screws.

If you cannot inspect or clean the chimney yourself, contact your local Morsø Dealer or a professional chimney sweep.

If you do experience a chimney fire, act promptly and:

Close the air control.

Get everyone out of the house.

Call the Fire Department.

Annual maintenance

Before the heating season, perform a thorough cleaning, inspection and repair:

Thoroughly clean the chimney and chimney connector.

Inspect the chimney for damage and deterioration. Replace weak sections of prefabricated chimney. Have a mason make repairs to a masonry chimney.

Inspect the chimney connector and replace any damaged sections.

Check gasketing for wear or compression, and replace if necessary.

Check the glass for cracking; replace if needed.

Check door and handles for tightness. Adjust if needed.

3.4 Leaving the stove for extended periods

Important:

If the stove is to be left unused for any period of time, clean it out thoroughly and leave the air control slightly open to allow airflow. Make sure that the flue does not allow rainwater to come anywhere near the stove; install a chimney cap, but do not block off the flue completely.

These measures should ensure there is a slight movement of air through the stove, and that the body of the stove remains dry, right into the corners.


Any ash left within an unfired stove can attract moisture like blotting paper. If moisture is allowed to settle within the stove, rust will form. Rust expands as it takes a grip. This can lead to undue pressure on the stove joints, and this in turn may result in damage to the stove.

NOTE: It is best to thoroughly clean the stove after the heating season has concluded. Adding a dessicant, such as kitter litter, into the ash pan helps absorb moisture during the summer months. Be sure to remove this prior to the heating season.

Thank you for buying a morsø stove.

We hope you have many years of carefree warmth in its company. Some initial experimentation with loading and running techniques will decide your normal routine. If you have any problems after this short learning phase, please refer to your stove dealer. Should they be unable to help for any reason, please contact us in writing at the address on the front of this publication.

3.5 Parts diagram for model Morsø 3600



3.6 Parts list for model Morsø 3600

Pos.No.	Parts
1	Base plate
2	Front frame
3	Door right
4	Side plate
5	Side frame
6	Door side
7	Inside rear plate
8	Top plate
9	Door left
10	Intermediate frame
11	Grate
12	Outside back plate
13	Inside top plate
14	Fire plate for side door
15	Fire plate for side plate
16	Baffle plate, cast iron
17	Leg
18	Front grate
19	Cover
20	Flue collar
21	Baffle plate, stainless
22	Convection rear plate
23	Stone side door
24	Stone side plate
25	Angle brace f. fire plate
26	Angle brace f. sideframe (Left hand sidedoor)
27	Air adaptor
28	Ash tray
29	Radiant shielding, bottom
30	Draught control
31	Baffle plate, stainless, inside top
32	Plate for intermediate frame
33	Air inlet arm
34	Stone back
35	Securing bracket f. back brick
36	Insulation
37	Axis for handle
38	Axis for handle
39	Stainless handle for adjustment
40	Door handle, stainless steel
41	Ceramic glass
42	Fitting w. thread for flue collar
43	Assemble steel
44	Flat bar
45	Hinge pin
46	Hinge pin
47	Cotter pin

48	Distance tube
50	Distance tube
51	Distance tube
52	Pressure spring, stainless
53	Glass fitting
54	Washer
55	Washer
56	Washer
57	Washer
59	Screw
60	Screw
61	Screw
63	Screw
65	Screw
66	Screw
67	Screw
68	Screw
69	Screw
70	Screw
71	Screw
72	Distance tube
73	Screw
74	Screw
75	Screw
76	Nuts
77	Screw
78	Screw
79	Screw
80	Screw
81	Tightening tape
83	Hanging for handle

APPENDIX H

1. TUNNEL FLOW RATE

Tunnel flow rates are determined using the velocity pressure measurement made by a standard Pitot tube. The Pitot tube is located at the center of the dilution tunnel. Three x/y axis traverses were used to determine the relationship between the center velocity pressure and the average obtained by traversing. This procedure was carried out in accordance with EPA Method 2.

Velocity pressure and tunnel temperature data are used to calculate tunnel velocity via EPA Method 2, equation 2-9 as follows:

$$T_v = K_p * C_p * \sqrt{\Delta P} * \sqrt{\frac{T_s}{P_s * M_s}}$$

- Where:
- K_p = 85.49 (English units constant for ft/sec.)
 - F_p = Pitot tube center point coefficient determined from traverses
 - C_p = .99 Coefficient for standard pitot tube
 - ΔP = Pitot tube velocity pressure (in. w.c.)
 - T_s = Absolute tunnel temperature (1R)
 - P_s = Absolute tunnel pressure (in. Hg)
 - M_s = Mole. Wt. of tunnel gas stream (lb./lb.-mole, wet basis) = 29 * (1-.04) + 18 * .04 = 28.56
 - T_v = Tunnel velocity (ft./sec.)

Tunnel flow is calculated by multiplying the average velocity as calculated by the above formula by the following equation (adaptation of EPA Method 2, formula 2-10).

$$T_f = \bar{T}_v * 60 * 0.1961 * \frac{528}{TT_{ave}} * \frac{PS}{29.92} * 1 - .04$$

Where:

- \bar{T}_v
= Average tunnel velocity (ft/sec.)
- 0.1961 = Tunnel cross sectional area (ft²)
- T_f = Tunnel flow rate (SCFM)
- TT_{ave} = Average tunnel temp. (1R)
- PS = Average barometric pressure during test.
- 60 = sec. to min. conversion
- 0.04 = Assumed tunnel moisture content (4% by Vol.)

2. EMISSIONS RATE CALCULATION

Emissions rates are calculated from the total weight gain of the probe and first and second filters of each sampling system as follows:

$$ER = \left(\frac{T_f * Wt. Gain * 60}{vol. sampled} \right)^{0.83} * 1.82$$

Where: ER = Emissions rate (grams/hour OM7 equivalent)
Vol. Samp. = Total volume sampled (SCFM, Dry)
Wt. Gain = Total weight gain for filter system (grams)
T_f = Tunnel flow rate (SCFM, Dry)

3. CORRECTIONS TO STANDARD CONDITIONS

The tunnel flow rate is corrected to standard conditions through the EPA Method 2 formulae. The volume sampled is measured by dry gas meters and must be corrected for meter temperature and ambient barometric pressure. The inlet and outlet temperatures of each dry gas meter are measured and recorded at 10-minute intervals during the test. The ambient barometric pressure is recorded at the beginning and end of each test.

The following formula is used to correct the total volume as measured by the dry gas meter to total volume at standard conditions (681F, 29.92 in. Hg):

$$VOL_{std} = VOL_m * \frac{PS}{29.92} * \frac{528}{AMT} * Y$$

Where: VOL_{std} = Total volume in Standard Cubic Feet
VOL_m = Total volume as measured by dry gas meter.
PS = Average barometric pressure
AMT = Average meter temperature (1R)
Y = Dry gas meter calibration factor

EXAMPLE CALCULATIONS

1. TUNNEL VELOCITY

INPUTS: P = .038 in. w.c.
T_s = 1001F
P_s = 29.3 in. Hg.
M_s = 28.56 lb./lb.-mole
C_p = .99
F_p = .945

$$T_v = 85.49 * .99 * .945 * \sqrt{.038} * \sqrt{\frac{560}{29.3 * 28.56}} = 12.754$$

2. TUNNEL FLOW RATE

INPUTS: T_v = 12.754 ft./sec.
TT_{ave} = 5601R
PS = 29.3 in. Hg.

$$T_f = 12.754 * 60 * 0.1961 * \frac{528}{560} * \frac{29.3}{29.92} * (1 - .04) = 133.0 \text{ SCFM}$$

3. EMISSIONS RATE

INPUTS: T_f = 133.0 SCFM
Wt. Gain = .0200 grams
Vol. Samp. = 100 Std. cubic feet

$$ER = \left(\frac{133 * .0200 * 60}{100} \right)_{.83} * 1.82 = 2.68 \text{ grams / hour}$$

4. VOLUME CORRECTION FOR DRY GAS METERS

INPUTS: $VOL_m = 104.479$ (Metered Feet³)
 $PS = 29.3$ (Average baro. pressure)
 $AMT = 801F$ (Ave. meter temp.) = 5401R
 $Y = .9996$ (Meter cal. factor)

$$VOL_{std} = 104.479 * \frac{29.3}{29.92} * \frac{528}{540} * .9996 = 100.00 \text{ Standard Ft}^3$$

APPENDIX I

Warnock Hersey Efficiency Test Report

Manufacturer: Morso
 Model: 3600
 Date: 8/6/01
 Run: 1
 Control #: J20049092
 Test Duration: 270

Overall Heating Efficiency: 67.71%
 Combustion Efficiency: 90.76%
 Heat Transfer Efficiency: 74.61%

Heat Output: 16303 BTU/Hr 17186 KJ/Hr
 Heat Input: 24076 BTU/Hr 25381 KJ/Hr

Burn Duration: 4.50 Hours
 Burn Rate: 2.73 Lb/Hr 1.239 Kg/Hr
 Stack Temp: 336.1 Deg.F 168.9 Deg.C

	Start	End
Barometer (in.Hg):	29.3	29.3
Wet Bulb (F):		
Dry Bulb (F):	74	79
Humidity (%):	84	63

Average Stove Temperature: #DIV/0!
 Moisture content of wood (wet basis): 17.36
 Average: 1.16 7.53 12.12 336.11 90.00

-0.06163 0.34342588 #DIV/0! #DIV/0! 7.34471 0.599

Elapsed Time	Weight Remaining	CO	CO ₂	O ₂	Flue Gas	Room Temp	Comb % K	Combust Eff %	Heat Transfer %	#DIV/0! Net Eff	7.34471 air Fuel	0.599 Unit MN
0	14.87	1.23	7.15	12.31	375	90	0.04	90.9%	22.7%	20.6%	8	6.75
10	13.00	1.70	5.17	14.11	438	90	0.49	74.2%	36.1%	26.8%	11	5.90
20	11.40	0.33	13.44	6.46	521	90	1.99	75.6%	57.7%	43.6%	6	5.17
30	9.40	0.35	13.98	6.35	536	90	2.48	72.2%	64.6%	46.7%	6	4.26
40	7.70	0.65	14.79	5.47	547	90	2.05	77.3%	71.0%	54.9%	6	3.49
50	6.40	0.39	14.01	6.16	522	90	0.81	89.4%	75.8%	67.7%	7	2.90
60	5.40	0.97	10.09	9.66	458	90	-0.04	95.8%	77.1%	73.8%	10	2.45
70	4.70	1.51	7.63	11.81	389	90	-0.34	97.2%	78.3%	76.1%	13	2.13
80	4.10	1.28	7.65	11.93	358	90	-0.47	101.3%	80.8%	81.8%	15	1.86
90	3.50	1.16	8.24	11.31	358	90	-0.68	106.4%	82.5%	87.8%	15	1.59
100	3.00	0.58	8.52	11.13	353	90	-1.06	119.8%	83.7%	100.3%	18	1.36
110	2.70	0.36	7.85	11.93	332	90	-1.10	125.4%	84.1%	105.5%	21	1.23
120	2.40	0.49	7.44	12.40	315	90	-0.93	120.6%	84.8%	102.2%	22	1.09
130	2.30	0.74	7.26	12.47	305	90	-0.88	116.9%	85.2%	99.5%	22	1.04
140	2.10	0.89	6.72	12.96	292	90	-0.83	115.3%	85.4%	98.4%	24	0.95
150	2.00	0.87	6.52	13.21	280	90	-0.79	114.6%	85.8%	98.4%	25	0.91
160	1.80	1.01	6.27	13.43	273	90	-0.72	111.5%	86.1%	96.0%	26	0.82
170	1.70	1.31	6.02	13.54	270	90	-0.66	107.0%	86.2%	92.2%	26	0.77
180	1.60	1.46	5.84	13.71	266	90	-0.56	102.6%	86.3%	88.6%	26	0.73
190	1.40	1.70	5.41	14.06	259	90	-0.47	97.9%	86.4%	84.6%	27	0.64
200	1.30	1.65	5.29	14.16	253	90	-0.53	100.2%	86.6%	86.8%	29	0.59
210	1.20	1.61	5.18	14.24	249	90	-0.60	102.8%	86.7%	89.1%	31	0.54
220	1.00	1.58	5.18	14.32	246	90	-0.51	100.2%	87.2%	87.4%	31	0.45
230	0.90	1.75	5.12	14.30	247	90	-0.47	97.4%	87.3%	85.0%	31	0.41
240	0.60	1.84	4.94	14.49	247	90	-0.37	93.3%	87.4%	81.6%	33	0.27
250	0.30	1.85	4.87	14.63	241	90	-0.25	89.4%	88.2%	78.8%	34	0.14
260	0.10	1.64	5.11	14.48	242	90	-0.28	92.3%	88.6%	75.7%	36	0.05
270	0.00	1.56	5.17	14.43	239	90	-0.32	94.3%	88.9%	83.8%	37	0.00

Warnock Hersey Efficiency Test Report

Manufacturer: Morso						
Model:	3600					
Date:	8/8/01					
Run:	2					
Control #:	J20049092					
Test Duration:	370					
		Start	End			
Barometer (in. Hg):		29.28	29.26			
Wet Bulb (F):						
Dry Bulb (F):		75	80			
Humidity (%):		72	67			
Average Stove Temperature:	#DIV/0!					
Moisture content of wood (wet basis):	16.96					
Average:	1.19	6.43	13.19	301.84	88.87	
Elapsed Time:	Weight Remaining	CO	CO ₂	O ₂	Flue Gas	Room Temp
0	15.54	0.51	7.90	11.90	324	90
10	14.10	0.84	5.96	14.01	434	90
20	12.9	0.4	11.03	9.28	480	90
30	11.40	0.35	13.72	6.91	515	90
40	10.20	0.48	14.20	6.35	527	89
50	8.60	0.48	14.74	5.59	544	90
60	6.80	0.28	13.09	7.30	509	90
70	5.90	0.49	9.51	10.65	439	90
80	5.30	0.60	8.90	11.20	406	90
90	5.00	0.91	8.61	11.28	393	90
100	4.70	0.77	7.27	12.51	351	90
110	4.40	0.66	7.03	12.73	332	89
120	4.20	0.40	6.99	12.86	315	89
130	4.00	0.63	6.57	13.21	301	90
140	3.80	0.74	6.59	13.11	294	90
150	3.60	0.87	6.01	13.74	281	89
160	3.50	0.85	5.77	13.95	268	89
170	3.30	1.08	5.54	14.08	263	89
180	3.20	1.22	5.47	14.08	257	89
190	2.90	1.18	5.55	14.00	254	89
200	2.70	1.41	5.29	14.17	250	88
210	2.60	1.32	5.32	14.26	247	88
220	2.40	1.42	5.24	14.21	246	88
230	2.20	1.65	4.66	14.58	241	88
240	2.10	1.82	4.46	14.70	237	89
250	1.90	1.83	4.40	14.76	233	88
260	1.80	1.72	4.29	14.95	231	88
270	1.60	1.90	3.93	15.15	225	88
280	1.50	1.83	4.42	14.83	223	88
290	1.20	1.88	4.01	15.14	218	88
300	1.10	1.84	3.68	15.54	213	88
310	1.00	1.77	3.51	15.66	208	88
320	0.80	1.85	3.45	15.73	204	88
330	0.70	1.88	3.44	15.74	202	88
340	0.60	1.87	3.28	15.88	200	88
350	0.40	1.68	3.60	15.77	202	88
360	0.20	1.89	3.47	15.72	201	88
370	0.00	1.88	3.48	15.73	202	88

Overall Heating Efficiency:			69.36%		
Combustion Efficiency:			91.47%		
Heat Transfer Efficiency:			75.83%		
Heat Output:	12678	BTU/Hr	13364	KJ/Hr	
Heat Input:	18277	BTU/Hr	19267	KJ/Hr	
Burn Duration:	6.17	Hours			
Burn Rate:	2.09	Lb/Hr	0.949	Kg/Hr	
Stack Temp:	301.8	Deg.F	149.9	Deg.C	
-0.10742	0.47977042	#DIV/0!	#DIV/0!	11.9425	0.886
Combust %	Combust Eff %	Heat Transfer	Net Eff	air	Unit
K	%	Transfer	Eff	Fuel	MN
-0.09	98.5%	33.8%	33.3%	8	7.05
0.64	77.7%	35.5%	27.6%	11	6.40
2.03	70.4%	49.6%	35.0%	6	5.85
3.21	64.7%	57.1%	36.9%	5	5.17
3.13	66.6%	62.5%	41.7%	5	4.63
2.25	75.7%	69.4%	52.5%	5	3.90
0.95	87.4%	75.1%	65.6%	7	3.09
0.12	95.3%	76.6%	73.0%	11	2.68
-0.08	98.0%	78.4%	76.9%	12	2.40
-0.19	98.1%	79.2%	77.7%	12	2.27
-0.58	107.9%	80.0%	86.3%	16	2.13
-0.76	113.9%	81.0%	92.3%	18	2.00
-0.75	116.7%	82.0%	95.7%	19	1.91
-0.82	117.3%	82.4%	96.7%	20	1.81
-0.86	117.1%	83.1%	97.3%	20	1.72
-0.72	112.9%	83.1%	93.8%	22	1.63
-0.79	115.9%	83.6%	96.9%	23	1.59
-0.75	112.5%	83.8%	94.3%	24	1.50
-0.73	110.6%	84.2%	93.1%	24	1.45
-0.78	112.4%	84.8%	95.4%	25	1.32
-0.72	108.4%	84.9%	92.1%	25	1.23
-0.64	106.8%	85.3%	91.1%	26	1.18
-0.73	108.9%	85.4%	93.0%	27	1.09
-0.83	110.5%	85.0%	93.9%	30	1.00
-0.80	107.7%	85.1%	91.6%	30	0.95
-0.79	107.4%	85.4%	91.7%	31	0.86
-0.78	108.4%	85.4%	92.6%	33	0.82
-0.84	109.2%	85.3%	93.1%	36	0.73
-0.67	102.9%	86.6%	89.2%	32	0.68
-0.75	105.9%	86.4%	91.5%	37	0.54
-0.70	104.6%	86.2%	90.1%	40	0.50
-0.82	111.3%	86.1%	95.8%	44	0.45
-0.73	106.3%	86.5%	92.0%	45	0.36
-0.70	104.6%	86.8%	90.8%	45	0.32
-0.74	106.5%	86.6%	92.2%	48	0.27
-0.60	102.8%	87.5%	89.9%	47	0.18
-0.65	102.3%	87.5%	84.2%	48	0.09
-0.64	102.1%	87.6%	89.4%	50	0.00

Warnock Hersey Efficiency Test Report

Manufacturer:	MORSO					
Model:	3600					
Date:	8/8/01					
Run:	3					
Control #:						
Test Duration:	85					
	Start	End				
Barometer (in.Hg):	29.04	29.03				
Wet Bulb (F):						
Dry Bulb (F):	74	86				
Humidity (%):	79	61				
Average Stove Temperature:	#DIV/0!					
Moisture content of wood (wet basis):	18.32					
Average:	0.19	9.10	11.04	714.70	89.80	
Elapsed Time:	Weight Remaining	CO	CO ₂	O ₂	Flue Gas	Room Temp
0:	15.69	0.02	0.19	19.79	658	88
10:	11.20	0.25	19.71	0.41	1046	90
20:	7.30	0.10	18.20	1.66	999	90
30:	3.70	0.04	13.65	6.13	855	90
40:	2.30	0.06	9.06	10.99	732	90
50:	1.60	0.07	7.38	12.92	659	90
60:	1.00	0.11	6.86	13.68	606	90
70:	0.60	0.25	5.70	14.66	554	90
80:	0.20	0.42	5.23	15.07	527	90
85:	0.00	0.58	5.04	15.22	511	90


Overall Heating Efficiency:	59.14%			
Combustion Efficiency:	77.07%			
Heat Transfer Efficiency:	76.74%			
Heat Output:	49937	BTU/Hr	52642	KJ/Hr
Heat Input:	84437	BTU/Hr	89012	KJ/Hr
Burn Duration:	1.42	Hours		
Burn Rate:	9.05	Lb/Hr	4.104	Kg/Hr
Stack Temp:	714.7	Deg.F	379.3	Deg.C
Combustion %	0.01231	0.10465447	#DIV/0!	#DIV/0!
Heat Transfer %	1.99657	0.244	*	*
Net Eff	air	Unit		
Fuel		MN		
0:	-1.37	-107.2%	-3.9%	4.2%
10:	3.71	70.7%	44.5%	31.5%
20:	0.94	91.2%	64.0%	58.4%
30:	-1.14	116.1%	72.7%	84.3%
40:	-0.98	122.1%	70.5%	86.1%
50:	-0.67	118.3%	69.3%	81.9%
60:	-0.44	112.1%	70.3%	78.8%
70:	-0.43	112.7%	68.9%	77.7%
80:	-0.36	108.6%	68.7%	66.1%
85:	-0.27	103.2%	69.0%	71.2%

Warnock Hersey Efficiency Test Report

Manufacturer: Morso						
Model: 3600						
Date: 8/9/01						
Run: 4						
Control #: J20049092						
Test Duration: 193						
		Start	End			
Barometer (in. Hg):		29	28.96			
Wet Bulb (F):						
Dry Bulb (F):		73	74			
Humidity (%):		63	70			
Average Stove Temperature: #DIV/0!						
Moisture content of wood (wet basis): 17.02						
Average:		0.61	6.73	13.29	438.62	88.10
Elapsed Time	Weight Remaining	CO	CO ₂	O ₂	Flue Gas	Room Temp
0	15.61	0.32	5.00	14.80	431	84
10	13.50	1.20	5.78	14.33	486	85
20	11.60	0.18	10.80	9.37	601	85
30	9.40	0.50	14.26	5.87	688	87
40	7.40	0.43	12.19	7.94	636	88
50	5.10	0.23	10.98	9.19	594	89
60	4.20	0.13	9.39	10.67	554	90
70	3.50	0.41	7.38	12.65	497	90
80	2.90	0.35	6.19	13.63	451	89
90	2.60	0.38	5.72	14.34	409	89
100	2.40	0.46	5.66	14.45	390	89
110	2.10	0.51	5.68	14.43	376	89
120	1.90	0.62	5.36	14.68	368	89
130	1.50	0.59	5.51	14.58	365	88
140	1.30	0.70	5.24	14.76	358	88
150	1.10	0.87	4.80	15.15	351	89
160	0.80	1.01	4.71	15.11	344	88
170	0.50	1.01	4.54	15.37	339	88
180	0.30	1.02	4.15	15.73	330	88
190	0.10	1.02	4.08	15.87	323	89
193	0.00	0.94	3.95	16.03	320	89

Overall Heating Efficiency:			65.26%
Combustion Efficiency:			92.15%
Heat Transfer Efficiency:			70.82%
Heat Output:	23263	BTU/Hr	24524 KJ/Hr
Heat Input:	35646	BTU/Hr	37577 KJ/Hr
Burn Duration:	3.22	Hours	
Burn Rate:	4.03	Lb/Hr	1.827 Kg/Hr
Stack Temp:	438.6	Deg.F	225.9 Deg.C
-0.0452	0.27222877	#DIV/0!	#DIV/0!
Combust %	Combust Eff %	Heat Transfer	Net Eff
K	%	Transfer	Eff
			air Unit
			Fuel MN
-0.53	115.8%	27.1%	31.3%
1.36	61.7%	27.1%	16.7%
1.59	76.0%	52.6%	39.9%
2.22	74.9%	61.3%	45.9%
0.89	86.8%	68.4%	59.4%
-0.25	102.8%	74.5%	76.6%
-0.75	114.3%	75.6%	86.4%
-0.70	114.6%	75.3%	86.3%
-1.08	132.6%	75.7%	100.3%
-0.76	122.3%	76.7%	93.8%
-0.64	116.8%	77.8%	90.9%
-0.60	114.8%	79.0%	90.6%
-0.61	114.4%	78.8%	90.2%
-0.55	112.7%	79.7%	89.8%
-0.58	113.0%	79.6%	89.9%
-0.51	108.8%	79.0%	86.0%
-0.55	108.9%	79.5%	86.6%
-0.42	104.0%	79.5%	82.6%
-0.45	105.5%	78.8%	83.1%
-0.35	101.1%	79.2%	73.5%
-0.38	103.5%	78.9%	81.6%
7.04944	0.492		

APPENDIX J



REORDER NO. 8385-45

Cole-Parmer Instrument Company
Chicago, Illinois 60648

PRINTED IN U.S.A.

REORDER NO. 8385-46

1000
 220049092
 upper
 combustion
 Start
 (2030) 8/3/0
 Morse
 60.0
 2 cr/hr
 ©

